



COLLEGE OF ENGINEERING

COMPREHENSIVE MASTER PLAN

February 2022

CLARK & ENERSEN

ACKNOWLEDGMENTS

This report was prepared by Clark & Enersen, along with our design partners EAPC, for the University of North Dakota College of Engineering. Thank you to the following people for their contributions to this report.



UNIVERSITY OF NORTH DAKOTA

- | | |
|---------------|-----------------|
| Les Bjore | Daba Gedafa |
| Brian Tande | Steve Burion |
| Mike Pieper | Anna Leddige |
| Bailey Bubach | Daba Gedafa |
| Michael Mann | Jaakko Putkonen |
| William Semke | Steve Brion |
| Anna Leddige | Ryan Adams |
| Frank Bowman | |



CLARK & ENERSEN

- Greg Lattig
Andy Stepp
Shawn Deiderich
Phillip Walter
Hannah Schafers



EAPC ARCHITECTS/ENGINEERS







- Casey Hutton
Brian Wetland
Derick Lunski



TABLE OF CONTENTS

| | | | |
|---|----------|---------------------------|----------|
| EXECUTIVE SUMMARY | A | PHASING AND COST | E |
| Goals and Objectives | 10 | Phasing Overview | 142 |
| Growth Analysis | 12 | Phase 1 | 148 |
| | | Phase 2 | 166 |
| | | Phase 3 | 184 |
| | | Phase 4 | 192 |
| | | Opinions of Probable Cost | 212 |
| | | Hyslop Starcher Site | 214 |
| EXISTING FACILITIES | B | APPENDIX | F |
| Campus Overview | 17 | Building Floor Plans | 218 |
| Harrington Hall | 21 | Design Iterations | |
| Upson II | 33 | Series 01 | 228 |
| Upson I | 43 | Series 02 | 223 |
| Leonard Hall | 59 | Series 03 | 240 |
| Collaborative Energy Center | 71 | | |
| SPACE ANALYSIS | C | | |
| Space Analysis Overview | 81 | | |
| Petroleum Engineering | 83 | | |
| Geology + Geological Engineering | 87 | | |
| Civil Engineering | 91 | | |
| Chemical Engineering | 95 | | |
| Electrical Engineering & Computer Science | 99 | | |
| Institute for Energy Studies | 103 | | |
| Mechanical Engineering | 107 | | |
| BioMedical Engineering | 111 | | |
| College of Engineering & Mines | 115 | | |
| Registrar | 119 | | |
| CONCEPTUAL PLANNING | D | | |
| Design Considerations | 124 | | |
| Massing Iterations | 128 | | |
| Conceptual Renderings | 132 | | |

LEGEND

| DEPARTMENTAL ACRONYMS | | SPACE TYPES ICONS | |
|--|--------|-------------------------|---|
| Petroleum Engineering | PE | Teaching Laboratories |  |
| Geology & Geological Engineering | GEO&GE | Research Laboratories |  |
| Civil Engineering | CE | Laboratory Support |  |
| Chemical Engineering | CHEM E | Lecture & Classroom |  |
| Electrical Engineering & Computer Science | EE&CS | Office & Administration |  |
| Institute for Energy Studies | IES | Other |  |
| Mechanical Engineering | MECH E | | |
| College of Engineering & Mines | COE | | |
| Registrar | REG | | |
| Bio Medical Engineering | BIO E | | |
| GENERAL ACRONYMS | | | |
| University of North Dakota | UND | | |
| Clark & Enersen | CE | | |
| Gross Square Feet | GSF | | |
| Net Square Feet | NSF | | |
| Net-To-Gross Ratio (i.e. NSF divided by GSF) | NTG | | |
| College of Engineering | COE | | |

A

EXECUTIVE SUMMARY

INTRODUCTION

This report has been assembled to describe various options for UND College of Engineering to respond to future growth challenges and existing deficiencies in the overall engineering complex. The college of Engineering occupies a complex of interconnected buildings built and joined together over the course of six decades. The facilities and systems that serve them are now in various states of age and condition and the evolution and enrollment of the various engineering departments has created a situation where the facilities are ill positioned to respond to modern teaching and research as well as planned growth projections within the college. The design team has been asked to investigate the condition of the facilities, quantify departmental growth and distribution across the complex and make recommendations for a long-term master plan for capital improvements to be implemented over time so that the college can respond to a host of coming challenges within it's curriculum.

EXECUTIVE SUMMARY

APPROACH AND PROCESS

The process of analyzing and formulating recommendations for the College of Engineering Masterplan involved three primary steps as follows: (1) Investigation and documentation of existing facilities and systems that make up the current complex. This included examination of existing drawings and documentation as well as on site investigation by architects and engineers to assess the type and condition of finishes, engineered systems, fixed furnishings and accessibility features in the existing complex. (2) Interviews with each department including department heads, faculty, administration and support staff to catalogue intended enrollment growth targets, identify programmatic deficiencies, and collect ideas that would enhance the college’s ability to attract students and faculty over the coming decades. (3) Formulation of various planning approaches that would pave the way for the college to meet the demands identified in step 2. This was an iterative process that involved the design team and building committee that met regularly over the duration of the endeavor. All information collected and iterative solutions identified are included in this document.

GOALS AND OBJECTIVES


- The goals and objectives of the long-range masterplan as delineated in the kick-off included the following primary points:
- Grow on campus enrollment to between 1,500 and 2,000 across all engineering departments
 - Create a facility layout that strikes a proper balance between inter departmental collaboration and departmental identity
 - Improve connectivity and wayfinding across entire complex
 - Rectify all accessibility issues with current facility
 - Reorganize complex to co-locate faculty groups
 - Create facility that allows for greater optimization and sharing of research space and equipment
 - Create a facility that improves ability to recruit both students and faculty
 - Increase ability to expand faculty count to improve faculty to student ratio
 - Expand access to computer classroom and work spaces
 - Improve HVAC and electrical infrastructure




GROWTH ANALYSIS

ENROLLMENT ANALYSIS

The bar graph below shows the current student enrollment and faculty/staff counts for each of the eight primary engineering departments. These numbers were collected during the initial departmental interviews to gain a snap shot in time of the general scope of the college as a whole. Additional breakdowns of the current enrollment and employment numbers are shown in the departmental discussions later in this document. Note that the numbers shown below represent overall raw enrollment numbers and do not breakdown the counts between on-campus and on-line students. As the discussion of growth projections proceeds on the following pages and in the main body of the document, particular attention is paid to the on-campus projections as this will have a greater impact on needed facilities.




USE NSF. The graphic below indicates existing square footage identified both by use and building location within the complex.



SPACE NEEDS ANALYSIS

One of the initial steps in the departmental interview process included collecting growth projections and initiatives. The interviews where this information was established included college administration, department chairs and all faculty members. Each of the main engineering departments took part and expressed their individual wishes and these meetings were followed up and further adjusted in subsequent meetings with Dean's office and primary building committee. The graph below shows the anticipated growth projections across the entire college of engineering. This data is further broken down by department and expressed in greater detail in the main body of the masterplan later in this document. Overall growth in all departments is shown for undergraduate students, masters students, PhD students and faculty.




DEPARTMENTAL NSF

The existing net square footage numbers in the tabulation shown below were established by extensive building tours and analysis of the existing floor plans. Additional breakdown of the space allocation by department is further delineated later in this document under the departmental description sections. The proposed Net square footage column comes from the current program plan that was created through an iterative process working with the college administration and building committee. The growth in net square footage was determined by identifying needs in the following categories:

- Growth in teaching and research and industrial laboratory space based on expressed needs coming from departmental discussions and reviewed by college administration and the building committee
- Provision of faculty and staff offices in accordance with growth projections (all faculty office spaces were sized according to current university guidelines and in some cases, square footage dedicated to office space was significantly reduced)
- Provision of adequate office space for on-campus masters and PhD students in accordance with growth projections
- Growth needs to accommodate new laboratory research and instructional initiatives

| DEPARTMENT | EXISTING NSF | PROPOSED NSF | PROPOSED GSF | |
|---|--------------|--------------|--------------|------|
| Petroleum Engineering | 9,199 | 17,228 | 30,225 | 87% |
| Geology & Geological Engineering | 32,063 | 28,559 | 50,104 | -11% |
| Civil Engineering | 14,373 | 22,540 | 39,544 | 57% |
| Chemical Engineering | 15,232 | 21,711 | 38,089 | 43% |
| Electrical Engineering & Computer Science | 13,812 | 19,453 | 34,128 | 41% |
| Institute for Energy Studies | 7,116 | 9,935 | 17,430 | 40% |
| Mechanical Engineering | 27,617 | 35,436 | 62,168 | 28% |
| College of Engineering | 22,952 | 24,404 | 42,814 | 6% |
| Registrar | 14,362 | 13,387 | 23,486 | -7% |
| Biomedical Engineering | 2,670 | 9,702 | 17,021 | 263% |
| Totals | 159,396 | 202,355 | 355,009 | 27% |



EXISTING FACILTIES


CAMPUS OVERVIEW

The college of Engineering complex includes five interconnected structures that have been built over the course of nearly 70 years. The east and west ends of the complex are the oldest and include Harrington Hall on the west, built in 1952 and Leonard Hall on the east, built in 1964. Upson I is the primary high bay laboratory space serving the college and was originally a stand-alone structure built in between Leonard and Harrington in 1971. In 1974, Upson II was constructed along the south side of Harrington Hall and was subsequently connected to Upson I via a single-story connector. The most recent major addition was the Collaborative Energy Complex, completed in 2016 between Leonard Hall and Upson I.

EXISTING FACILITIES OVERVIEW

WAYFINDING AND CIRCULATION

Wayfinding and general circulation across the engineering complex is not ideal. As the various additions have been added over the years, an east/west pathway has evolved that moves to the north and south in the area of Upson I and emerges into corridor built as part of the CEC construction before turning back to the north to enter Leonard Hall at the north end. The main on grade floors in most of the complex do align with the exception of the transition from CEC into Leonard Hall. The vertical offset in this area is approximately four feet. One of the main impediments to horizontal circulation is the varied story height of the buildings that make up the complex.





1952

62,895 GSF

The tables below show the square footage by use and department for Harrington Hall.

| STATS | |
|-------------------|------------|
| # OF LEVELS | 4 |
| NSF | 32,367 NSF |
| GSF | 62,895 GSF |
| SPACE TYPES (NSF) | |
| PE | - |
| GEO E | - |
| CIVIL E | 1,134 SF |
| CHEM E | 13,751 SF |
| EE&CS | 9,231 SF |
| IES | - |
| MECH E | - |
| BIO E | - |
| COE | 3,978 SF |
| REG | 4,273 SF |
| USE BREAKOUT | |
| TEACHING LAB | 5,309 SF |
| RESEARCH LAB | 12,055 SF |
| LAB SUPPORT | 2,739 SF |
| LECTURE | 4,273 SF |
| OFFICE + ADMIN | 6,270 SF |
| OTHER | 1,721 SF |

HARRINGTON HALL

BUILDING SUMMARY

Harrington Hall was constructed in 1952 and is comprised of approximately 62,895 gross square feet. The building is 3 stories above grade with a largely unoccupied basement area that mostly houses mechanical HVAC equipment. It appears that Harrington Hall was the Harrington Hall is the oldest portion of the complex and was one of the original campus buildings dedicated to engineering. The original construction consisted of a cast-in-place concrete structure with a three-story portion along the west and a large single story high bay on the east. Prior to the construction of Upson II, a three-story addition was added to the southeast corner structure, apparently to provide an interconnected series of mezzanines and high bay shafts to accommodate research and teaching in Chemical engineering. The façade is mostly brick with windows lined in stone tracery in a gothic motif, primarily along the west façade. Another major addition occurred in 2008 to north end of Harrington Hall to add office and some teaching space for the JODASS program. Harrington Hall connects directly to Upson II to the south. The floors and main corridor align, but there is a slight ramp up into Upson II (about 8 inches) on several floors.

Harrington Hall accommodates shared and dedicated program space for several departments. It is fair to say that among all of the buildings that make up the complex, Harrington Hall hosts the most diverse and wide-reaching collection of departmental spaces. The first floor spaces include several computer and electrical engineering laboratories of various sizes, a registrar scheduled classroom and the first floor of the chemical engineering teaching and research areas that is housed in the southeast three-story addition. The north end of the first floor is occupied by office space for the JODASS program. The second floor of Harrington Hall houses additional JODASS space, electrical engineering teaching laboratories as well as four EE&CS faculty offices, The second level of the Chemical Engineering teaching and research laboratories, a shared senior research projects lab, civil engineering computational spaces and three centrally scheduled classrooms. The third floor of Harrington Hall mostly houses spaces dedicated to Chemical Engineering including research labs, teaching labs and faculty offices.



DEPARTMENT BREAKOUT LEGEND

- | | | |
|---|--------------------------------|-----------------------------|
| CHEMICAL ENGINEERING | CIVIL ENGINEERING | BIOMEDICAL ENGINEERING |
| ELECTRICAL ENGINEERING + COMPUTER SCIENCE | COLLEGE OF ENGINEERING + MINES | INSTITUTE OF ENERGY STUDIES |
| GEOLOGY + GEOLOGICAL ENGINEERING | PETROLEUM ENGINEERING | BUILDING SUPPORT |
| MECHANICAL ENGINEERING | REGISTRAR | CIRCULATION |



USE BREAKOUT LEGEND

- | | |
|--------------------------------|------------------|
| CLASSROOM / LABORATORY SUPPORT | RESTROOMS |
| CLASSROOM / LABORATORY | BUILDING SUPPORT |
| HIGH BAY | CIRCULATION |
| OFFICE / ADMINISTRATION | |

MECHANICAL AND ELECTRICAL EVALUATION

BUILDING MECHANICAL UTILITIES

5" CI Sanitary sewer exits the west side of the building.
2" domestic water enters the north side of the building.
6" storm sewer exits the north side of the buildings.
6" LP steam main enters the west side of the building.
The 1-1/2" pumped condensate exits the west side of the building.
1-1/4" natural gas enters the west side of the building.

001 MECHANICAL ROOM - BASEMENT (FIG. 1.1 - 1.4)

The basement mechanical room contains a 1-1/2" HP steam service, steam pressure reducing station, 1-1/2" pumped condensate return, flash tank, pressure reducing station, sanitary sewer ejector pump, steam/domestic hot water heater, vacuum pump, as well as other various accessories. It appears that much of this equipment is original 1950s version with the exception of the steam pressure reducing station which appears to have been added or upgraded during the LAB 120 renovations. See photos of this area below.

ROOF - MECHANICAL (FIG. 1.5)

The roof contains multiple items. Roof mounted exhaust fans, mini split air cooled condensing units, roof drains, abandoned capped curbs, plumbing vents, as well as a chiller. The chiller is located on an old abandoned cooling tower curb.

JODSASS CENTER - FIRST AND SECOND FLOOR

HVAC SYSTEMS:

The HVAC system for this space is provided by a rooftop unit, with VAV boxes with hot water reheat for each zone. Hot water for reheats is created using a steam/heating water converter, condensate pump, and a pair of heating water pumps.

PLUMBING SYSTEMS: New plumbing services were provided for this space.

FIRE PROTECTION: This area is provided with a wet sprinkler system with concealed heads.

120 LAB - FIRST FLOOR (FIG. 1.6)

HVAC SYSTEMS: The HVAC system for this space is provide by a dedicated rooftop unit, with VAV boxes with hot water reheat for each of the 6 zones. Equipment appears to be early 2000 version. Hot water for reheats is created using steam/heating water converter, condensate and a pair of heating water pumps located in the basement MER.of Upson II. A new chiller was installed for this system around 2014.

PLUMBING SYSTEMS: Typical, no notable issues.

FIRE PROTECTION: No fire protection was observed.



FIGURE 1.1
Steam Pressure Reducing Station



FIGURE 1.2
Controls Air Compressor



FIGURE 1.3
Sewage Ejector Pump



FIGURE 1.4
Domestic Water Heater



FIGURE 1.5
Mini Split ACCUs



FIGURE 1.6
Lab 120 HVAC

160 LAB - FIRST FLOOR (FIG. 1.7 - 1.9)

HVAC SYSTEMS: This area was constructed as part of the 1969 Upson I project. This area is served by a dedicated air handling unit (AHU-12). This area is very compact and maintenance for this equipment is very tight. This unit is provided with steam heating. The cooling for this air handling unit is provided by a chiller mounted on the roof. There is a dedicated exhaust system that serves a jet turbine engine that was installed in 2010. This exhaust system exits the lab and runs up the exterior of the building to 15' above the adjacent roof.

PLUMBING SYSTEMS: Typical, no notable issues.

FIRE PROTECTION: No fire protection was observed.

FIRST FLOOR - WEST SIDE

HVAC SYSTEMS: In general, most of this floor is heated with perimeter steam unit ventilators and steam perimeter radiation. The controls are predominantly pneumatic.

PLUMBING SYSTEMS: The plumbing fixtures appear to have been replaced at some point and are in good working condition. The drain, waste, and vent piping as well as the domestic water piping within the ceilings and walls were not accessible at the time of our visit. It is assumed that most of the piping is original to the building.

FIRE PROTECTION: No fire protection was observed.

SECOND FLOOR (FIG. 1.10)

HVAC SYSTEMS: The northwest portion of this floor appears to be mostly original equipment. Steam unit ventilators, and perimeter radiation provide heating. No cooling is provided in these areas. The south west and southeast portions are provided with heating and cooling from an air handling unit installed in the penthouse mechanical room of Upson II. This is a multizone unit that serves various areas of both Harrington and Upson II. The large middle classroom 218 is provided the newer Trane PTAC units for HVAC.

PLUMBING SYSTEMS: Typical, no notable issues.

260 LAB - SECOND FLOOR (FIG. 1.11 - 1.15)

HVAC SYSTEMS: This area was constructed as part of the 1969 Upson I project. It was updated with new HVAC in 1997. This space is served by a dedicated make up air unit (AHU-13). There are 7 individual terminal coils for 7 different zone controls. This lab is served by a single roof mounted exhaust fan that is connected to 4 fume hoods. This fan also has a heat recovery coil in the main exhaust duct trunk. The make-up air unit is served heating water and chilled water. Heating water is created through a steam/heating water heat exchanger located in the mechanical room 260D. The chilled water equipment is actually located in a penthouse located on the roof of Upson II. A new chiller was installed for this system around 2014.

PLUMBING SYSTEMS: Acid waste sinks are located in this lab.

FIRE PROTECTION: No fire protection was observed.




FIGURE 1.7
Lab 160 AHU-12 End View



FIGURE 1.8
Lab 160 AHU-12 Side View



FIGURE 1.9
AHU-12 Chiller



FIGURE 1.10
Steam Pressure Reducing Station



FIGURE 1.11
Steam Pressure Reducing Station



FIGURE 1.12
Steam Pressure Reducing Station

THIRD FLOOR (FIG. 1.16 - 1.17)

HVAC SYSTEMS: It appears that most of this floor has the original heating equipment. Steam unit ventilators and perimeter radiation provide heat. There is little to no ventilation in this floor. Lab 321 has 3 large fume hoods. These would be served by 3 roof mounted exhaust fans with risers. The offices 322-323 are provided with individual split system air conditioners.

PLUMBING SYSTEMS: It should be noted that there is little to no water pressure in the men's restroom. This may be indicative of piping issues. The lab areas on the west end are provided with acid waste, natural gas, compressed air, and vacuum piping.

FIRE PROTECTION: No fire protection was observed.

360 LAB - THIRD FLOOR (FIG. 1.18)

HVAC SYSTEMS: This area was constructed as part of the 1969 Upson I project. This area is served by a dedicated air handling unit (AHU-14). This unit uses steam as a heat source. No cooling was observed for this unit.

PLUMBING SYSTEMS: Other than the pressure issue listed above, no other issues were noted.

FIRE PROTECTION: No fire protection was observed.

ELECTRICAL - FULL BUILDING

ELECTRICAL SYSTEM: The electrical system is a 1600A 208/120V service located in room #2 of the basement. An arc flash study was performed on this equipment; however, it does not indicate when this work was done. The panel doesn't look very old, but we cannot confirm the age of the panelboard.

LIGHTING: The majority of the lights are standard T8 2x4 fixtures or 1x4 flush mounted fixtures. In the main display area, there are accent lights.

FIRE ALARM: The notification devices are fairly new, we were not able locate the fire alarm panel.

DATA: A combination of surface raceway and flush mounted data was installed in offices and classrooms.



FIGURE 1.13
Typical Fume Hood




FIGURE 1.14
Chilled Water Pumps located in Upson II Penthouse



FIGURE 1.15
New Chiller (2014) for Lab 160 MAU AHU-13





FIGURE 1.16
Lab 321 Hoods




FIGURE 1.17
Lab 321 Hood Exhaust Fans



FIGURE 1.18
Lab 320 AHU-14




- 1 CODE ISSUE: ADA ACCESSIBILITY
- 2 CODE ISSUE: EGRESS PATHWAY
- INTERIOR CONDITIONS**
5=BEST 1=WORST
-  NO ACCESS

A# FLOOR COVERING (TYPE + CONDITION)

- | | |
|-----------------|------------------|
| A: CARPET | G: CERAMIC TILE |
| B: EXP CONCRETE | H: RUBBER |
| C: SHEET VINYL | I: ASBESTOS TILE |
| D: EPOXY | J: TERRAZZO |
| E: VCT | K: RAISED FLOOR |
| F: LVT | |

A# WALLS (TYPE + CONDITION)

- | | |
|-----------------|-------------------|
| A: DRYWALL | H: EXP BRICK |
| B: CMU | I: PLASTER/STUCCO |
| C: BRICK | J: BURNISHED CMU |
| D: CONCRETE | K: GLAZED CMU |
| E: PAINT | L: STONE |
| F: WOOD | M: ACOUSTIC TILE |
| G: CERAMIC TILE | |



A# CEILINGS (TYPE + CONDITION)

- A: GYP BOARD D: WOOD
B: ACT E: ADHERED TILE
C: EXPOSED

A# CASEWORK (TYPE + CONDITION)

- A: PLAM D: TLT PARTITION
B: WOOD E: STEEL
C: DISPLAY CASE

A EQUIPMENT (TYPE + CONDITION)

- A: COPY MACHINE H: -4 C FREEZER
B: VIDEO SCREEN I: LASER TABLE
C: PROJECTOR J: CONFERENCE TV
D: SMARTBOARD K: WHITE BOARD
E: REFRIGERATOR L: VENDING MACHINE
F: -80 C FREEZER M: LAB HOOD
G: -20 C FREEZER N: SCALE-UP



1974

46,452 GSF

The tables below show the square footage by use and department for Upson II.


| STATS | |
|-------------------|------------|
| # OF LEVELS | 4 |
| NSF | 25,196 NSF |
| GSF | 46,452 GSF |
| SPACE TYPES (NSF) | |
| PE | - |
| GEO E | - |
| CIVIL E | 3,995 SF |
| CHEM E | 1,098 SF |
| EE&CS | 2,902 SF |
| IES | - |
| MECH E | 5,008 SF |
| BIO E | 2,670 SF |
| COE | 7,060 SF |
| REG | 2,463 SF |
| USE BREAKOUT | |
| TEACHING LAB | 818 SF |
| RESEARCH LAB | 4,603 SF |
| LAB SUPPORT | 1,000 SF |
| LECTURE | 2,384 SF |
| OFFICE + ADMIN | 14,666 SF |
| OTHER | 1,725 SF |

UPSON II

BUILDING SUMMARY


Upson II was constructed in 1974 and is comprised of approximately 46,452 gross square feet. It includes three stories above grade plus an occupied basement. The structure occupies a narrow footprint with a cast-in-place concrete structure and brick façade with narrow aluminum framed windows and is inconsistent with the context of the adjoining Harrington Hall. Upson II mostly aligns and connects with all three floors of Harrington Hall and connects to the rest of the complex only at the ground level.

The basement of Upson II houses laboratory space for the Bio-engineering program and the Mechanical Engineering department as well as a shared core facility for imaging instrumentation. The Dean’s office for the College of Engineering and Mines is located on the first floor along with two, small underutilized classrooms and a portion of the faculty offices for Mechanical Engineering. The second floor is organized similarly to the first with two additional small classrooms and the majority of the faculty offices for Mechanical and Civil Engineering. The third floor includes the faculty offices for Electrical Engineering & Computer Science as well as faculty offices for Chemical Engineering. The third floor also includes two teaching / research laboratories for environmental engineering associated with the Chemical Engineering department and some space for graduate students in that program.



DEPARTMENT BREAKOUT LEGEND

- | | | |
|---|--------------------------------|-----------------------------|
| CHEMICAL ENGINEERING | CIVIL ENGINEERING | BIOMEDICAL ENGINEERING |
| ELECTRICAL ENGINEERING + COMPUTER SCIENCE | COLLEGE OF ENGINEERING + MINES | INSTITUTE OF ENERGY STUDIES |
| GEOLOGY + GEOLOGICAL ENGINEERING | PETROLEUM ENGINEERING | BUILDING SUPPORT |
| MECHANICAL ENGINEERING | REGISTRAR | CIRCULATION |



USE BREAKOUT LEGEND

- | | |
|--------------------------------|------------------|
| CLASSROOM / LABORATORY SUPPORT | RESTROOMS |
| CLASSROOM / LABORATORY | BUILDING SUPPORT |
| HIGH BAY | CIRCULATION |
| OFFICE / ADMINISTRATION | |

MECHANICAL SITE EVALUATION

BUILDING MECHANICAL UTILITIES

- 6" CI Sanitary sewer exits the west side of the building.
- 3" domestic water is connected to a 4" water main in the basement of Harrington hall on the north side of Upson II.
- 6" storm sewer exits the south side of the buildings.
- 2" HP steam main enters the west side of the building.
- 2" pumped condensate exits the west side of the building.
- 1-1/4" natural gas is connected to second floor Unit B located in Harrington Hall.
- 1" compressed air is connected to second floor Unit B located in Harrington Hall.

19 MECHANICAL ROOM - BASEMENT MIDDLE (FIG. 2.1 - 2.3)

There is a 9 zone multizone air handling unit in this space (AHU-3). This unit is provided with low pressure steam heating and chilled water cooling. This unit serves the entire basement area. There is a condensate pump and a sump pump also located in this room.

25 MECHANICAL ROOM - BASEMENT WEST (FIG. 2.4 - 2.5)

- HVAC SYSTEMS:** This area contains the steam and condensate service for the building, and a condensate pump.
- PLUMBING SYSTEMS:** This area contains a large base mounted sewage ejector pump.
- FIRE PROTECTION:** No fire protection was observed.

401 MECHANICAL PENTHOUSE (FIG. 2.6 - 2.8)

- HVAC SYSTEMS:** The penthouse contains two air handlers. AHU-1 is a dual duct (hot deck/cold deck) VAV system. This air handler serves first, second, and third floors. These floors have dual duct VAV Boxes. The second air handler AHU-2 serves portions of Harrington Hall and is discussed in other areas of this report. Each unit is provided with hot water heating and chilled water cooling. Heating water is provided through a steam/heating water heat exchanger and a pair of pumps. Chilled water is provided by a roof mounted chiller and a pair of pumps.
- PLUMBING SYSTEMS:** No issues were noted.
- FIRE PROTECTION:** No fire protection was observed.

BASEMENT FLOOR

- HVAC SYSTEMS:** This area is served by AHU-3. As described above, the area is provided with heating and cooling from the 9 zone multizone unit.
- PLUMBING SYSTEMS:** The main bathroom groups in the hallway have been upgraded. No issues were noted.
- FIRE PROTECTION:** No fire protection was observed.

FIRST FLOOR

- HVAC SYSTEMS:** This entire floor is served with dual duct VAV boxes with hot deck and cold deck ductwork. There are multiple zones throughout this space. The return air is handled through light troffers in the ceiling, they do not have typical return air grilles. The perimeter rooms are also provided with radiation along the exterior walls.
- PLUMBING SYSTEMS:** The plumbing fixtures appear to have been updated at some point. They appear to be in good working order.
- FIRE PROTECTION:** No fire protection was observed.

SECOND FLOOR

- HVAC SYSTEMS:** This entire floor is served with dual duct VAV boxes with hot deck and cold deck ductwork. There are multiple zones throughout this space. The return air is handled through light troffers in the ceiling, they do not have typical return air grilles. The perimeter rooms are also provided with radiation along the exterior walls.
- PLUMBING SYSTEMS:** The plumbing fixtures appear to have been updated at some point. They appear to be in good working order. The lab areas on the west end are provided with acid waste, natural gas, compressed air, and vacuum piping.
- FIRE PROTECTION:** No fire protection was observed.

THIRD FLOOR

- HVAC SYSTEMS:** This entire floor is served with dual duct VAV boxes with hot deck and cold deck ductwork. There are multiple zones throughout this space. The return air is handled through light troffers in the ceiling, they do not have typical return air grilles. The perimeter rooms are also provided with radiation along the exterior walls. There are two rooms on the west end of this floor with fume hoods and dedicated exhaust fans on the roof.
- PLUMBING SYSTEMS:** The plumbing fixtures appear to have been updated at some point. They appear to be in good working order. The lab areas on the west end are provided with acid waste, natural gas, compressed air, and vacuum piping.
- FIRE PROTECTION:** No fire protection was observed.



FIGURE 2.1
AHU-3 Multizone Air Handler



FIGURE 2.2
AHU-3 Multizone Air Handler



FIGURE 2.5
Sewage Pump



FIGURE 2.6
Air Handler AHU-1



FIGURE 2.3
Condensate Pump



FIGURE 2.4
Condensate Pump



FIGURE 2.7
Air Handler AHU-1



FIGURE 2.8
Chiller


ELECTRICAL - FULL BUILDING

ELECTRICAL SYSTEM: The electrical system was updated at one point to have a standby generator for the entire building. The main reason for this was to backup the State of ND servers located in the basement of this building. The servers have since been relocated to a different building. The existing generator is rated at 500KW 208/120V 3PH Diesel fueled with 400-gallon tank. In 2015 the additional cooling for the servers was also removed from the generator load.

LIGHTING: A majority of the rooms are standard T8 2x4 fixtures. The rooms appear to be well lit.


FIRE ALARM: The existing fire alarm panel is a Simplex 4020. It is located in RM 168 on first floor.

DATA: A combination of surface raceway and flush mounted data was installed in offices and classrooms.



KEYNOTE LEGEND

| | | | | | |
|--|---|--|---|---|---|
| <div>1</div> CODE ISSUE: ADA ACCESSIBILITY | <div>A#</div> FLOOR COVERING (TYPE + CONDITION) | <div>A#</div> WALLS (TYPE + CONDITION) | <div>A#</div> CEILINGS (TYPE + CONDITION) | <div>A#</div> CASEWORK (TYPE + CONDITION) | <div>A</div> EQUIPMENT (TYPE + CONDITION) |
| <div>2</div> CODE ISSUE: EGRESS PATHWAY | A: CARPET | A: DRYWALL | A: GYP BOARD | A: PLAM | A: COPY MACHINE |
| INTERIOR CONDITIONS 5=BEST 1=WORST | B: EXP CONCRETE | B: CMU | B: ACT | B: WOOD | B: VIDEO SCREEN |
| | C: SHEET VINYL | C: BRICK | C: EXPOSED | C: DISPLAY CASE | C: PROJECTOR |
| | D: EPOXY | D: CONCRETE | | | D: SMARTBOARD |
| | E: VCT | E: PAINT | | | E: REFRIGERATOR |
| | F: LVT | F: WOOD | | | F: -80 C FREEZER |
| | | G: CERAMIC TILE | | | G: -20 C FREEZER |
| | | H: EXP BRICK | | | H: -4 C FREEZER |
| | | I: PLASTER/STUCCO | | | I: LASER TABLE |
| | | J: BURNISHED CMU | | | J: CONFERENCE TV |
| | | K: GLAZED CMU | | | K: WHITE BOARD |
| | | L: STONE | | | L: VENDING MACHINE |
| | | M: ACOUSTIC TILE | | | M: LAB HOOD |
| | | | | | N: SCALE-UP |





1971

76,179 GSF

The tables below show the square footage by use and department for Upson I.

| STATS | |
|-------------------|------------|
| # OF LEVELS | 2 |
| NSF | 33,389 NSF |
| GSF | 76,179 GSF |
| SPACE TYPES (NSF) | |
| PE | - |
| GEO E | 9,244 SF |
| CIVIL E | 383 SF |
| CHEM E | - |
| EE&CS | - |
| IES | 22,609 SF |
| MECH E | - |
| BIO E | 1,153 SF |
| COE | - |
| REG | - |
| USE BREAKOUT | |
| TEACHING LAB | 10,124 SF |
| RESEARCH LAB | 11,463 SF |
| LAB SUPPORT | 10,030 SF |
| LECTURE | - |
| OFFICE + ADMIN | 1,772 SF |
| OTHER | - |

UPSON I

BUILDING SUMMARY

Upson I was constructed in 1971 and is comprised of approximately 76,179 gross square feet. It is a two story structure and was originally constructed to provide the bulk of the high bay, industrial teaching and research space for the Mechanical and Civil Engineering programs. Approximately two-thirds of it's footprint is a single tall story for high bay space along the eastern and western thirds while the center third of the building accommodates a mezzanine level with various medium and small sized spaces that serve as teaching laboratories and small graduate office and storage spaces. The façade of the building has very few windows and provides overhead sectional doors into the high bay spaces along the west side, creating large vehicle and equipment entrances for the high bay spaces. The high bay spaces along the east side of the facility do not have sufficient overhead door access.

The first floor high bay spaces generally accommodate Mechanical Engineering operations along the west side of the first floor and Civil Engineering spaces along the east. A large portion of the high bay spaces are served on each side by three bridge cranes that can move north and south over the top of the existing concrete masonry partitions separating the large high bay spaces. The center portion of the first floor provides storage and support space such as small lab alcoves, a welding shop and a laser laboratory. The second floor mezzanine area has a single, double loaded corridor running north and south and provides space for Mechanical Engineering teaching and research labs along with small office spaces for Civil and Mechanical Engineering graduate students as well as research spaces that are shared among various departments and programs.




SECOND FLOOR

FIRST FLOOR

DEPARTMENT BREAKOUT LEGEND

- | | | |
|---|--------------------------------|-----------------------------|
| CHEMICAL ENGINEERING | CIVIL ENGINEERING | BIOMEDICAL ENGINEERING |
| ELECTRICAL ENGINEERING + COMPUTER SCIENCE | COLLEGE OF ENGINEERING + MINES | INSTITUTE OF ENERGY STUDIES |
| GEOLOGY + GEOLOGICAL ENGINEERING | PETROLEUM ENGINEERING | BUILDING SUPPORT |
| MECHANICAL ENGINEERING | REGISTRAR | CIRCULATION |



SECOND FLOOR

FIRST FLOOR

USE BREAKOUT LEGEND

- | | |
|--------------------------------|------------------|
| CLASSROOM / LABORATORY SUPPORT | RESTROOMS |
| CLASSROOM / LABORATORY | BUILDING SUPPORT |
| HIGH BAY | CIRCULATION |
| OFFICE / ADMINISTRATION | |

MECHANICAL SITE EVALUATION

BUILDING MECHANICAL UTILITIES

- 6" CI Sanitary sewer exits the north side of the building.
- 6" domestic water service enters the building on the north side. This service runs around the entire building and also feeds Upson II and Harrington Hall.
- 8" storm sewer exits the southeast side of the building.
- 4" HP steam main enters the east side of the building.
- 2" pumped condensate exits the east side of the building.
- 4" natural gas enters the north side of the building. This service runs around the entire building and also feed Upson II and Harrington Hall.
- 2" compressed air enters the west side of the building.

005 MECHANICAL ROOM - BASEMENT (FIG. 3.1 - 3.5)

This room contains a steam pressure reducing station, steam/heating water converter, heating water pumps, vacuum pump, domestic hot water generator, 4" domestic water meter, air compressors, large in-line return/exhaust fan, and various other accessories. You can also access a series of lower level storage areas and a tunnel to the 4" 125# HP steam and 2" pumped condensate service from this space. There are three large base mounted pumps also installed in this room. These pumps are most likely used for a specific research project.

204 MECHANICAL ROOM - SECOND FLOOR NORTH (FIG. 3.6 - 3.7)

This room contains air handlers (AHU-10) and (AHU-11). These units are single zone and provided with steam heating and chilled water cooling. These units were installed new in 2020.

201B MECHANICAL ROOM - SECOND FLOOR SOUTH (FIG. 3.8 - 3.11)

This room contains all new equipment. Air handler (AHU-9), return fan, steam pressure reducing station, steam heat exchanger, heating pumps, air compressor, and various accessories. All of this equipment was new and installed in 2020.

ROOF - MECHANICAL (FIG. 3.12 - 3.14)

The roof contains typical mechanical equipment. Roof drains, roof hoods, a few exhaust fans, and two additional rooftop air handlers. The York RTU was new in 2020, the Trane RTU is older, around 2010.



FIGURE 3.1
Domestic Hot Water Generator, Steam Heat Exchanger, Heating Water Pumps



FIGURE 3.2
Heating Pumps



FIGURE 3.3
Steam / Heating Water Heat Exchanger



FIGURE 3.4
Return / Exhaust Fan



FIGURE 3.5
Research Project Pumps



FIGURE 3.6
Air Handler AHU-10



FIGURE 3.7
Air Handler AHU-11



FIGURE 3.8
Air Handler AHU-9



FIGURE 3.13
York Rooftop Unit



FIGURE 3.14
Trane Rooftop Unit



FIGURE 3.9
Return Air Fan



FIGURE 3.10
Steam Heat Exchanger



FIGURE 3.15
Air Handling Unit AHU-4



FIGURE 3.16
Ductwork from York to 100A-100C



FIGURE 3.11
Pumps



FIGURE 3.12
Roof




FIGURE 3.17
Ductwork from York RTU to 100A - 100C



FIGURE 3.18
Air Handling Unit AHU-5

100 RESEARCH - FIRST FLOOR (FIG. 3.15)

- HVAC SYSTEMS: This area is served by a single zone air handling unit (AHU-4) suspended from the ceiling. This unit was installed in 2020. This unit provides heating and cooling using steam and chilled water.
- PLUMBING SYSTEMS: Typical HW,CW, gas, compressed air as expected in this type of space.
- FIRE PROTECTION: No fire protection was observed.

100A - 100C RESEARCH - FIRST FLOOR (FIG. 3.16 - 3.17)

- HVAC SYSTEMS: This area is served by a single zone roof mounted air handling unit (York). This unit was installed in 2020. This unit provides heating and cooling using steam and chilled water. The coils for the heating and cooling are installed in the space below the roof.
- PLUMBING SYSTEMS: Typical HW,CW, gas, compressed air as expected in this type of space.
- FIRE PROTECTION: No fire protection was observed.

102 SHOP - FIRST FLOOR (FIG. 3.18)

- HVAC SYSTEMS: This area is served by a single zone air handling unit suspended from the roof structure (AHU-5). This system brings in fresh air from the roof as well as return air in from the space. This unit was installed in 2020. This unit provides heating and cooling using steam and chilled water.
- PLUMBING SYSTEMS: Typical HW,CW, gas, compressed air as expected in this type of space.
- FIRE PROTECTION: No fire protection was observed.

104 SHOP - FIRST FLOOR (FIG. 3.19)

- HVAC SYSTEMS: This area is served by a single zone air handling unit suspended from the roof structure (AHU-6). This system brings in fresh air from the roof as well as return air in from the space. This unit was installed in 2020. This unit provides heating and cooling using steam and chilled water.
- PLUMBING SYSTEMS: Typical HW,CW, gas, compressed air as expected in this type of space.
- FIRE PROTECTION: No fire protection was observed.

104 SHOP - FIRST FLOOR (FIG. 3.20)

- HVAC SYSTEMS: This area is served by a single zone air handling unit installed in MER 204 (AHU-10). This system brings in fresh air from the roof as well as return air in from the space. This unit was installed in 2020. The unit provides heating and cooling using steam and chilled water. There is also a central exhaust fan in the middle of the room at the roof level.
- PLUMBING SYSTEMS: Typical HW,CW, gas, compressed air as expected in this type of space.
- FIRE PROTECTION: No fire protection was observed.

150 CIVIL OFFICES / KILN - FIRST FLOOR (FIG. 3.21 - 3.24)

- HVAC SYSTEMS: This area is served by a single zone rooftop air handling unit installed on the roof (RTU). This system brings in fresh air from the roof and provide make up air for the welding shop 105 and the wood shop 111. This unit was installed in 2020. The unit provides heating and cooling using steam and chilled water. There are also two original 1969 exhaust fans on the roof. One each for the welding shop and wood shop.
- PLUMBING SYSTEMS: Typical HW,CW, gas, compressed air as expected in this type of space.
- FIRE PROTECTION: No fire protection was observed.

150 CIVIL OFFICES / KILN - FIRST FLOOR (FIG. 3.25)

- HVAC SYSTEMS: This area is served by a single zone air handling unit installed in MER 204 (AHU-11). This system brings in fresh air from the roof as well as return air in from the space. This unit was installed in 2020. The unit provides heating and cooling using steam and chilled water. There is also a central exhaust fan mounted on the roof that provides exhaust for various rooms in this area.
- PLUMBING SYSTEMS: Typical HW,CW, gas, compressed air as expected in this type of space.
- FIRE PROTECTION: No fire protection was observed.

112 HIGH BAY - FIRST FLOOR (FIG. 3.26 - 2.28)

- HVAC SYSTEMS: This area is served by a single zone air handling unit suspended from the roof structure (AHU-1). This system brings in fresh air from the roof as well as return air in from the space. This unit was installed in 2020. This unit provides heating and cooling using steam and chilled water. There is also a central exhaust fan in the middle of the room at the roof level. This area also contains a large hood and exhaust system. At this time, it appears that the exhaust system is abandoned. A Curing Room is also set up in this space. This room contains a series of misting heads to control humidity.
- PLUMBING SYSTEMS: Typical HW,CW, gas, compressed air as expected in this type of space.
- FIRE PROTECTION: No fire protection was observed.

113 HIGH BAY - FIRST FLOOR (FIG. 3.29)

- HVAC SYSTEMS: This area is served by a single zone air handling unit suspended from the roof structure (AHU-2). This system brings in fresh air from the roof as well as return air in from the space. This unit was installed in 2020. This unit provides heating and cooling using steam and chilled water. There is also a central exhaust fan in the middle of the room at the roof level.
- PLUMBING SYSTEMS: Typical HW,CW, gas, compressed air as expected in this type of space.
- FIRE PROTECTION: No fire protection was observed.

114 HIGH BAY - FIRST FLOOR (FIG. 3.30)

HVAC SYSTEMS: This area is served by a single zone air handling unit suspended from the roof structure (AHU-3). This system brings in fresh air from the roof as well as return air in from the space. This unit was installed in 2020. This unit provides heating and cooling using steam and chilled water. There is also a central exhaust fan in the middle of the room at the roof level. An additional dedicated engine exhaust fan is also provided along the east wall.

PLUMBING SYSTEMS: Typical HW,CW, gas, compressed air as expected in this type of space.

FIRE PROTECTION: No fire protection was observed.

SECOND FLOOR (FIG. 3.31)

HVAC SYSTEMS: The central portion of the first floor, between the large exterior labs, is served by AHU-9 which is located in MER 201B. This includes rooms 201 - 222, etc. This air handler is a dual duct unit with three separate sets of hot deck/cold deck mains. Each individual room is provided with a dual duct VAV box and provides individual zone control. There is no indication that these VAV boxes have been upgraded, they would be original to the 1969 building.

PLUMBING SYSTEMS: Typical HW,CW, gas, compressed air as expected in this type of space.

FIRE PROTECTION: No fire protection was observed.

ELECTRICAL - FULL BUILDING

ELECTRICAL SYSTEM: The electrical service is a 480V 3-Phase 800A service, it was installed in 1970. The main distribution panel is in the basement with a transformer mounted between the 480V 3 Phase service and the 208V 3 Phase distribution. The 208V 3Phase has a bolted pressure switch shown on the left in Figure 1. Clearance between walls and other equipment does not meet current spacing requirements. Additional distribution is located on the other side of the sections shown in Figure 1, see Figure 2 for back side.

LIGHTING: The existing lighting appears to be adequate for each of the spaces.

FIRE ALARM: The existing fire alarm panel is a Simplex 4020. It is located in the corridor outside of room 101 on the first floor.

DATA: A combination of surface raceway and flush mounted data was installed in offices and classrooms.



FIGURE 3.19
Air Handling Unit AHU-6



FIGURE 3.20
Air Handling Unit AHU-10



FIGURE 3.21
York Rooftop Unit



FIGURE 3.22
Welding and Wood Shop Exhaust Fans



FIGURE 3.23
Welding Area



FIGURE 3.24
Wood Shop Area



FIGURE 3.25
Air Handling Unit AHU-11



FIGURE 3.26
Air Handling Unit AHU-1



FIGURE 3.31
Air Handler AHU-9



FIGURE 3.27
Hood



FIGURE 3.28
Curing Room



FIGURE 3.29
Air Handler AHU-2







FIGURE 3.30
Air Handler AHU-3



KEYNOTE LEGEND

- 1 CODE ISSUE: ADA ACCESSIBILITY
- 2 CODE ISSUE: EGRESS PATHWAY
- INTERIOR CONDITIONS**
5=BEST 1=WORST
-  NO ACCESS

A# FLOOR COVERING (TYPE + CONDITION)

- A: CARPET G: CERAMIC TILE
B: EXP CONCRETE H: RUBBER
C: SHEET VINYL I: ASBESTOS TILE
D: EPOXY J: TERRAZZO
E: VCT K: RAISED FLOOR
F: LVT

A# WALLS (TYPE + CONDITION)

- | | |
|-----------------|-------------------|
| A: DRYWALL | H: EXP BRICK |
| B: CMU | I: PLASTER/STUCCO |
| C: BRICK | J: BURNISHED CMU |
| D: CONCRETE | K: GLAZED CMU |
| E: PAINT | L: STONE |
| F: WOOD | M: ACOUSTIC TILE |
| G: CERAMIC TILE | |

A# CEILINGS (TYPE + CONDITION)

- A: GYP BOARD D: WOOD
B: ACT E: ADHERED TILE
C: EXPOSED

A# CASEWORK (TYPE + CONDITION)

- A: PLAM
B: WOOD
C: DISPLAY CASE
D: TLT PARTITION
E: STEEL

A EQUIPMENT (TYPE + CONDITION)

- A: COPY MACHINE H: -4 C FREEZER
B: VIDEO SCREEN I: LASER TABLE
C: PROJECTOR J: CONFERENCE TV
D: SMARTBOARD K: WHITE BOARD
E: REFRIGERATOR L: VENDING MACHINE
F: -80 C FREEZER M: LAB HOOD
G: -20 C FREEZER N: LAB-UP



1964

68,690 GSF

The tables below show the square footage by use and department for Leonard Hall.


| STATS | |
|-------------------|------------|
| # OF LEVELS | 4 |
| NSF | 46,741 NSF |
| GSF | 68,690 GSF |
| SPACE TYPES (NSF) | |
| PE | 2,229 SF |
| GEO E | 32,063 SF |
| CIVIL E | - |
| CHEM E | - |
| EE&CS | 1,679 SF |
| IES | - |
| MECH E | - |
| BIO E | - |
| COE | 3,144 SF |
| REG | 7,626 SF |
| USE BREAKOUT | |
| TEACHING LAB | 10,285 SF |
| RESEARCH LAB | 4,773 SF |
| LAB SUPPORT | 6,719 SF |
| LECTURE | 5,614 SF |
| OFFICE + ADMIN | 10,443 SF |
| OTHER | 8,907 SF |

LEONARD HALL

BUILDING SUMMARY


Leonard Hall was constructed in 1964 and is comprised of approximately 68,690 gross square feet in a historic structure including a basement, three floors above grade and third floor clerestory and small penthouse. It was originally built as the home of the Geology Department and the masonry exterior and interior masonry construction near the main entrance and in the main lobby are in laid with various fossils and geological specimens. All four floors are organized along a single double loaded corridor with the exception of the third floor that has a secondary corridor along the eastern half of the floor plate. The structure is cast in place concrete. The structure also houses a large lecture hall on the northwest corner of the original structure.

Most of the building is assigned to the Geology and Geological Engineering Department with a few exceptions. The eastern half of the basement layout provides a large amount of storage and industrial wet lab space to serve as storage and prep space for the Geology department's large collection of fossil and geological specimens as well as field equipment storage and some geology teaching and research space. The west half the basement floor provides a series of small rooms that are largely dedicated to graduate student office space for the Petroleum Engineering program. The north end of the first floor provides the main east entrance into the engineering complex. The lobby space in this area was originally designed as a display and open museum space that is still used in the same manner today with numerous fossil and geological specimens. The double loaded corridor extending south from this area provides access to two of the larger registrar classrooms in the complex as well as two classrooms that have been assigned to the Electrical Engineering program for use as computational teaching and research laboratories. The balance of the space is assigned to Geology and Geological Engineering and includes teaching labs and faculty offices. The faculty offices for Geology on this floor and for the floors above were originally designed to be used as office space as well as faculty research space which creates faculty offices for this program that are in some cases as large as 400 net square feet. This is well outside of the current norm and campus standards for net assignable square feet for office space. The second floor of Leonard Hall includes three additional medium sized classrooms that are centrally scheduled by the registrar with the balance of the spaces assigned to the Geology and Geological Engineering department to accommodate teaching and research labs as well as additional large faculty offices. The third floor of Leonard Hall is almost entirely assigned to Geology and Geological Engineering to accommodate some of the smaller laboratory spaces in the program, additional large faculty offices and the FD Holland Jr Geology and Geological Engineering Library. The library occupies roughly one third of the assignable square footage of the floor and includes a relocated steel library stack mezzanine over a portion of the space to expand storage capacity.



DEPARTMENT BREAKOUT LEGEND

- | | | |
|---|----------------------------------|-------------------------------|
| ■ CHEMICAL ENGINEERING | ■ CIVIL ENGINEERING | ■ BIOMEDICAL ENGINEERING |
| ■ ELECTRICAL ENGINEERING + COMPUTER SCIENCE | ■ COLLEGE OF ENGINEERING + MINES | ■ INSTITUTE OF ENERGY STUDIES |
| ■ GEOLOGY + GEOLOGICAL ENGINEERING | ■ PETROLEUM ENGINEERING | ■ BUILDING SUPPORT |
| ■ MECHANICAL ENGINEERING | ■ REGISTRAR | ■ CIRCULATION |



USE BREAKOUT LEGEND

- | | |
|----------------------------------|--------------------|
| ■ CLASSROOM / LABORATORY SUPPORT | ■ RESTROOMS |
| ■ CLASSROOM / LABORATORY | ■ BUILDING SUPPORT |
| ■ HIGH BAY | ■ CIRCULATION |
| ■ OFFICE / ADMINISTRATION | |

MECHANICAL AND ELECTRICAL SITE EVALUATION

BUILDING MECHANICAL UTILITIES

There are two sanitary sewer services the exit the west side of the building. 5"CI and 4"CI.

There are two acid waste services the exit the west side of the building. 4"CI and 4"CI.

There are two storm sewer services the exit the west side of the building. 5"CI and 5"CI.

4" domestic water service enters the building on the north side toward the large lecture bowl.

3" HP steam main enters the south end of the large lecture bowl.

2" pumped condensate exits the south end of the large lecture bow.

2" natural gas enters the building on the north side toward the large lecture bowl.

002 MECHANICAL ROOM - BASEMENT (FIG. 4.1-4.6)

This room contains three air handlers (AHU-1, AHU-2, AHU-3), heating pumps, two steam/heating water heat exchangers, steam and condensate entrance, steam pressure reducing station, domestic water service, and various accessories. The air handlers were installed in 2020. They are served with hot water heating and chilled water cooling. The heating pumps and other remaining equipment appear to be original to the building in 1963. AHU-1 is a single zone unit and serves the basement with ventilation. AHU-2 is a single zone unit and serves the first floor with ventilation. AHU-3 is a single zone unit and serves the large lecture bowl #100 with ventilation. There is also a water-cooled chiller in this room.

PENTHOUSE AND ROOF - MECHANICAL (FIG. 4.7-4.8)

This penthouse contains an air handler (AHU-4). This unit is a dual duct VAV unit with hot deck/cold deck supply ductwork. This ductwork serves dual duct VAV boxes on the third floor. This unit is provided with heating water and DX for cooling. The roof area contains an air-cooled condensing unit and a fluid cooler. Both the air handler and the air-cooled condensing unit were replaced in 2020. The air-cooled condensing unit serves AHU-4. The fluid cooler must serve the chiller in the basement mechanical room which would serve AHU-1, AHU-2, and AHU-3. There is also a dual duct VAV box that serves the Library #326.

BASEMENT AREAS

HVAC SYSTEMS: This area is served by a dedicated air handler AHU-1. It is provided with hot water heating and chilled water cooling. The supply duct mains are routed down the main corridors with a supply grille feeding just inside the rooms. The return is drawn wild through a large wall grill in the main corridor. Each individual room is provided with perimeter radiation heating. There are no individual cooling zone controls. Besides the air handler, the rest of the heating equipment appears to be original to the 1963 building.

PLUMBING SYSTEMS: Typical for this type of space.

FIRE PROTECTION: No fire protection was observed.

FIRST FLOOR AREAS (FIG. 4.9-4.11)

HVAC SYSTEMS: The northern portion of this level is served by a dedicated air handler AHU-2. It is provided with hot water heating and chilled water cooling. The supply duct mains are routed down the main corridor with supply grilles in the ceiling of the north end rooms. The return is drawn wild through a large wall grill on the north end wall near the north stairs. Each individual room is provided with perimeter radiation heating and a few unit ventilators. Besides the unit ventilators, there are no other individual cooling zone controls for this end. Besides the air handler, the rest of the heating equipment appears to be original to the 1963 building. The south end of this level is provided with unit ventilators which provides a means of ventilation. These unit ventilators use heating hot water for heat, and chilled water for cooling. Some of the rooms are also provided with mini-split air conditions, either on the wall or in the ceiling. These rooms are 108, 110, and 112. There are reports that the unit ventilators no longer function properly and most likely no longer provide ventilation as originally intended. During the 2014 CEC project, fresh air was ducted to the west side unit ventilators because this new building covered outside air access.

PLUMBING SYSTEMS: Typical for this type of space. These fixtures appear to be original to the building.

FIRE PROTECTION: Fire protection was provided in this room under the CEC project in 2014.

SECOND FLOOR AREAS (FIG. 4.12-4.15)

HVAC SYSTEMS: This level is served by exterior unit ventilators. These unit ventilators us heating hot water for heat, and chilled water for cooling. The unit ventilators provide a source of fresh air to each space. This fresh air is pulled through the individual rooms and out into the corridor. From there it is exhausted out the north end of the corridor through a wall grille and an exhaust fan. The unit ventilators appear to be original to the 1963 building.

PLUMBING SYSTEMS: Typical for this type of space. These fixtures appear to be original to the building. Gas and compressed air are provided to lab type areas.

FIRE PROTECTION: No fire protection was observed.

201 LAB - SECOND FLOOR (FIG. 4.16)

HVAC SYSTEMS: This room is heated and cooled using a unit ventilator. This room also has a fume hood with a dedicated exhaust fan.

PLUMBING SYSTEMS: Typical lab type fixtures are provided in this room. They appear to be original to the building. Gas and compressed air are also provided at the labs.

FIRE PROTECTION: No fire protection was observed.

209 LAB - SECOND FLOOR

HVAC SYSTEMS: This room is heated and cooled using a unit ventilator. This room also has a fume hood with

a dedicated exhaust fan.

PLUMBING SYSTEMS: Typical lab type fixtures are provided in this room. They appear to be original to the building. Gas and compressed air are also provided at the labs

FIRE PROTECTION: No fire protection was observed.

212 LAB - SECOND FLOOR (FIG. 4.17)

HVAC SYSTEMS: This room is heated and cooled using a unit ventilator. This room also has a fume hood with a dedicated exhaust fan.

PLUMBING SYSTEMS: Typical lab type fixtures are provided in this room. They appear to be original to the building. Gas and compressed air are also provided at the labs

FIRE PROTECTION: No fire protection was observed.

THIRD FLOOR

HVAC SYSTEMS: This area is served by AHU-4 located in the penthouse. This unit is a hot deck/cold deck unit which serves multiple dual duct VAV boxes throughout this level. The main supply ductwork is routed above the main corridor. Each individual space is provided with a dual duct VAV box for individual zone control. The perimeter rooms are also provided with hot water radiation. Return air is drawn through a large wall grille in the corridor and up into the penthouse where it is wild back to the air handler. Looking at the available drawings, most of the VAV boxes would be original to the building.

PLUMBING SYSTEMS: Typical for this type of space.

FIRE PROTECTION: No fire protection was observed.

326 LIBRARY - THIRD FLOOR

HVAC SYSTEMS: This area is served by AHU-4 located in the penthouse. There is a single dual duct VAV box that is dedicated to this space to control the heating and cooling

PLUMBING SYSTEMS: Typical for this type of space.

FIRE PROTECTION: No fire protection was observed.

ELECTRICAL - FULL BUILDING

ELECTRICAL SYSTEM: In 2015 a new 208V 3PH 2000A service was added in room 26 of the basement. This new service back fed the existing service located in room 48 of the basement.

LIGHTING: The existing lighting appears to be adequate for each of the spaces.

FIRE ALARM: The existing fire alarm panel is a Simplex 4100U, it is located in room 48 of the basement.



FIGURE 4.1
Air Handler AHU-1



FIGURE 4.2
Air Handler AHU-2



FIGURE 4.3
Air Handler AHU-3



FIGURE 4.4
Steam Heat Exchangers



FIGURE 4.5
Heat Water Pumps



FIGURE 4.6
Domestic Water Generator



FIGURE 4.7
Air Cooled Condensing Unit



FIGURE 4.8
Fluid Cooler



FIGURE 4.13
Typical Unit Ventilator



FIGURE 4.14
Typical Wall Hung Water Closet



FIGURE 4.9
Typical Supply Register



FIGURE 4.10
Typical Unit Ventilators



FIGURE 4.15
Typical Wall Hung Lavatories



FIGURE 4.16
Fume Hood




FIGURE 4.11
Typical Ceiling Mounted Mini-Split Cooling Cassette



FIGURE 4.12
Typical Unit Ventilator



FIGURE 4.17
Fume Hood



2016
41,183 GSF


The tables below show the square footage by use and department for Collaborative Energy Center.

| STATS | |
|-------------------|------------|
| # OF LEVELS | 2 |
| NSF | 21,703 NSF |
| GSF | 41,183 GSF |
| SPACE TYPES (NSF) | |
| PE | 6,970 SF |
| GEO E | - |
| CIVIL E | - |
| CHEM E | - |
| EE&CS | - |
| IES | 7,116 SF |
| MECH E | - |
| BIO E | - |
| COE | 7,617 SF |
| REG | - |
| USE BREAKOUT | |
| TEACHING LAB | 2,332 SF |
| RESEARCH LAB | 6,321 SF |
| LAB SUPPORT | 2,013 SF |
| LECTURE | 2,086 SF |
| OFFICE + ADMIN | 7,817 SF |
| OTHER | 1,134 SF |

COLLABORATIVE ENERGY CENTER


BUILDING SUMMARY

The Collaborative Energy Center was constructed in 20016 and is comprised of approximately 41,183 gross square feet. It is the most recent addition to the complex and is a steel framed, two story addition constructed between Leonard Hall and Upson I, in some cases with the existing exterior façade and windows used as the interior wall surface. It is the only building within the complex that was built without a basement level. It was built primarily to provide space for the Petroleum Engineering program and the Institute for Energy Studies. The first floor provides space for Petroleum Engineering teaching and research laboratories and associated open faculty office space. It also provides shared research and student projects space as well as the lower level of the Institute for Energy Studies High Bay research lab. A connecting overhead door connects a fabrication bay to the northeast high bay space in Upson I. The main floor aligns with the adjacent space in Upson I and is offset from the adjoining Leonard Hall by approximately 4'-0". The second floor of the facility connects with the second floor of Leonard Hall at the south end of the structure, but does not communicate with any upper story space in Upon I. The second floor of the Collaborative Energy Center includes space for IES graduate students and a small shared wet laboratory as well as teaching and classroom spaces scheduled by the college and the executive training room.



DEPARTMENT BREAKOUT LEGEND

- | | | |
|---|--------------------------------|-----------------------------|
| CHEMICAL ENGINEERING | CIVIL ENGINEERING | BIOMEDICAL ENGINEERING |
| ELECTRICAL ENGINEERING + COMPUTER SCIENCE | COLLEGE OF ENGINEERING + MINES | INSTITUTE OF ENERGY STUDIES |
| GEOLOGY + GEOLOGICAL ENGINEERING | PETROLEUM ENGINEERING | BUILDING SUPPORT |
| MECHANICAL ENGINEERING | REGISTRAR | CIRCULATION |



USE BREAKOUT LEGEND

- | | |
|--------------------------------|------------------|
| CLASSROOM / LABORATORY SUPPORT | RESTROOMS |
| CLASSROOM / LABORATORY | BUILDING SUPPORT |
| HIGH BAY | CIRCULATION |
| OFFICE / ADMINISTRATION | |

MECHANICAL AND ELECTRICAL SITE EVALUATION

BUILDING MECHANICAL UTILITIES

- This building was constructed between two existing buildings and built over a rerouted 12" HP steam and 6" condensate main that serves the entire campus.
- 6" sanitary sewer exits the north end of the building.
- 10" storm sewer exits the south end of the building.
- 8" rain leader (storm sewer) also exits the south end of the building. This line serves Upson I.
- 3" domestic water service enters the building at the northwest corner.
- 3" HP steam taps off the campus main in the north end basement mechanical room.
- 2" pumped condensate taps into the campus main in the north end basement mechanical room.
- 2" natural gas enters the building on the north end.
- 6" fire protection service enters the northwest corner of the building.

MECHANICAL ROOM - BASEMENT

- HVAC SYSTEMS:** This area contains the steam and condensate service, steam pressure reducing station, flash tank, condensate pump, condensate meter, and various accessories. All of this equipment was installed in 2014.
- PLUMBING SYSTEMS:** Typical plumbing systems for these types of spaces. Sump pumps SP-2, SP-3 are provided for lower level floor drains and drain tile. These were new in 2014.
- FIRE PROTECTION:** Area is provided with a wet pipe fire protection system. Fire protection is also provided throughout the steam tunnel.

213 MECHANICAL ROOM - SECOND FLOOR (FIG. 5.1)

- HVAC SYSTEMS:** This area contains a steam/heating water heat exchanger, heating water pumps, chilled water pumps, glycol make up units, domestic water heater, and two energy recovery units (AHU-6 and AHU-7). Energy recovery units AHU-6 and AHU-7 exhaust air from the building, recover energy, and preheat/precool outside air before it is fed back to AHU-1 and AHU-2. AHU-6 tempers AHU-1. AHU-7 tempers for AHU-2. Heating water and chilled water is pumped from this room out to the various other roof mounted air handlers.
- PLUMBING SYSTEMS:** Typical plumbing systems for these types of spaces.
- FIRE PROTECTION:** Area is provided with a wet pipe fire protection system.

ROOF - MECHANICAL (FIG. 5.2 - 5.4)

- HVAC SYSTEMS:** The building is broken up into different space and usages. AHU-1, AHU-2, AHU-3, AHU-4 serve this building. Most of the mechanical equipment is located on the roof, with a few units inside mechanical rooms.




FIGURE 5.1
213 MER Equipment Layout

AHU-1 serves all the classrooms. This rooftop unit is provided with hot water heating and chilled water cooling. This unit serves multiple single duct VAV boxes with hot water reheats.

AHU-2 serves all the administration offices. This rooftop unit is provided with hot water heating and chilled water cooling. This unit serves multiple single duct VAV boxes with hot water reheats.

AHU-3 serves all the Petroleum Engineering Lab. This rooftop unit is provided with hot water heating and chilled water cooling. This unit serves various single duct VAV boxes with hot water reheats.

AHU-4 serves all the High Bay. This rooftop unit is provided with hot water heating and chilled water cooling. This unit serves various single duct VAV boxes with hot water reheats.

AHU-5 serves all the unit ventilators within Leonard Hall. This rooftop unit is provided with hot water heating and chilled water cooling. This unit simply provides tempered outside air to the unit ventilators that were covered up with this new building.

CHILLER CH-1 is a roof mounted air-cooled chiller. This chilled provides chilled water to all the air handlers for this building. The chilled water pumps are located in the second floor mechanical room.

PLUMBING SYSTEMS: Typical plumbing systems for these types of spaces.

FIRE PROTECTION: Area is provided with a wet pipe fire protection system.

SECOND FLOOR

HVAC SYSTEMS: All the spaces are provided with single duct VAV boxes with hot water reheat. The perimeter rooms are provided with hot water finned tube radiation. The VAV boxes that serve classroom type spaces are served by AHU-1. The VAV boxes that serve administration type spaces are served by AHU-2. All VAV boxes are provided with an Occupied/Standby/Unoccupied mode based on space occupancy sensors and time of day scheduling.

PLUMBING SYSTEMS: Typical plumbing systems for these types of spaces.

FIRE PROTECTION: Area is provided with a wet pipe fire protection system.

134 HIGH BAY - FIRST FLOOR

HVAC SYSTEMS: The high bay is served by AHU-4. All the spaces are provided with single duct VAV boxes with hot water reheat. Two dedicated roof mounted exhaust serve two hoods (HD-2, HD-3) in this area. The high bay itself was provided with basic HVAC. Any special provisions required for special research projects need to be provided as required. They are not part of the basic house system.

PLUMBING SYSTEMS: Typical plumbing systems for these types of spaces. Medical gas piping systems are also provided in this area.

FIRE PROTECTION: Area is provided with a wet pipe fire protection system.

136 SAMPLE PREP - FIRST FLOOR

HVAC SYSTEMS: This room is served by AHU-4. It is provided with a single duct VAV boxes with hot water reheat. A dedicated roof mounted exhaust fan serves a hood (HD-4) in this area.

PLUMBING SYSTEMS: Typical plumbing systems for these types of spaces. Medical gas piping systems are also provided in this area.

FIRE PROTECTION: Area is provided with a wet pipe fire protection system.

136 SAMPLE PREP - FIRST FLOOR

HVAC SYSTEMS: The high bay is served by AHU-3. All the spaces are provided with single duct VAV boxes with hot water reheat. A dedicated roof mounted exhaust serves one hood (HD-1) in this area.

PLUMBING SYSTEMS: Typical plumbing systems for these types of spaces. Medical gas piping systems are also provided in this area.

FIRE PROTECTION: Area is provided with a wet pipe fire protection system.

240 IES LAB - SECOND FLOOR (FIG. 5.5 - 5.6)

HVAC SYSTEMS: The IES Lab is served by AHU-2. This space is provided with a single duct VAV box with hot water reheat. Two dedicated roof mounted exhaust fans serve hood (HD-2) and hood (HD-3) in this room.

PLUMBING SYSTEMS: Typical plumbing systems for these types of spaces. Medical gas piping systems are also provided in this area. The domestic water is generated by a steam/water instantaneous water heater.

FIRE PROTECTION: Area is provided with a wet pipe fire protection system.



FIGURE 5.2
Typical Unit Ventilator



FIGURE 5.3
Typical Wall Hung Water Closet





FIGURE 5.4
Typical Wall Hung Lavatories



FIGURE 5.5
Fume Hood



FIGURE 5.5
Fume Hood



SPACE EVALUATION

INTRODUCTION

As part of this study, all departments within the College of Engineering and Mines participated in a series of interviews to discuss the current state of the department and project growth needs, both in terms of student and faculty counts as well as laboratory and office space to accommodate this growth and future expansion anticipated by new initiatives in the various programs. The following is a brief listing of those findings that were use d to formulate the long-term goals for the facilities.



PE

PETROLEUM ENGINEERING
DEPARTMENT SUMMARY

The Petroleum Engineering Department is primarily housed in the Collaborative Energy Center and the basement of Leonard Hall. The current enrollment in this program includes 140 undergraduate students, 20 master’s students and 60 PhD candidates with 7 full-time faculty positions. This enrollment typically ranks fourth in the nation among all petroleum engineering programs. The undergraduate student enrollment is projected to grow from 140 to 200 students in the near future while the graduate and PhD programs are planned to remain close to current levels into the future. With this growth, it is anticipated that 2 to 3 new faculty hires will be required for a total 10 full time positions.

The total net square footage within the existing engineering complex that is dedicated to Petroleum Engineering totals approximately 9,200 nsf. The department also utilizes a remote high bay site at a former power plant that provides additional industrial lab space that is approximately 10,200 square feet. The college uses this space for research involving large drill rigs and full-scale extraction equipment. The possibility of planning for new space to accommodate this full-scale equipment on campus as part of an expanded engineering complex was discussed, but it was decided that at this time, it would be difficult and potentially unsafe to provide access into the heart of campus for this purpose.

| SPACE PROJECTIONS | CURRENT NSF | FUTURE NSF | PROGRAMMATIC CHANGES |
|---------------------------|-------------|------------|---|
| Net Square Feet (NSF) | | | |
| TEACHING LABORATORIES | 2,332 | 4,962 | 1. Petroleum Engineering Teaching Lab (146) is doubled in size |
| RESEARCH LABORATORIES | 2,480 | 4,658 | 2. New Computational Laboratory |
| LABORATORY SUPPORT | - | - | 3. Industrial Drill Laboratory |
| LECTURE AND CLASSROOM | - | - | 4. Existing Wet Research Laboratory is doubled |
| OFFICE AND ADMINISTRATION | 4,387 | 7,608 | 5. Faculty Office count grows from 7 to 10 |
| OTHER | - | - | 6. Visiting Faculty Offices are added |
| TOTAL | 9,199 | 17,288 | 7. Staff and Administrative Office count grows from 2 to 10 |
| | | | 8. PhD Office count to accommodate 60 occupants (existing shown for approximately 48 occupants) |
| | | | 87% Increase |

| PERSONNEL PROJECTIONS | CURRENT | FUTURE | NOTES |
|------------------------------|---------|---------------|-------|
| C/O: On Campus/Online | | | |
| UNDERGRADUATE STUDENTS (C/O) | 140 / - | 200 / - | |
| MASTERS STUDENTS (C/O) | 20 / - | 20 / - | |
| PHD STUDENTS (C/O) | 60 / - | 60 / - | |
| FACULTY | 7 | 10 (+ 10 FT) | |
| NSF PER STUDENT ON CAMPUS | 42 NSF | 60 NSF | |

SPACE SUMMARY



Teaching Laboratories

| | | | | | | | |
|---|-----|-------|---|-------|-------|-------|-------|
| Virtual Reality Laboratory | 140 | 605 | 1 | 605 | 605 | 0 | 1,061 |
| PE Teaching Laboratory | 146 | 1,000 | 1 | 2,178 | 2,178 | 1,178 | 3,821 |
| Drill Simulation Laboratory | 148 | 727 | 1 | 727 | 727 | 0 | 1,275 |
| Industry Partner Computational Laboratory | New | 0 | 1 | 1,452 | 1,452 | 1,452 | 2,547 |



Research Laboratories

| | | | | | | | |
|----------------------------|-----|-------|---|-------|-------|-------|-------|
| Hess Innovation Laboratory | 144 | 2,480 | 1 | 2,480 | 2,480 | 0 | 4,351 |
| New PE Research Laboratory | New | 0 | 1 | 2,178 | 2,178 | 2,178 | 3,821 |
| Drill Research High Bay | - | 0 | 0 | 0 | 0 | 0 | 0 |



Office & Administrative

| | | | | | | | |
|--------------------------------|------|-----|----|-----|-------|-------|-------|
| Department Chair Office | 113K | 203 | 1 | 170 | 170 | -33 | 298 |
| Faculty Office | 113C | 124 | 0 | 0 | 0 | -124 | 0 |
| Faculty Office | 113D | 115 | 0 | 0 | 0 | -115 | 0 |
| Faculty Office | 113E | 116 | 0 | 0 | 0 | -116 | 0 |
| Faculty Office | 113F | 117 | 0 | 0 | 0 | -117 | 0 |
| Faculty Office | 113G | 114 | 0 | 0 | 0 | -114 | 0 |
| Faculty Office | 113H | 109 | 0 | 0 | 0 | -109 | 0 |
| Faculty Office | 113J | 109 | 0 | 0 | 0 | -109 | 0 |
| Faculty Office | New | 0 | 10 | 120 | 1,200 | 1,200 | 2,105 |
| Visiting Faculty Office | New | 0 | 2 | 120 | 240 | 240 | 421 |
| Staff / Administrative Offices | 113A | 123 | 0 | 0 | 0 | -123 | 0 |
| Staff / Administrative Offices | 113B | 115 | 0 | 0 | 0 | -115 | 0 |
| Staff / Administrative Offices | New | 0 | 10 | 100 | 1,000 | 1,000 | 1,754 |
| PhD Office | 6 | 110 | 0 | 0 | 0 | -110 | 0 |
| PhD Office | 8 | 110 | 0 | 0 | 0 | -110 | 0 |
| PhD Office | 10 | 112 | 0 | 0 | 0 | -112 | 0 |
| PhD Office | 12 | 110 | 0 | 0 | 0 | -110 | 0 |
| PhD Office | 14 | 112 | 0 | 0 | 0 | -112 | 0 |
| PhD Office | 16 | 110 | 0 | 0 | 0 | -110 | 0 |
| PhD Office | 18 | 112 | 0 | 0 | 0 | -112 | 0 |
| PhD Office | 20 | 110 | 0 | 0 | 0 | -110 | 0 |
| PhD Office | 22 | 112 | 0 | 0 | 0 | -112 | 0 |
| PhD Office | 24 | 110 | 0 | 0 | 0 | -110 | 0 |
| PhD Office | 28 | 125 | 0 | 0 | 0 | -125 | 0 |
| PhD Office | 30 | 108 | 0 | 0 | 0 | -108 | 0 |
| PhD Office | 32 | 108 | 0 | 0 | 0 | -108 | 0 |
| PhD Office | 34 | 108 | 0 | 0 | 0 | -108 | 0 |
| PhD Office | 36 | 108 | 0 | 0 | 0 | -108 | 0 |
| PhD Office | 38 | 108 | 0 | 0 | 0 | -108 | 0 |
| PhD Office | 40 | 108 | 0 | 0 | 0 | -108 | 0 |
| PhD Office | 42 | 244 | 0 | 0 | 0 | -244 | 0 |

PhD Office

45

104

0

0

0

-104

0

PhD Office Cubicles

113 no.

715

0

0

0

-715

0

PhD Open Office

New

0

60

80

4,800

4,800

8,421

Student Work Space

113 so.

198

1

198

198

0

347

TOTALS

9,199

17,228

8,029

30,225



GEO E

The tables below show the net square footage, enrollment and full-time faculty numbers for both the current and future state associated within the Geology and Geological Engineering department to achieve the programmatic changes identified on the right. The tables on the following pages provide a listing of current and future space allocation throughout the complex to serve the department.

GEOLOGY + GEOLOGICAL ENGINEERING
DEPARTMENT SUMMARY





The Geology and Geological Engineering Department is primarily housed in Leonard Hall. The current enrollment in this program includes 45 undergraduate students and 15 master's students with 10 full-time faculty positions. This department differs from most others within the college in that it's curriculum includes a major earth science division that provides instruction to a broad portion of the campus (Geology 101 which serves 100 to 150 students per semester in multiple sections). Total enrollment in the program was 109 students as recently as 2015. It is assumed that current enrollment is at a low ebb and will recover quickly in the coming years. The undergraduate student enrollment is projected to grow from 45 to 120 students in the near future while the graduate program is projected to grow from 15 to 40 students. It is assumed that the current faculty count will be able to accommodate the expanded enrollment with little or no growth.



The total net square footage within the existing engineering complex that is dedicated to Geology and Geological Engineering is just over 32,000 nsf. While the department is projecting some growth and certain teaching labs need expansion, the right sizing of existing faculty office spaces creates a projection in net square footage that is actually less than the current totals.

| SPACE PROJECTIONS <small>Net Square Feet (NSF)</small> | CURRENT NSF | FUTURE NSF | PROGRAMMATIC CHANGES |
|---|-------------|------------|--|
| TEACHING LABORATORIES | 6,129 | 6,519 | 1. Geology 101 Teaching Laboratory is enlarged and Prep Space added |
| RESEARCH LABORATORIES | 4,773 | 5,136 | 2. Faculty offices are reduced from 11 spaces to 10 spaces and reduced in size |
| LABORATORY SUPPORT | 6,719 | 4,184 | 3. Average existing faculty office space size of those identified is 362 square feet |
| LECTURE AND CLASSROOM | 212 | 212 | 4. Grad Student / PhD Office space to accommodate 36 occupants (existing shown for approximately 18 occupants) |
| OFFICE AND ADMINISTRATION | 8,214 | 6,492 | |
| OTHER | 6,016 | 6,016 | |
| TOTAL | 32,063 | 28,559 | 12% Decrease |

| PERSONNEL PROJECTIONS <small>C/O: On Campus/Online</small> | CURRENT | FUTURE | NOTES |
|---|---------|---------|-------|
| UNDERGRADUATE STUDENTS (c/o) | 45 / - | 120 / - | |
| MASTERS STUDENTS (c/o) | 15 / - | 40 / - | |
| PHD STUDENTS (c/o) | - / - | - / - | |
| FACULTY | 10 | 10 | |
| NSF PER STUDENT ON CAMPUS | 541 NSF | 197 NSF | |

SPACE SUMMARY

| | # | EXT. NSF | QTY | NSF EA. | PROP. NSF | DIFF. | GSF |
|---|-----------------------|----------|-----|---------|-----------|--------|-------|
|  | Teaching Laboratories | | | | | | |
| Instruct / Res. Lab - Environmental Eng. | 3B | 304 | 1 | 304 | 304 | 0 | 533 |
| Instruct / Res. Lab - Geomorphology | 9 | 1,289 | 1 | 1,289 | 1,289 | 0 | 2,261 |
| Instruct / Res. Lab - Geo Engineering | 13 | 274 | 1 | 274 | 274 | 0 | 481 |
| Instruct / Res. Lab - Hydrology | 13A | 274 | 1 | 274 | 274 | 0 | 481 |
| Geology Computer Laboratory | 108 | 849 | 1 | 849 | 849 | 0 | 1,489 |
| Mineralogy Teaching Laboratory | 201 | 921 | 1 | 921 | 921 | 0 | 1,616 |
| Instruct / Res. Lab - Microscopy | 210 | 875 | 1 | 875 | 875 | 0 | 1,535 |
| Sedimentology Instructional Laboratory | 212 | 1,062 | 1 | 1,452 | 1,452 | 390 | 2,547 |
| Computer Teaching Laboratory | 315 | 281 | 1 | 281 | 281 | 0 | 493 |
|  | Research Laboratories | | | | | | |
| Research Lab - Geo Eng. | 5 | 608 | 1 | 608 | 608 | 0 | 1,067 |
| Geochemistry Research Laboratory | 205 | 809 | 1 | 809 | 809 | 0 | 1,419 |
| Mineralogy Research Laboratory | 206 | 595 | 1 | 595 | 595 | 0 | 1,044 |
| Paleontology Research & Teaching Laboratory | 209 | 1,123 | 1 | 1,123 | 1,123 | 0 | 1,970 |
| Geo Research Laboratory | 301 | 280 | 1 | 280 | 280 | 0 | 491 |
| Geo EARL Laboratory (Chem) | 303A | 459 | 1 | 459 | 459 | 0 | 805 |
| Geo EARL Laboratory | 303 | 243 | 1 | 243 | 243 | 0 | 426 |
| Geo EARL Laboratory (office) | 305 | 178 | 1 | 178 | 178 | 0 | 312 |
| Research Lab | 314A | 230 | 1 | 230 | 230 | 0 | 404 |
| Geo Research Laboratory | 322A | 248 | 1 | 248 | 248 | 0 | 435 |
| Geology 101 Prep Lab | New | 0 | 1 | 363 | 363 | 363 | 637 |
|  | Laboratory Support | | | | | | |
| Geo Specimen Storage | 1 | 376 | 0 | 376 | 0 | -376 | 0 |
| Field Equipment Storage | 11 | 611 | 1 | 611 | 611 | 0 | 1,072 |
| Storage / Shop | 44 | 216 | 1 | 216 | 216 | 0 | 379 |
| Geo & Geo Eng Storage | 2A | 457 | 0 | 457 | 0 | -457 | 0 |
| Geo & Geo Eng Storage | 2B | 125 | 0 | 125 | 0 | -125 | 0 |
| Geo & Geo Eng Storage | 2C | 130 | 0 | 130 | 0 | -130 | 0 |
| Geo & Geo Eng Storage | 2D | 170 | 0 | 170 | 0 | -170 | 0 |
| Geo & Geo Eng Storage | 2E | 115 | 0 | 115 | 0 | -115 | 0 |
| Rock Prep | 3 | 258 | 1 | 258 | 258 | 0 | 453 |
| Rock Prep Storage | 3A | 37 | 1 | 37 | 37 | 0 | 65 |
| Hydrology Equipment | 4 | 142 | 1 | 142 | 142 | 0 | 249 |
| Rock Saw Room | 9B | 301 | 1 | 301 | 301 | 0 | 528 |
| Geology Sample Recovery | 9A | 300 | 1 | 300 | 300 | 0 | 526 |
| Geology Field Gear & Collections | 15 | 617 | 1 | 617 | 617 | 0 | 1,082 |
| Geo Collections | 17 | 378 | 0 | 378 | 0 | -378 | 0 |
| Paleontology Collections | 104 | 774 | 0 | 774 | 0 | -774 | 0 |
| Instructional Collections | 106 | 274 | 0 | 274 | 0 | -274 | 0 |
| Paleontology Collections | 208 | 1,056 | 0 | 1,056 | 0 | -1,056 | 0 |
| Prep Lab? | 304 | 151 | 1 | 151 | 151 | 0 | 265 |
| Prep Lab? | 304A | 118 | 1 | 118 | 118 | 0 | 207 |
| Dark Room | 316 | 113 | 1 | 113 | 113 | 0 | 198 |
| High Density Specimen Storage | New | 0 | 1 | 1,320 | 1,320 | 1,320 | 2,316 |
|  | Lecture and Classroom | | | | | | |
| Instructional Recording Studio | 308 | 212 | 1 | 212 | 212 | 0 | 372 |

| | # | EXT. NSF | QTY | NSF EA. | PROP. NSF | DIFF. | GSF | |
|---|--|----------|--------|---------|-----------|--------|--------|--------|
|  | Office & Administrative | | | | | | | |
| | Department Chair Office | 103 | 389 | 1 | 170 | 170 | -219 | 298 |
| | Faculty Office | 114 | 426 | 0 | 0 | 0 | -426 | 0 |
| | Faculty Office | 202 | 454 | 0 | 0 | 0 | -454 | 0 |
| | Faculty Office | 204 | 454 | 0 | 0 | 0 | -454 | 0 |
| | Faculty Office | 207 | 430 | 0 | 0 | 0 | -430 | 0 |
| | Faculty Office | 213 | 468 | 0 | 0 | 0 | -468 | 0 |
| | Faculty Office | 313 | 281 | 0 | 0 | 0 | -281 | 0 |
| | Faculty Office | 317 | 281 | 0 | 0 | 0 | -281 | 0 |
| | Faculty Office | 322B | 254 | 0 | 0 | 0 | -254 | 0 |
| | Faculty Office | 322C | 218 | 0 | 0 | 0 | -218 | 0 |
| | Faculty Office | 324 | 362 | 0 | 0 | 0 | -362 | 0 |
| | Faculty Office | 330A | 329 | 0 | 0 | 0 | -329 | 0 |
| | Faculty Office | New | 0 | 10 | 120 | 1,200 | 1,200 | 2,105 |
| | Visiting Faculty Office | 321 | 236 | 1 | 120 | 120 | -116 | 211 |
| | Staff / Administrative Offices | 101 | 564 | 1 | 564 | 564 | 0 | 989 |
| | Staff / Administrative Offices | 101A | 286 | 1 | 286 | 286 | 0 | 502 |
| | Staff / Administrative Offices | 101B | 143 | 1 | 143 | 143 | 0 | 251 |
| | Conference Room | 105 | 446 | 1 | 446 | 446 | 0 | 782 |
| | Lab Director Office | 300 | 165 | 1 | 120 | 120 | -45 | 211 |
| | Faculty Lounge | 306 | 269 | 1 | 269 | 269 | 0 | 472 |
| | Grad Student Offices | 217 | 423 | 0 | 0 | 0 | -423 | 0 |
| | Grad Student Offices (2) | 309 | 178 | 0 | 0 | 0 | -178 | 0 |
| | Grad Student Offices (2) | 311 | 166 | 0 | 0 | 0 | -166 | 0 |
| | Grad Student Offices (2) | 312 | 114 | 0 | 0 | 0 | -114 | 0 |
| | Grad Students (5) | 319 | 281 | 0 | 0 | 0 | -281 | 0 |
| | FD Holland Jr. Library - Dir. Office | 326B | 174 | 1 | 174 | 174 | 0 | 305 |
| | Grad Students / PhD Offices | New | 0 | 36 | 80 | 2,880 | 2,880 | 5,053 |
|  | Other | | | | | | | |
| | Emeritus Faculty | 113 | 423 | 1 | 120 | 120 | -303 | 211 |
| | Student Study Area | 7 | 554 | 1 | 554 | 554 | 0 | 972 |
| | Storage / Library | 314 | 233 | 1 | 233 | 233 | 0 | 409 |
| | Geo Break Area | 318 | 274 | 1 | 274 | 274 | 0 | 481 |
| | FD Holland Jr. Geo Library | 326 | 1,793 | 1 | 1,793 | 1,793 | 0 | 3,146 |
| | FD Holland Jr. Library - Workroom | 326A | 199 | 1 | 199 | 199 | 0 | 349 |
| | FD Holland Jr. Geo Library - Mezzanine - 1 | 326 | 1,297 | 1 | 1,297 | 1,297 | 0 | 2,275 |
| | FD Holland Jr. Geo Library - Mezzanine - 2 | 328 | 315 | 1 | 315 | 315 | 0 | 553 |
| | FD Holland Jr. Geo Library - Map Room - 1 | 328 | 848 | 1 | 848 | 848 | 0 | 1,488 |
| | FD Holland Jr. Geo Library - Map Room - 2 | 330 | 503 | 1 | 503 | 503 | 0 | 882 |
| | TOTALS | | 32,063 | | | 28,559 | -3,504 | 50,104 |



CIVIL E

CIVIL ENGINEERING
DEPARTMENT SUMMARY

The Civil Engineering Department is primarily housed in Upson I and Upson II Halls. The current enrollment in this program has a significant on-line student component and includes 342 undergraduate students (89 on-campus; 253 on-line), 15 master's students and 7 PhD candidates with 7 full-time faculty positions. The enrollment is projected to grow to 360 undergraduate students (one-half on-line), 30 master's students and up to 20 PhD candidates. This enrollment growth will also lead to a full time faculty demand of 12 positions in an effort to improve the faculty to student ratio.

The total net square footage within the existing engineering complex that is dedicated to Civil Engineering is just over 14,000 nsf. The department has identified the need for additional conventional and high bay laboratory space to accommodate new initiatives in teaching and research centered around structural aging and assessment as well as student projects.

The tables below show the net square footage, enrollment and full-time faculty numbers for both the current and future state associated within the Civil Engineering department to achieve the programmatic changes identified on the right. The tables on the following pages provide a listing of current and future space allocation throughout the complex to serve the department.

| SPACE PROJECTIONS <small>Net Square Feet (NSF)</small> | CURRENT NSF | FUTURE NSF | PROGRAMMATIC CHANGES |
|---|-------------|------------|---|
| TEACHING LABORATORIES | 6,872 | 6,872 | <div>1. Addition of 3 major research laboratory spaces:<ul style="list-style-type: none">• High Bay Research Lab• Small Scale Bridge Laboratory• MICA (Modern Infrastructure Condition Assessment) Laboratory</div> <div>2. Faculty Office count grows from 9 to 12</div> <div>3. Grad Student / PhD Office space to accommodate 16 occupants (existing shown for approximately 12 occupants)</div> |
| RESEARCH LABORATORIES | 1,340 | 8,712 | |
| LABORATORY SUPPORT | 3,139 | 3,139 | |
| LECTURE AND CLASSROOM | - | - | |
| OFFICE AND ADMINISTRATION | 2,517 | 3,312 | |
| OTHER | 505 | 505 | |
| TOTAL | 14,373 | 22,540 | 56% Increase |

| PERSONNEL PROJECTIONS <small>C/O: On Campus/Online</small> | CURRENT | FUTURE | NOTES |
|---|----------|-----------|-------|
| UNDERGRADUATE STUDENTS (C/O) | 89 / 253 | 180 / 360 | |
| MASTERS STUDENTS (C/O) | 15 / - | 30 / - | |
| PHD STUDENTS (C/O) | 6 / 1 | 20 / 4 | |
| FACULTY | 7 | 12 | |
| NSF PER STUDENT ON CAMPUS | 130 NSF | 97 NSF | |

SPACE SUMMARY



Teaching Laboratories

| | | | | | | | |
|---------------------------------|-----|-------|---|-------|-------|---|-------|
| Concrete and Asphalt Laboratory | 112 | 3,130 | 1 | 3,130 | 3,130 | 0 | 5,491 |
| Steel and Concrete Laboratory | 113 | 3,342 | 1 | 3,342 | 3,342 | 0 | 5,863 |
| Computational Laboratory | 215 | 400 | 1 | 400 | 400 | 0 | 702 |



Research Laboratories

| | | | | | | | |
|---------------------------------|-----|-----|---|-------|-------|-------|-------|
| Environmental Engineering Lab 1 | 362 | 734 | 1 | 726 | 726 | -8 | 1,274 |
| Environmental Engineering Lab 2 | 363 | 606 | 1 | 726 | 726 | 120 | 1,274 |
| Industrial Research Laboratory | New | 0 | 1 | 2,904 | 2,904 | 2,904 | 5,095 |
| Bridge Lab | New | 0 | 1 | 1,452 | 1,452 | 1,452 | 2,547 |
| MICA Laboratory | New | 0 | 1 | 2,904 | 2,904 | 2,904 | 5,095 |



Laboratory Support

| | | | | | | | |
|--------------------------|------|-----|---|-----|-----|---|-------|
| Basement Storage | 2 | 370 | 1 | 370 | 370 | 0 | 649 |
| Basement Storage | 3 | 370 | 1 | 370 | 370 | 0 | 649 |
| Basement Pump Room | 18 | 380 | 1 | 380 | 380 | 0 | 667 |
| Equipment Storage | 100A | 141 | 1 | 141 | 141 | 0 | 247 |
| Surveying Equipment | 106I | 155 | 1 | 155 | 155 | 0 | 272 |
| Asphalt Binding Room | 106H | 261 | 1 | 261 | 261 | 0 | 458 |
| Water Sampling Equipment | 106F | 41 | 1 | 41 | 41 | 0 | 72 |
| Curing Room | 112A | 103 | 1 | 103 | 103 | 0 | 181 |
| Equipment Room | 112B | 101 | 1 | 101 | 101 | 0 | 177 |
| Storage Room | 112C | 156 | 1 | 156 | 156 | 0 | 274 |
| Storage Room | 112D | 101 | 1 | 101 | 101 | 0 | 177 |
| Mezzanine | 227 | 689 | 1 | 689 | 689 | 0 | 1,209 |
| Lab Storage | 363A | 90 | 1 | 90 | 90 | 0 | 158 |
| Lab Storage | 363B | 104 | 1 | 104 | 104 | 0 | 182 |
| Prep Lab | 364 | 77 | 1 | 77 | 77 | 0 | 135 |



Office & Administrative

| | | | | | | | |
|--------------------------|------|-----|----|-----|-------|-------|-------|
| Department Chair Civil E | 260P | 120 | 1 | 170 | 170 | 50 | 298 |
| Faculty Office | 260A | 157 | 0 | 0 | 0 | -157 | 0 |
| Faculty Office | 260B | 110 | 0 | 0 | 0 | -110 | 0 |
| Faculty Office | 260C | 108 | 0 | 0 | 0 | -108 | 0 |
| Faculty Office | 260D | 120 | 0 | 0 | 0 | -120 | 0 |
| Faculty Office | 260E | 105 | 0 | 0 | 0 | -105 | 0 |
| Faculty Office | 260J | 164 | 0 | 0 | 0 | -164 | 0 |
| Faculty Office | 260K | 108 | 0 | 0 | 0 | -108 | 0 |
| Faculty Office | 260L | 96 | 0 | 0 | 0 | -96 | 0 |
| Faculty Office | 260M | 108 | 0 | 0 | 0 | -108 | 0 |
| Faculty Office | New | 0 | 12 | 120 | 1,440 | 1,440 | 2,526 |
| CE Reception Area | 260 | 203 | 1 | 203 | 203 | 0 | 356 |
| Conference Room | 260F | 183 | 1 | 183 | 183 | 0 | 321 |
| Mail Room | 260G | 36 | 1 | 36 | 36 | 0 | 63 |

| | | | | | | | |
|-----------------------------|-----|-----|----|-----|-------|-------|-------|
| Grad Students | 205 | 70 | 0 | 0 | 0 | -70 | 0 |
| Grad Students | 211 | 72 | 0 | 0 | 0 | -72 | 0 |
| Grad Students | 213 | 72 | 0 | 0 | 0 | -72 | 0 |
| Grad Students | 214 | 70 | 0 | 0 | 0 | -70 | 0 |
| Grad Students | 223 | 229 | 0 | 0 | 0 | -229 | 0 |
| Grad Students | 361 | 386 | 0 | 0 | 0 | -386 | 0 |
| Grad Students / PhD Offices | New | 0 | 16 | 80 | 1,280 | 1,280 | 2,246 |
| Other | | | | | | | |
| CE Commons / Student Groups | 216 | 505 | 1 | 505 | 505 | 0 | 886 |

TOTALS

14,373

22,540

8,167

39,544



CHEM E

The tables below show the net square footage, enrollment and full-time faculty numbers for both the current and future state associated within the Chemical Engineering department to achieve the programmatic changes identified on the right. The tables on the following pages provide a listing of current and future space allocation throughout the complex to serve the department.

CHEMICAL ENGINEERING DEPARTMENT SUMMARY

The Chemical Engineering Department is primarily housed in Harrington Hall and Upson II. The current enrollment in this program has a significant on-line student component and includes 235 undergraduate students (110 on-campus; 125 on-line), 15 master's students (one-half on-line) and 15 PhD candidates (one-half on-line) with 7 full-time faculty positions. The enrollment is projected to grow to 400 undergraduate students (one-half on-line), 24 master's students (one-half on-line) and up to 24 PhD candidates (one-half on-line). This enrollment growth will also lead to a full time faculty demand of 12 positions in an effort to improve the faculty to student ratio to a target value of 25:1.

The total net square footage within the existing engineering complex that is dedicated to Chemical Engineering is just over 15,000 nsf. The department has identified the need for additional wet chemistry research and teaching laboratory space as well as a consolidation and modernization of unit operations instruction laboratories. The existing unit operations labs are located in the aging 3 story expansion on the east side of Harrington Hall and the area is in need of replacement to function efficiently and safely.

| SPACE PROJECTIONS | CURRENT NSF | FUTURE NSF | PROGRAMMATIC CHANGES |
|---------------------------|-------------|------------|---|
| Net Square Feet (NSF) | | | |
| TEACHING LABORATORIES | 3,410 | 5,156 | 1. Expansion of Wet Chemistry Teaching Space |
| RESEARCH LABORATORIES | 4,953 | 5,692 | 2. Consolidation and expansion of Unit Operations Teaching Laboratories |
| LABORATORY SUPPORT | 2,426 | 3,188 | 3. Expansion of Wet Chemistry Research Laboratory Space |
| LECTURE AND CLASSROOM | - | - | 4. Faculty Office count grows from 9 to 12 |
| OFFICE AND ADMINISTRATION | 3,654 | 6,886 | 5. Grad Student / PhD Office space to accommodate 48 occupants (existing shown for approximately 7 occupants) |
| OTHER | 789 | 789 | |
| TOTAL | 15,232 | 21,711 | 42% Increase |

| PERSONNEL PROJECTIONS | CURRENT | FUTURE | NOTES |
|------------------------------|-----------|-----------|-------|
| C/O: On Campus/Online | | | |
| UNDERGRADUATE STUDENTS (c/o) | 110 / 125 | 200 / 200 | |
| MASTERS STUDENTS (c/o) | 8 / 7 | 12 / 12 | |
| PHD STUDENTS (c/o) | 8 / 7 | 12 / 12 | |
| FACULTY | 7 | 12 | |
| NSF PER STUDENT ON CAMPUS | 120 NSF | 91 NSF | |

SPACE SUMMARY



Teaching Laboratories

| | | | | | | | |
|-------------------------------------|-----|-------|---|-------|-------|--------|-------|
| Wet Chemistry Teaching Laboratory | 304 | 332 | 2 | 726 | 1,452 | 1,120 | 2,547 |
| Teaching Laboratory (Unit Ops 3) | 316 | 334 | 0 | 0 | 0 | -334 | 0 |
| Computational Laboratory | 320 | 800 | 1 | 800 | 800 | 0 | 1,404 |
| Teaching Laboratory (Unit Ops 1) | 321 | 794 | 1 | 1,089 | 1,089 | 295 | 1,911 |
| Teaching Laboratory (Unit Ops 2) | 360 | 1,150 | 0 | 0 | 0 | -1,150 | 0 |
| Unit Operations Teaching Laboratory | New | 0 | 1 | 1,815 | 1,815 | 1,815 | 3,184 |



Research Laboratories

| | | | | | | | |
|-------------------------------|------|-------|---|-------|-------|-----|-------|
| Pilot Scale Systems Research | 100B | 383 | 1 | 383 | 383 | 0 | 672 |
| Chem E Research | 160 | 2,244 | 1 | 2,178 | 2,178 | -66 | 3,821 |
| Wet Chemistry Research | 260 | 1,190 | 1 | 1,815 | 1,815 | 625 | 3,184 |
| Hoffman Energetics Laboratory | 322B | 107 | 1 | 107 | 107 | 0 | 188 |
| Research Laboratory | 360B | 243 | 1 | 363 | 363 | 120 | 637 |
| Research Laboratory | 360C | 238 | 1 | 363 | 363 | 125 | 637 |
| Research Laboratory | 360E | 428 | 1 | 363 | 363 | -65 | 637 |
| Electrolysis Laboratory | 362A | 120 | 1 | 120 | 120 | 0 | 211 |



Laboratory Support

| | | | | | | | |
|-----------------------------------|------|-----|---|-----|-----|-----|-----|
| Chem E Shop / Tool Storage | 160A | 403 | 1 | 484 | 484 | 81 | 849 |
| Fittings and Material Storage | 160B | 240 | 1 | 242 | 242 | 2 | 425 |
| Chem E Shop Storage | 160C | 83 | 1 | 121 | 121 | 38 | 212 |
| Chemistry Prep | 260B | 240 | 1 | 242 | 242 | 2 | 425 |
| Instrumentation Laboratory | 260C | 220 | 1 | 242 | 242 | 22 | 425 |
| Instrumentation Laboratory | 261 | 350 | 1 | 363 | 363 | 13 | 637 |
| Storage | 322A | 42 | 1 | 42 | 42 | 0 | 74 |
| Teaching Lab Prep | 360A | 164 | 1 | 242 | 242 | 78 | 425 |
| Glassware Prep / Chemical Storage | 360D | 160 | 1 | 363 | 363 | 203 | 637 |
| Flue Mezzanine | 360F | 140 | 1 | 242 | 242 | 102 | 425 |
| Chemical Storage | 360G | 283 | 1 | 363 | 363 | 80 | 637 |
| Chemical Storage | 360H | 101 | 1 | 242 | 242 | 141 | 425 |



Office & Administrative

| | | | | | | | |
|-------------------------|------|-----|----|-----|-------|-------|-------|
| Department Chair Chem E | 365B | 120 | 1 | 170 | 170 | 50 | 298 |
| Faculty Office | 305 | 156 | 0 | 0 | 0 | -156 | 0 |
| Faculty Office | 307 | 161 | 0 | 0 | 0 | -161 | 0 |
| Faculty Office | 313 | 168 | 0 | 0 | 0 | -168 | 0 |
| Faculty Office | 314 | 159 | 0 | 0 | 0 | -159 | 0 |
| Faculty Office | 315 | 151 | 0 | 0 | 0 | -151 | 0 |
| Faculty Office | 365C | 126 | 0 | 0 | 0 | -126 | 0 |
| Faculty Office | 365D | 126 | 0 | 0 | 0 | -126 | 0 |
| Faculty Office | 365E | 126 | 0 | 0 | 0 | -126 | 0 |
| Faculty Office | New | 0 | 11 | 120 | 1,320 | 1,320 | 2,316 |
| Lab Manager's Office | 260A | 164 | 1 | 120 | 120 | -44 | 211 |

| | | | | | | | |
|-----------------------------|------|-----|----|-----|-------|-------|-------|
| Department Office | 365 | 499 | 1 | 499 | 499 | 0 | 875 |
| Conference Room | 325 | 144 | 1 | 144 | 144 | 0 | 253 |
| Mail Room | 365A | 101 | 1 | 101 | 101 | 0 | 177 |
| Grad Students | 223 | 229 | 0 | 0 | 0 | -229 | 0 |
| Faculty Office | 308 | 156 | 0 | 0 | 0 | -156 | 0 |
| Grad Students | 312 | 159 | 0 | 0 | 0 | -159 | 0 |
| Grad Students | 322C | 118 | 0 | 0 | 0 | -118 | 0 |
| Grad Students | 322D | 99 | 0 | 0 | 0 | -99 | 0 |
| Grad Students / PhD Offices | New | 0 | 48 | 80 | 3,840 | 3,840 | 6,737 |
| Break Room | 306 | 161 | 1 | 161 | 161 | 0 | 282 |
| Student Lounge | 318 | 531 | 1 | 531 | 531 | 0 | 932 |
| Other | | | | | | | |
| Storage | 1 | 236 | 1 | 236 | 236 | 0 | 414 |
| Storage | 3 | 238 | 1 | 238 | 238 | 0 | 418 |
| Unused | 323 | 140 | 1 | 140 | 140 | 0 | 246 |
| Unused | 323A | 175 | 1 | 175 | 175 | 0 | 307 |



| | | | | | | |
|--------|--------|--|--|--------|-------|--------|
| TOTALS | 15,232 | | | 21,711 | 6,479 | 38,089 |
|--------|--------|--|--|--------|-------|--------|



EE&CS

The tables below show the net square footage, enrollment and full-time faculty numbers for both the current and future state associated within the Electrical Engineering and Computer Science department to achieve the programmatic changes identified on the right. The tables on the following pages provide a listing of current and future space allocation throughout the complex to serve the department.

ELECTRICAL ENGINEERING + COMPUTER SCIENCE DEPARTMENT SUMMARY

The Electrical Engineering and Computer Science Department is primarily housed in Harrington Hall and Upson II, but also includes two computational labs in Leonard Hall on the opposite side of the complex. The department supports undergraduate and graduate/PhD majors in several areas including electrical engineering, computer science, data science and cyber security. At present, it also includes bio-medical engineering, but the current plan is for that program to become a stand-alone department (see section on Bio-medical Engineering later in this document). Current enrollment within the department includes 520 undergraduate students and approximately 130 students in various graduate/PhD programs and a current full-time faculty count of 18. The enrollment in EE/CS is projected to grow by approximately 50% in the next 10 years to numbers approaching 750 undergraduate students and 190 students in the graduate and PhD programs with a full-time faculty goal of 30.

The total net square footage within the existing engineering complex that is dedicated to Electrical Engineering and Computer Science is just under 14,000 nsf. The department has identified the need for expanded instructional laboratory space a new computational research facility as well as additional office space for graduate and PhD candidates.

| SPACE PROJECTIONS | CURRENT NSF | FUTURE NSF | PROGRAMMATIC CHANGES |
|---------------------------|-------------|------------|--|
| Net Square Feet (NSF) | | | |
| TEACHING LABORATORIES | 3,178 | 3,476 | 1. Consolidation and slight increase in Teaching Laboratory space |
| RESEARCH LABORATORIES | 6,646 | 7,733 | 2. New Computational Research Laboratory |
| LABORATORY SUPPORT | 209 | 209 | 3. Faculty Office count grows from 17 to 31 |
| LECTURE AND CLASSROOM | - | - | 4. Grad Student / PhD Office space to accommodate 40 occupants (existing shown for approximately 25 occupants) |
| OFFICE AND ADMINISTRATION | 3,779 | 8,035 | |
| OTHER | - | - | |
| TOTAL | 13,812 | 19,453 | 21% Increase |

| PERSONNEL PROJECTIONS | CURRENT | FUTURE | NOTES |
|------------------------------|---------|---------|-------|
| C/O: On Campus/Online | | | |
| UNDERGRADUATE STUDENTS (c/o) | 520 / - | 520 / - | |
| MASTERS STUDENTS (c/o) | 86 / - | 125 / - | |
| PHD STUDENTS (c/o) | 45 / - | 65 / - | |
| FACULTY | 18 | 30 | |
| NSF PER STUDENT ON CAMPUS | 24 NSF | 21 NSF | |

SPACE SUMMARY



Teaching Laboratories

| | # | EXT. NSF | QTY | NSF EA. | PROP. NSF | DIFF. | GSF |
|-------------------------------------|------|----------|-----|---------|-----------|-------|-------|
| EE&CS Teaching Laboratory | 110 | 842 | 0 | 0 | 0 | -842 | 0 |
| EE&CS Teaching Laboratory | 112 | 837 | 0 | 0 | 0 | -837 | 0 |
| EE&CS Teaching Laboratory | New | 0 | 1 | 1,815 | 1,815 | 1,815 | 3,184 |
| EE&CS Embedded Systems Teaching Lab | 120C | 572 | 1 | 572 | 572 | 0 | 1,004 |
| EE&CS Undergraduate Teaching Lab | 220 | 506 | 0 | 0 | 0 | -506 | 0 |
| EE&CS Circuits & Power Teaching Lab | 222 | 421 | 0 | 0 | 0 | -421 | 0 |
| EE&CS Circuits & Power Teaching Lab | New | 0 | 1 | 1,089 | 1,089 | 1,089 | 1,911 |



Research Laboratories

| | | | | | | | |
|--------------------------------------|------|-------|---|-------|-------|-------|-------|
| EE&CS Research Laboratory | 100H | 461 | 1 | 461 | 461 | 0 | 809 |
| Power and Energy Research Laboratory | 109 | 734 | 1 | 734 | 734 | 0 | 1,288 |
| EE&CS Research Laboratory | 112 | 333 | 1 | 333 | 333 | 0 | 584 |
| EE&CS Research Laboratory | 113 | 391 | 1 | 391 | 391 | 0 | 686 |
| EE&CS Maker Space | 120 | 2,219 | 1 | 2,178 | 2,178 | -41 | 3,821 |
| EE&CS Research Laboratory | 120A | 406 | 1 | 363 | 363 | -43 | 637 |
| EE&CS Research Laboratory | 120F | 434 | 1 | 363 | 363 | -71 | 637 |
| EE&CS Research Laboratory | 126 | 573 | 1 | 726 | 726 | 153 | 1,274 |
| EE&CS Research Laboratory | 211 | 153 | 1 | 153 | 153 | 0 | 268 |
| EE&CS Research Laboratory | 212 | 177 | 1 | 177 | 177 | 0 | 311 |
| EE & CS Computer Laboratory | 123 | 442 | 1 | 442 | 442 | 0 | 775 |
| Senior Design Lab | 213 | 323 | 1 | 323 | 323 | 0 | 567 |
| Computational Research Laboratory | New | 0 | 1 | 1,089 | 1,089 | 1,089 | 1,911 |



Laboratory Support

| | | | | | | | |
|-----------------------------|------|-----|---|-----|-----|---|-----|
| EE & CS Maker Space Support | 120B | 209 | 1 | 209 | 209 | 0 | 367 |
|-----------------------------|------|-----|---|-----|-----|---|-----|



Office & Administrative

| | | | | | | | |
|-------------------------|------|-----|---|-----|-----|------|-----|
| Department Chair Office | 366B | 269 | 1 | 170 | 170 | -99 | 298 |
| Faculty Office | 160I | 96 | 0 | 0 | 0 | -96 | 0 |
| Faculty Office | 160L | 107 | 0 | 0 | 0 | -107 | 0 |
| Faculty Office | 366A | 125 | 0 | 0 | 0 | -125 | 0 |
| Faculty Office | 366C | 107 | 0 | 0 | 0 | -107 | 0 |
| Faculty Office | 366D | 107 | 0 | 0 | 0 | -107 | 0 |
| Faculty Office | 366E | 117 | 0 | 0 | 0 | -117 | 0 |
| Faculty Office | 366G | 107 | 0 | 0 | 0 | -107 | 0 |
| Faculty Office | 366H | 110 | 0 | 0 | 0 | -110 | 0 |
| Faculty Office | 366J | 110 | 0 | 0 | 0 | -110 | 0 |
| Faculty Office | 366K | 110 | 0 | 0 | 0 | -110 | 0 |
| Faculty Office | 366L | 110 | 0 | 0 | 0 | -110 | 0 |
| Faculty Office | 366M | 110 | 0 | 0 | 0 | -110 | 0 |
| Faculty Office | 366N | 118 | 0 | 0 | 0 | -118 | 0 |
| Faculty Office | 366P | 106 | 0 | 0 | 0 | -106 | 0 |
| Faculty Office | 366Q | 110 | 0 | 0 | 0 | -110 | 0 |

| | # | EXT. NSF | QTY | NSF EA. | PROP. NSF | DIFF. | GSF |
|-----------------------------|------|----------|-----|---------|-----------|-------|-------|
| Faculty Office | 366R | 130 | 0 | 0 | 0 | -130 | 0 |
| Faculty Office | 369 | 107 | 0 | 0 | 0 | -107 | 0 |
| Faculty Office | New | 0 | 30 | 120 | 3,600 | 3,600 | 6,316 |
| EE&CS Reception Area | 366 | 270 | 1 | 270 | 270 | 0 | 474 |
| Conference Space | 160F | 183 | 1 | 183 | 183 | 0 | 321 |
| Copy Room | 366F | 120 | 1 | 120 | 120 | 0 | 211 |
| GTA Office | 120D | 319 | 1 | 319 | 319 | 0 | 560 |
| Grad Student Offices | 205 | 176 | 0 | 176 | 0 | -176 | 0 |
| Grad Student Offices | 206 | 153 | 0 | 153 | 0 | -153 | 0 |
| Grad Student Offices | 223 | 229 | 0 | 229 | 0 | -229 | 0 |
| Grad Students / PhD Offices | New | 0 | 40 | 80 | 3,200 | 3,200 | 5,614 |
| Storage | 366S | 173 | 1 | 173 | 173 | 0 | 304 |

| | | | | | | | |
|--------|--|--------|--|--|--------|-------|--------|
| TOTALS | | 13,812 | | | 19,453 | 5,641 | 34,128 |
|--------|--|--------|--|--|--------|-------|--------|



IES

The tables below show the net square footage, enrollment, faculty and research staff numbers for both the current and future state associated within the Institute for Energy Studies to achieve the programmatic changes identified on the right. The tables on the following pages provide a listing of current and future space allocation throughout the complex to serve the department.

INSTITUTE FOR ENERGY STUDIES
DEPARTMENT SUMMARY




The Institute for Energy Studies is housed entirely in the Collaborative Energy Center. It differs significantly from most other departments within the college. Founded in 2010, it is a department that focuses on grant funded research and hosts graduate level programs in energy engineering and environmental engineering. Current research focus areas are in carbon capture, rare earth metals mining and energy storage. The department employs a single full-time faculty member and a research and grant writing staff of 12. In addition, the institute regularly employs graduate and undergraduate students from other departments to assist with its research initiatives. The enrollment of students pursuing graduate degrees within the institute is expected to grow to as much as 50 in Master's and PhD programs. In addition, the institute expects to grow its resident research staff to 20 in the future.

The total net square footage currently assigned to the institute is just over 7,000 nsf and includes office space, flexible research laboratories and a research high bay space. Being located in the Collaborative Energy Center, all the space assigned to the institute is relatively new.

| SPACE PROJECTIONS <small>Net Square Feet (NSF)</small> | CURRENT NSF | FUTURE NSF | PROGRAMMATIC CHANGES |
|---|-------------|------------|--|
| TEACHING LABORATORIES | - | - | 1. Increase in Equipment Test High-Bay Research space |
| RESEARCH LABORATORIES | 2,355 | 2,918 | 2. Increase in Fabrication Bay space |
| LABORATORY SUPPORT | 2,013 | 2,367 | 3. Staff Office count grows from 7 to 20 (includes office space for new Instructor and Grant Writer positions) |
| LECTURE AND CLASSROOM | - | - | 4. Grad Student / PhD Office space to accommodate 26 occupants (existing shown for approximately 20 occupants) |
| OFFICE AND ADMINISTRATION | 2,748 | 4,650 | |
| OTHER | - | - | |
| TOTAL | 7,116 | 9,935 | 39% Increase |

| PERSONNEL PROJECTIONS <small>C/O: On Campus/Online</small> | CURRENT | FUTURE | NOTES |
|---|---------|---------|-------|
| UNDERGRADUATE STUDENTS (C/O) | - / - | - / - | |
| MASTERS STUDENTS (C/O) | 18 / 17 | 9 / 9 | |
| PHD STUDENTS (C/O) | - / - | 25 / 7 | |
| FACULTY | 1 / 12 | 1 / 20 | |
| NSF PER STUDENT ON CAMPUS | 395 NSF | 292 NSF | |

SPACE SUMMARY

| | | | | | | | | |
|---|--|------|-------|----|-------|-------|--------|--------|
|  | Research Laboratories | | | | | | | |
| | IES High Bay Equip. Test Laboratory | 134 | 982 | 1 | 982 | 982 | 0 | 1,723 |
| | IES High Bay Equip. Test Laboratory (Mezz) | 234 | 526 | 1 | 1,089 | 1,089 | 563 | 1,911 |
| | IES Wet Laboratory | 240 | 847 | 1 | 847 | 847 | 0 | 1,486 |
|  | Laboratory Support | | | | | | | |
| | IES Receiving and Loading | 130 | 542 | 1 | 542 | 542 | 0 | 951 |
| | Air Compressor | 130A | 52 | 1 | 52 | 52 | 0 | 91 |
| | Storage | 130B | 31 | 1 | 31 | 31 | 0 | 54 |
| | IES Fabrication Bay | 132 | 735 | 1 | 1,089 | 1,089 | 354 | 1,911 |
| | IES Sample Processing | 136 | 289 | 1 | 289 | 289 | 0 | 507 |
| | IES Research Control Room | 236 | 364 | 1 | 364 | 364 | 0 | 639 |
|  | Office & Administrative | | | | | | | |
| | IES Department Chair Office | 246A | 179 | 1 | 170 | 170 | -9 | 298 |
| | IES Instructor's Office | New | 0 | 1 | 120 | 120 | 120 | 211 |
| | IES Grant Writer's Office | New | 0 | 1 | 120 | 120 | 120 | 211 |
| | IES Staff Office | 246B | 120 | 0 | 0 | 0 | -120 | 0 |
| | IES Staff Office | 246C | 120 | 0 | 0 | 0 | -120 | 0 |
| | IES Staff Office | 246D | 196 | 0 | 0 | 0 | -196 | 0 |
| | IES Staff Office | 246E | 119 | 0 | 0 | 0 | -119 | 0 |
| | IES Staff Office | 246F | 119 | 0 | 0 | 0 | -119 | 0 |
| | IES Staff Office | 246G | 119 | 0 | 0 | 0 | -119 | 0 |
| | IES Staff Office | 246H | 119 | 0 | 0 | 0 | -119 | 0 |
| | IES Staff Office | New | 0 | 18 | 120 | 2,160 | 2,160 | 3,789 |
| | Grad Student Cubicles | 246 | 1,657 | 0 | 0 | 0 | -1,657 | 0 |
| | Grad Students / PhD Offices | New | 0 | 26 | 80 | 2,080 | 2,080 | 3,649 |
| TOTALS | | | 7,116 | | | 9,935 | 2,819 | 17,430 |



MECH E

MECHANICAL ENGINEERING

DEPARTMENT SUMMARY

The Mechanical Engineering Department is primarily housed in Upson I and Upson II Halls. The current enrollment in this program has a significant on-line student component and includes 620 undergraduate students (one-half on-line), 26 master's students (one-half on-line) and 11 PhD candidates with 14 full-time faculty positions. The enrollment is projected to grow to 800 undergraduate students (one-half on-line), 36 master's students and up to 16 PhD candidates. This enrollment growth will also lead to a full time faculty demand of 21 positions.

The total net square footage within the existing engineering complex that is dedicated to Mechanical Engineering is over 27,000 nsf. The department has identified the need for additional space to accommodate heavy equipment and machine space in support of its existing high bay labs and the addition of a dedicated freshman research projects laboratory.

The tables below show the net square footage, enrollment and full-time faculty numbers for both the current and future state associated within the Mechanical Engineering department to achieve the programmatic changes identified on the right. The tables on the following pages provide a listing of current and future space allocation throughout the complex to serve the department.

SPACE PROJECTIONS

Net Square Feet (NSF)

| |
|---------------------------|
| TEACHING LABORATORIES |
| RESEARCH LABORATORIES |
| LABORATORY SUPPORT |
| LECTURE AND CLASSROOM |
| OFFICE AND ADMINISTRATION |
| OTHER |
| TOTAL |

CURRENT NSF

| |
|---------------|
| 3,111 |
| 12,390 |
| 7,542 |
| - |
| 4,574 |
| - |
| 27,617 |

FUTURE NSF

| |
|---------------|
| 4,968 |
| 16,414 |
| 8,290 |
| - |
| 5,764 |
| - |
| 35,436 |

PROGRAMMATIC CHANGES

1. Expansion of High-Bay Instructional Machine Shop space
 2. Increase in Freshman Projects Research Laboratory space
 3. Increase in High-Bay Machine Shop space
 4. Increase in Welding Shop space
 5. Faculty office count grows from 16 to 20
 6. Grad Student / PhD Office space to accommodate 32 occupants (existing shown for approximately 22 occupants)
- 28% Increase**

PERSONNEL PROJECTIONS

C/O: On Campus/Online

| |
|------------------------------|
| UNDERGRADUATE STUDENTS (C/O) |
| MASTERS STUDENTS (C/O) |
| PHD STUDENTS (C/O) |
| FACULTY |
| NSF PER STUDENT ON CAMPUS |

CURRENT

| |
|-----------|
| 310 / 310 |
| 13 / 13 |
| 10 / 1 |
| 14 |
| 82 NSF |

FUTURE

| |
|-----------|
| 400 / 400 |
| 18 / 18 |
| 14 / 2 |
| 21 |
| 83 NSF |

NOTES

SPACE SUMMARY



Teaching Laboratories

| | | | | | | | |
|-----------------------------------|-----|-------|---|-------|-------|-------|-------|
| ME Instructional Measurement Lab | 221 | 931 | 1 | 1,089 | 1,089 | 158 | 1,911 |
| ME Computational Laboratory | 264 | 510 | 1 | 510 | 510 | 0 | 895 |
| ME Instructional Machine Shop new | New | 0 | 1 | 1,699 | 1,699 | 1,699 | 2,981 |
| ME Instructional Machine Shop exg | 102 | 1,568 | 1 | 1,568 | 1,568 | 0 | 2,751 |
| ME Recording Room | 280 | 102 | 1 | 102 | 102 | 0 | 179 |



Research Laboratories

| | | | | | | | |
|---|------|-------|---|-------|-------|-------|-------|
| ME Research Laboratory (hi-temp/manuf) | 12D | 1,310 | 1 | 1,310 | 1,310 | 0 | 2,298 |
| ME Faculty Research Laboratory | 100 | 2,015 | 1 | 2,015 | 2,015 | 0 | 3,535 |
| ME Freshman Projects | 101 | 470 | 1 | 726 | 726 | 256 | 1,274 |
| ME Student Projects Laboratory | New | 0 | 1 | 1,815 | 1,815 | 1,815 | 3,184 |
| Laser Laboratory | 105B | 426 | 1 | 660 | 660 | 234 | 1,158 |
| ME Undergraduate Robotics Lab | 106A | 366 | 1 | 366 | 366 | 0 | 642 |
| ME Faculty Research Laboratory | 106C | 260 | 1 | 260 | 260 | 0 | 456 |
| ME Formula Car Cage | 114A | 1,110 | 1 | 1,110 | 1,110 | 0 | 1,947 |
| ME Student Projects Research Laboratory | 114 | 1,741 | 1 | 1,741 | 1,741 | 0 | 3,054 |
| ME Faculty Research Laboratory | 115 | 360 | 1 | 360 | 360 | 0 | 632 |
| ME Machine Shop new | New | 0 | 1 | 1,719 | 1,719 | 1,719 | 3,016 |
| ME Machine Shop exg | 104 | 1,911 | 1 | 1,911 | 1,911 | 0 | 3,353 |
| Machine Vision Laboratory | 200 | 357 | 1 | 357 | 357 | 0 | 626 |
| Machine Vision Laboratory | 200A | 105 | 1 | 105 | 105 | 0 | 184 |
| Mechanical Testing Laboratory | 201A | 667 | 1 | 667 | 667 | 0 | 1,170 |
| ME Faculty Research Laboratory | 201C | 368 | 1 | 368 | 368 | 0 | 646 |
| Senior Design Lab | 213 | 323 | 1 | 323 | 323 | 0 | 567 |
| ME Faculty Research Laboratory | 217 | 220 | 1 | 220 | 220 | 0 | 386 |
| ME Faculty Research Laboratory | 219 | 381 | 1 | 381 | 381 | 0 | 668 |



Laboratory Support

| | | | | | | | |
|------------------------|------|-------|---|-------|-------|-----|-------|
| Chemical Storage | 12E | 108 | 1 | 108 | 108 | 0 | 189 |
| Electrical Equipment | 12A | 135 | 1 | 135 | 135 | 0 | 237 |
| Machining Shop | 12B | 135 | 1 | 135 | 135 | 0 | 237 |
| Storage | 2 | 370 | 1 | 370 | 370 | 0 | 649 |
| Storage | 3 | 370 | 1 | 370 | 370 | 0 | 649 |
| ME 3D Printing | 100C | 207 | 1 | 207 | 207 | 0 | 363 |
| ME High Bay Support | 102A | 246 | 1 | 246 | 246 | 0 | 432 |
| Welding Shop | 105 | 1,232 | 1 | 1,980 | 1,980 | 748 | 3,474 |
| Welding Supply | 105A | 126 | 1 | 126 | 126 | 0 | 221 |
| ME Storage / Dock Area | 106 | 2,285 | 1 | 2,285 | 2,285 | 0 | 4,009 |
| ME Foundry | 106D | 332 | 1 | 332 | 332 | 0 | 582 |
| Storage | 106E | 139 | 1 | 139 | 139 | 0 | 244 |
| Storage | 106G | 181 | 1 | 181 | 181 | 0 | 318 |
| ME Foundry Support | 106K | 71 | 1 | 71 | 71 | 0 | 125 |



Office & Administrative

| | | | | | | | |
|-----------------------------|------|-----|----|-----|-------|-------|-------|
| Storage | 106M | 187 | 1 | 187 | 187 | 0 | 328 |
| Secure Storage | 106B | 150 | 1 | 150 | 150 | 0 | 263 |
| ME Wood Shop | 111 | 479 | 1 | 479 | 479 | 0 | 840 |
| ME Vibration Equipment Cage | 114B | 395 | 1 | 395 | 395 | 0 | 693 |
| ME 3D Printing | 201 | 394 | 1 | 394 | 394 | 0 | 691 |
| ME Department Chair | 270 | 108 | 1 | 170 | 170 | 62 | 298 |
| Faculty Offices | 160A | 157 | 0 | 0 | 0 | -157 | 0 |
| Faculty Offices | 160B | 108 | 0 | 0 | 0 | -108 | 0 |
| Faculty Offices | 160C | 108 | 0 | 0 | 0 | -108 | 0 |
| Faculty Offices | 160D | 120 | 0 | 0 | 0 | -120 | 0 |
| Faculty Offices | 160E | 105 | 0 | 0 | 0 | -105 | 0 |
| Faculty Offices | 220 | 260 | 0 | 0 | 0 | -260 | 0 |
| Faculty Offices | 266A | 126 | 0 | 0 | 0 | -126 | 0 |
| Faculty Offices | 266B | 100 | 0 | 0 | 0 | -100 | 0 |
| Faculty Offices | 267 | 208 | 0 | 0 | 0 | -208 | 0 |
| Faculty Offices | 268 | 127 | 0 | 0 | 0 | -127 | 0 |
| Faculty Offices | 269 | 129 | 0 | 0 | 0 | -129 | 0 |
| Faculty Offices | 271 | 110 | 0 | 0 | 0 | -110 | 0 |
| Faculty Offices | 272 | 88 | 0 | 0 | 0 | -88 | 0 |
| Faculty Offices | 273 | 108 | 0 | 0 | 0 | -108 | 0 |
| Faculty Offices | 274 | 109 | 0 | 0 | 0 | -109 | 0 |
| Faculty Offices | 275 | 129 | 0 | 0 | 0 | -129 | 0 |
| Faculty Offices | New | 0 | 20 | 120 | 2,400 | 2,400 | 4,211 |
| Lab Manager's Office | 106L | 110 | 1 | 120 | 120 | 10 | 211 |
| ME Department Office | 266 | 258 | 1 | 258 | 258 | 0 | 453 |
| ME Conference Room | 278 | 256 | 1 | 256 | 256 | 0 | 449 |
| Grad Student Offices | 200B | 405 | 0 | 0 | 0 | -405 | 0 |
| Grad Student Offices | 200C | 111 | 0 | 0 | 0 | -111 | 0 |
| Grad Student Offices | 200D | 108 | 0 | 0 | 0 | -108 | 0 |
| Grad Student Offices | 202 | 68 | 0 | 0 | 0 | -68 | 0 |
| Grad Student Offices | 206 | 72 | 0 | 0 | 0 | -72 | 0 |
| Grad Student Offices | 207 | 70 | 0 | 0 | 0 | -70 | 0 |
| Grad Student Offices | 208 | 72 | 0 | 0 | 0 | -72 | 0 |
| Grad Student Offices | 209 | 70 | 0 | 0 | 0 | -70 | 0 |
| Grad Student Offices | 210 | 72 | 0 | 0 | 0 | -72 | 0 |
| Grad Student Offices | 212 | 70 | 0 | 0 | 0 | -70 | 0 |
| Graduate Student Cubicles | 12 | 632 | 0 | 0 | 0 | -632 | 0 |
| Grad Students / PhD Offices | New | 0 | 32 | 80 | 2,560 | 2,560 | 4,491 |

| | | | | | | | |
|--------|--|--------|--|--|--------|-------|--------|
| TOTALS | | 27,617 | | | 35,436 | 7,819 | 62,168 |
|--------|--|--------|--|--|--------|-------|--------|



BIO E

BIOMEDICAL ENGINEERING

DEPARTMENT SUMMARY





The Biomedical Engineering Department is entirely housed in the basement of Upson II. This program has only recently been established as a stand-alone program and at this time only offers graduate degrees. The current enrollment in this program includes 35 graduate students (17 on-line) and a full-time faculty count of 1.75 through joint appointments. In the near future, the department plans to create an undergraduate program accommodating 100 students and to grow its graduate program to 60 student (projecting on-half of those to be on-line). The department expects the faculty count under this enrollment to reach 7 full-time positions.

The total net square footage within the existing engineering complex that is dedicated to Biomedical Engineering is approximately 2,600 nsf. The future needs of the department include expansion of teaching laboratory space as well as significant growth in research space for wet lab, optics and exercise research.

| SPACE PROJECTIONS | CURRENT NSF | FUTURE NSF | PROGRAMMATIC CHANGES |
|---------------------------|-------------|------------|--|
| Net Square Feet (NSF) | | | |
| TEACHING LABORATORIES | 206 | 1,452 | 1. Expansion of Teaching Laboratory |
| RESEARCH LABORATORIES | 924 | 4,356 | 2. Expansion of Research Laboratory Space |
| LABORATORY SUPPORT | 152 | 484 | 3. Creation of Laboratory Space for: |
| LECTURE AND CLASSROOM | - | - | • Wet Chemistry |
| OFFICE AND ADMINISTRATION | 1,388 | 3,410 | • Optics |
| OTHER | - | - | • Exercise |
| TOTAL | 2,670 | 9,702 | • Faculty office count grows from 1 to 7 |
| | | | 4. Grad Student / PhD Office space to accommodate 30 |
| | | | 360% Increase |

| PERSONNEL PROJECTIONS | CURRENT | FUTURE | NOTES |
|------------------------------|---------|---------|-------|
| C/O: On Campus/Online | | | |
| UNDERGRADUATE STUDENTS (C/O) | - / - | 100 / - | |
| MASTERS STUDENTS (C/O) | 13 / 17 | 60 / 30 | |
| PHD STUDENTS (C/O) | - / - | - / - | |
| FACULTY | 1.75 | 7 | |
| NSF PER STUDENT ON CAMPUS | 76 NSF | 74 NSF | |

SPACE SUMMARY

| | # | EXT. NSF | QTY | NSF EA. | PROP. NSF | DIFF. | GSF |
|---|-----|----------|-----|---------|-----------|--------|--------|
|  Teaching Laboratories | | | | | | | |
| Biomed Eng Teaching Laboratory | 10 | 206 | 1 | 1,452 | 1,452 | 1,246 | 2,547 |
|  Research Laboratories | | | | | | | |
| Biomedical Engineering Laboratory | 10A | 924 | 1 | 1,815 | 1,815 | 891 | 3,184 |
| Biomedical Research Wet Laboratory | New | 0 | 1 | 1,089 | 1,089 | 1,089 | 1,911 |
| Biomedical Optics Laboratory | New | 0 | 1 | 726 | 726 | 726 | 1,274 |
| Biomedical Exercise Laboratory | New | 0 | 1 | 726 | 726 | 726 | 1,274 |
|  Laboratory Support | | | | | | | |
| Biomed Lab Storage | 10C | 152 | 1 | 363 | 363 | 211 | 637 |
| Biomedical Secure Records Storage | New | 0 | 1 | 121 | 121 | 121 | 212 |
|  Office & Administrative | | | | | | | |
| Department Chair Office | New | 0 | 1 | 170 | 170 | 170 | 298 |
| Faculty Office | New | 0 | 7 | 120 | 840 | 840 | 1,474 |
| Biomed E Office | 11A | 149 | 0 | 149 | 0 | -149 | 0 |
| Biomed Eng Grad Office / Conference | 11 | 1,111 | 0 | 1,111 | 0 | -1,111 | 0 |
| Biomed PhD Office | 10B | 128 | 0 | 128 | 0 | -128 | 0 |
| Grad Students / PhD Offices | New | 0 | 30 | 80 | 2,400 | 2,400 | 4,211 |
| TOTALS | | 2,670 | | | 9,702 | 7,032 | 17,021 |



COE

COLLEGE OF ENGINEERING
DEPARTMENT SUMMARY

In addition to the departmental space tabulations identified earlier, the college also possesses a significant amount of shared program space that includes the Dean's office and administration, core research labs, classrooms, student amenities, storage and the JODASS program. A moderate amount of growth associated with shared core space is anticipated. One of the primary shared research areas requested includes space to accommodate research by several departments involving the use of drones which is shown in the projected table.

The tables below show the net square footage numbers for both the current and future state associated within the core facilities of the College of Engineering and Mines to achieve the programmatic changes identified on the right. The tables on the following pages provide a listing of current and future space allocation throughout the complex to serve these needs.

| SPACE PROJECTIONS <small>Net Square Feet (NSF)</small> | CURRENT NSF | FUTURE NSF | PROGRAMMATIC CHANGES |
|---|-------------|------------|---|
| TEACHING LABORATORIES | 1,153 | 1,153 | 1. New High-Bay Drone Laboratory (shared space requested by both Civil and EE/CS) |
| RESEARCH LABORATORIES | 3,354 | 4,806 | |
| LABORATORY SUPPORT | 301 | 301 | |
| LECTURE AND CLASSROOM | 2,389 | 2,389 | |
| OFFICE AND ADMINISTRATION | 9,707 | 9,707 | |
| OTHER | 6,048 | 6,048 | |
| TOTAL | 22,952 | 24,404 | 6% Increase |

| PERSONNEL PROJECTIONS <small>C/O: On Campus/Online</small> | CURRENT | FUTURE | NOTES |
|---|---------|--------|--|
| UNDERGRADUATE STUDENTS (C/O) | - / - | - / - | 1. Space utilized by all departments inside the College of Engineering |
| MASTERS STUDENTS (C/O) | - / - | - / - | |
| PHD STUDENTS (C/O) | - / - | - / - | |
| FACULTY | - / - | - / - | |
| NSF PER STUDENT ON CAMPUS | - / - | - / - | |

SPACE SUMMARY



Teaching Laboratories

Mezzanine Teaching Laboratory? 222 1,153 1 1,153 1,153 0 2,023

Research Laboratories

Core Imaging Laboratory 16 1,029 1 1,029 1,029 0 1,805

Undergraduate Computer Laboratory 145 760 1 760 760 0 1,333

Mezzanine Research Laboratory 218 726 1 726 726 0 1,274

CEM Computer Laboratory 225 839 1 839 839 0 1,472

Drone Laboratory New 0 1 1,452 1,452 1,452 2,547



Laboratory Support

CEM Computer Lab Support 225A 104 1 104 104 0 182

Imaging Prep Laboratory 17 197 1 197 197 0 346



Lecture and Classroom

Executive Training Room 202 617 1 617 617 0 1,082

Multi-Purpose Classroom 205 732 1 732 732 0 1,284

Multi-Purpose Classroom 209 737 1 737 737 0 1,293

General Classroom (COE) 307 303 1 303 303 0 532



Office & Administrative

COE Admin. - Reception 165 722 1 722 722 0 1,267

COE Admin. - Deans Office 165A 401 1 401 401 0 704

COE Admin. - Assistants Office 165C 110 1 110 110 0 193

COE Admin - Business Officer Office 165D 143 1 143 143 0 251

COE- Admin Office 165E 177 1 177 177 0 311

COE Dean's Conference Room 166 358 1 358 358 0 628

COE Admin - Support Specialist Office 103 558 1 558 558 0 979

COE Admin Office 103A 102 1 102 102 0 179

COE Admin Office 103C 102 1 102 102 0 179

COE Admin - Online Program Coord. Office 103D 111 1 111 111 0 195

COE Admin - Online Program Support Office 103E 103 1 103 103 0 181

COE Admin Office 103F 103 1 103 103 0 181

COE Admin - Copy Room 103G 251 1 251 251 0 440

COE Admin Office 103H 113 1 113 113 0 198

COE Admin Office 103J 114 1 114 114 0 200

COE Admin Grant Manager's Office 160J 164 1 164 164 0 288

COE Admin. Grant Manager's Office 160K 107 1 107 107 0 188

COE Admin. - Undergrad Program Coord. Office 160M 119 1 119 119 0 209

COE Admin. - Grad Program Coord. Office 160N 109 1 109 109 0 191

COE Admin. - Linux Administrators Office 162 152 1 152 152 0 267

COE Admin. -IT Coord. Office 162C 98 1 98 98 0 172

Office - IT? 162A 107 1 107 107 0 188

Office - IT? 162B 109 1 109 109 0 191

COE Storage 163 109 1 109 109 0 191

| | # | EXT. NSF | QTY | NSF EA. | PROP. NSF | DIFF. | GSF |
|---|------|----------|-----|---------|-----------|-------|--------|
| COE Copy Room | 167 | 143 | 1 | 143 | 143 | 0 | 251 |
| Conference Room | 371 | 405 | 1 | 405 | 405 | 0 | 711 |
| AE2S Board Room | 106 | 810 | 1 | 810 | 810 | 0 | 1,421 |
| AE2S BR Storage | 106A | 54 | 1 | 54 | 54 | 0 | 95 |
| AE2S BR Coats | 106B | 51 | 1 | 51 | 51 | 0 | 89 |
| Reception Area (ME; EE&CS) | 160 | 203 | 1 | 203 | 203 | 0 | 356 |
| Jodsaas Center Lobby | 100 | 878 | 1 | 878 | 878 | 0 | 1,540 |
| Jodsaas Center Admin Office | 100A | 136 | 1 | 136 | 136 | 0 | 239 |
| Jodsaas Center Admin Office | 100B | 167 | 1 | 167 | 167 | 0 | 293 |
| Jodsaas Center Admin Office | 100D | 181 | 1 | 181 | 181 | 0 | 318 |
| Jodsaas Center Admin Office | 100E | 250 | 1 | 250 | 250 | 0 | 439 |
| Jodsaas Center Conference Room | 100G | 754 | 1 | 754 | 754 | 0 | 1,323 |
| Student Organization Office / Storage | 221 | 242 | 1 | 242 | 242 | 0 | 425 |
| Solberg Student Success Center | 103B | 209 | 1 | 209 | 209 | 0 | 367 |
| Kitchenette | 20 | 62 | 1 | 62 | 62 | 0 | 109 |
| Lounge - Kitchenette | 120 | 230 | 1 | 230 | 230 | 0 | 404 |
| Faculty Lounge | 258 | 390 | 1 | 390 | 390 | 0 | 684 |
| Other | | | | | | | |
| Student Lounge | 46 | 264 | 1 | 264 | 264 | 0 | 463 |
| 1st Floor Lobby / Museum (Leonard Hall) | 150A | 2,577 | 1 | 2,577 | 2,577 | 0 | 4,521 |
| Big Ideas Gym | 141 | 958 | 1 | 958 | 958 | 0 | 1,681 |
| Storage | 103K | 42 | 1 | 42 | 42 | 0 | 74 |
| Vending | 102 | 134 | 1 | 134 | 134 | 0 | 235 |
| Storage | 1 | 236 | 1 | 236 | 236 | 0 | 414 |
| Closet | 160G | 35 | 1 | 35 | 35 | 0 | 61 |
| Instructional Services Office? | 226 | 191 | 1 | 191 | 191 | 0 | 335 |
| COE Hall of Fame | 175 | 393 | 1 | 393 | 393 | 0 | 689 |
| Open Lounge | 170 | 350 | 1 | 350 | 350 | 0 | 614 |
| Student Study Space | 180 | 695 | 1 | 695 | 695 | 0 | 1,219 |
| Unknown | 203 | 173 | 1 | 173 | 173 | 0 | 304 |
| TOTALS | | 22,952 | | | 24,404 | 1,452 | 42,814 |



REG

REGISTRAR DEPARTMENT SUMMARY




The current engineering complex includes several teaching spaces that are centrally scheduled by the registrar and are regularly used by the various colleges within the university. These spaces include several medium and small classrooms as well as the main lecture hall at the northwest corner of Leonard Hall. Two of these existing classrooms located in Upson II are underutilized and are shown to be removed from the program.

The tables below show the net square footage numbers for both the current and future state associated within the instructional spaces that are centrally scheduled by the Registrar.

| SPACE PROJECTIONS <small>Net Square Feet (NSF)</small> | CURRENT NSF | FUTURE NSF | PROGRAMMATIC CHANGES |
|---|-------------|------------|---|
| TEACHING LABORATORIES | 2,477 | 2,477 | 1. Eliminate two small classrooms that are underutilized (161 & 164 Upson II) |
| RESEARCH LABORATORIES | - | - | |
| LABORATORY SUPPORT | - | - | |
| LECTURE AND CLASSROOM | 11,756 | 10,860 | |
| OFFICE AND ADMINISTRATION | - | - | |
| OTHER | 129 | 50 | 6% Decrease |
| TOTAL | 14,362 | 13,387 | |

| PERSONNEL PROJECTIONS <small>C/O: On Campus/Online</small> | CURRENT | FUTURE | NOTES |
|---|---------|--------|--|
| UNDERGRADUATE STUDENTS (C/O) | - / - | - / - | 1. Space utilized by all departments inside the College of Engineering |
| MASTERS STUDENTS (C/O) | - / - | - / - | |
| PHD STUDENTS (C/O) | - / - | - / - | |
| FACULTY | - / - | - / - | |
| NSF PER STUDENT ON CAMPUS | - / - | - / - | |

SPACE SUMMARY

| | | | | | | | | |
|---|--|--------|-------|--------|-------|-------|------|--------|
|  | Teaching Laboratories | | | | | | | |
| | Shared Teaching Laboratory / Classroom | 107 | 847 | 1 | 847 | 847 | 0 | 1,486 |
| | Shared Teaching Laboratory / Classroom | 211 | 561 | 1 | 561 | 561 | 0 | 984 |
| | Shared Teaching Laboratory / Classroom | 215 | 1,069 | 1 | 1,069 | 1,069 | 0 | 1,875 |
|  | Lecture and Classroom | | | | | | | |
| | Lecture Hall | 100 | 2,500 | 1 | 2,500 | 2,500 | 0 | 4,386 |
| | Classroom | 108 | 608 | 1 | 608 | 608 | 0 | 1,067 |
| | Classroom | 109 | 1,681 | 1 | 1,681 | 1,681 | 0 | 2,949 |
| | Classroom | 161 | 447 | 0 | 0 | 0 | -447 | 0 |
| | Classroom | 164 | 449 | 0 | 0 | 0 | -449 | 0 |
| | Classroom | 204 | 646 | 1 | 646 | 646 | 0 | 1,133 |
| | Classroom | 214 | 918 | 1 | 918 | 918 | 0 | 1,611 |
| | Classroom (Interactive) | 217 | 925 | 1 | 925 | 925 | 0 | 1,623 |
| | Classroom | 218 | 949 | 1 | 949 | 949 | 0 | 1,665 |
| | Classroom (Interactive) | 261 | 1,026 | 1 | 1,026 | 1,026 | 0 | 1,800 |
| | Classroom | 263 | 462 | 1 | 462 | 462 | 0 | 811 |
| | Classroom | 324 | 1,145 | 1 | 1,145 | 1,145 | 0 | 2,009 |
|  | Other | | | | | | | |
| | Projection Booth | 100A | 50 | 1 | 50 | 50 | 0 | 88 |
| | Projection Booth | 161A | 43 | 0 | 0 | 0 | -43 | 0 |
| | Projection Booth | 164A | 36 | 0 | 0 | 0 | -36 | 0 |
| TOTALS | | 14,362 | | 13,387 | | -975 | | 23,486 |



CONCEPTUAL PLANNING

INTRODUCTION

The following pages illustrate the iterative conceptual design process that was engaged as the design team and building committee investigated various ways to make achieve the future facility scope.

CONCEPTUAL DESIGN

INTRODUCTION

Upon completion of the departmental interviews, an initial programmatic scope was established. The initial findings indicated an approximate need of 205,000 in overall net square footage to achieve the enrollment and faculty growth while also providing some additional programmatic space for new initiatives within the college. The existing engineering complex comprises approximately 159,400 net square feet. At the time, this calculation included the scope associated with the remote drill lab. Through the review process with the committee, it was decided that the remote drill lab should remain at its current site as access for the large equipment used there would prove to be difficult and potentially hazardous to maneuver through campus. Later on in the process, it was also decided that new teaching, research and office space should be created to expand the Biomedical Engineering operations as that program is planned in the immediate future to become a stand-alone department. As the program is now envisioned, the complex will need to include 202,355 net square feet and will accommodate space for teaching and research, faculty and grad student office accommodations, student amenities, and the addition of some spaces to respond to emerging initiatives in the engineering curriculum. There were also some reductions reflected in the overall net square footage including reduction in the size of some spaces and the elimination of some underutilized spaces such as old classrooms. Assuming a net to gross conversion of 57%, it was determined that the overall gross square footage to meet the future goals of the combined college of engineering and mines would need to be approximately 355,000 gross square feet. The detailed take off of the existing plans indicated that the current complex is comprised of 259,400 gross square feet creating the need for an additional 95,600 gross square feet within the complex to be achieved through targeted additions and renovations over the next 10 to 15 years.

The following pages illustrate the iterative conceptual design process that was engaged as the design team and building committee investigated various ways to make achieve the future facility scope.

DESIGN CONSIDERATIONS

The aim of the design process centered around the goals and objectives established in the early kick-off meetings for the project. These concepts guided the design process once the program need was established and included the following major features.

ENROLLMENT: Expand enrollment with a focus on on-campus participation. The overall enrollment in the fall of 2020 was approximately 2,200 which included roughly 47% on-campus enrollment. The committee set the goal for on-campus enrollment at 1,500 to 2,000 over the next 10 to 15 years which would represent an approximate increase of between 45% and 93%. It is assumed that over the course of this time frame, on-line enrollment will continue to be in the 50% range of overall enrollment.

DEPARTMENTAL GROWTH: All departments expect steady growth well into the future which should be reflected in the goals of the facility maser plan. Mechanical Engineering is the largest program and that is expected to remain the case, but the fastest growing program is Electrical Engineering and Computer Science.

Demand for Petroleum Engineering has fallen off in recent years, but moderate growth should be accommodated as future booms in the energy industry are anticipated. Biomedical Engineering will become it's own department in near future and should be poised for significant expansion. Civil Engineering is an important discipline in North Dakota and the college has determined that it is not meeting local demand. Civil Engineering is currently 75% on-line and that department has set a goal for improving that ratio to accommodate more students on-campus.

FOSTERING COLLABORATION: A proper balance between collaboration and departmental identity should be identified and be readily apparent in the solution. Faculty within departments should be located near one another to foster intra-departmental collaboration. Over the years, some of this co-location has become decentralized, but it has improved in recent years after the construction of the Collaborative Energy Center.

CELEBRATE THE UNIQUENESS OF UND ENGINEERING AND MINES: The college is small enough that students get to know one another and the faculty leading to collaboration and cross pollination. The solution should continue to foster and preserve this family like atmosphere and promote a sense of community. It should also celebrate that portion of the student body that is non-traditional with many students that are older and engaged in re-training.

RESEARCH SPACE: The facility should create an environment where resources are shared among all disciplines and across faculty and students with the goal of increasing undergraduate involvement in research initiatives.

RECRUITMENT AND RETENTION: The facility should be designed with recruitment in mind. The various disciplines within the college should be put on display to help with retention which has always been difficult in engineering, broadly. The entry procession into the complex should celebrate engineering and the vast number of career choices available with an engineering degree should be displayed.

INTERACTION WITH OTHER COLLEGES: The College of Engineering and specific departments within it regularly collaborate with other programs across campus. These collaborations are mostly based in research and will include interface with Aerospace Engineering, the Medical School, the department of Chemistry and the college of Business. The spaces created through the course of masterplan implementation should be situated to take advantage of these arrangements and future detailed designs should seek input from other campus entities that could benefit.

FACULTY: Current faculty count is 65 with a total staff of approximately 100. The faulty counts are too low leading to a poor faculty to student ratio which is close to 1:50 in some departments. This number should be closer to 1:30. A facility master plan should look at ways the faculty/student ratio can be improved over time by providing adequate space not only for faculty offices, but for shared research space to improve opportunities for faculty recruitment.

CLASSROOM SPACE: The masterplan should provide adequate conventional classroom space, but it should be sized appropriately (several existing registrar scheduled classrooms are too small to be effectively utilized). It should also take into account available classroom space in adjacent buildings in this region of campus and may include enclosed links between Harrington Hall and the Education Building to the north. The large lecture hall in Leonard Hall is widely used and needs to be preserved. Computer classrooms should also be planned that can be used for both instruction and student projects.

HVAC AND ELECTRICAL SYSTEMS UPGRADES: The masterplan should provide for the replacement and upgrade of aging systems for HVAC and electrical systems as the targeted renovations are phased into the plan.

ACCESSIBILITY AND LIFE SAFETY: Accessible entrances, restrooms and class/lab furnishings should be planned throughout so that all accessibility issues are rectified through the course of the masterplan implementation. Any life safety issues and code deficiencies should also be addressed.


APPROACH

The conceptual design approach included a series of massing studies that were investigated to achieve the following aims:

- Provide the addition of net and gross square footage to achieve the growth identified in the planning phase
- Renovate targeted areas of the building that were most in need to modernization to meet current standards for laboratory safety and modular planning
- Provide swing space sufficient to implement a phased renovation of all areas of the complex in need of modernization and system replacement that would allow the college to operate continuously with no down time
- Create new dynamic space that would aid in recruitment and celebrate the engineering disciplines
- Create a circulation path through the complex that would improve way-finding and continuity
- Provide improved horizontal circulation the upper stories of the complex
- Eliminate programmatic elements that were underused or determined to be unneeded in the future
- Correct spaces that were oversized
- Correct life safety code issues
- Correct accessibility issues


EARLY OPTIONS

The massing iterations described below and illustrated on the following pages show the progression of massing options investigated to meet the project objectives.




CONCEPT DIAGRAM
Main goals to create unity among COE campus


MASSING SERIES 1: Massing Series 1 included the phase 1 construction of new 3 story addition that provided all of the new square footage included in the programming study. The addition was located partially in the existing quad north of the complex and would connect the north side of Harrington Hall and the north side Upson I at both the first and second floors. This option would leave the courtyard between Harrington and Upson I open to serve as a service yard and large scale entrance into the west high bay spaces in Upson I. Once this addition was completed, it would have provided adequate swing space to vacate and renovate the existing areas of the complex that required major renovation in 3 to 4 phases. The total gross square footage of the phase one addition was 82,500 GSF with a footprint of approximately 24,300 GSF and a 9,700 square foot mechanical penthouse.




MASSING SERIES 2: Massing Series 2 also included the phase 1 construction of new 2 story addition that provided 44,700 new gross square feet to be located in the area between Harrington and Upson I connecting both existing structures at the first and second floors. This series also included new high bay space in the new addition along the north side of Upson I and called for a new large scale equipment entrance to be located on the north side of the addition providing access to the high bay spaces in Upson I. The phase I addition would then serve as swing space for the demolition and full three story replacement of Harrington Hall in it's entirety with new construction totaling approximately 112,000 gross square feet. When coupled with the phase I addition, the phase II replacement of Harrington Hall would provide the required square footage to meet all scope



MASSING SERIES 3: Massing Series 3 called for a phase I addition between Harrington and Upson I followed by the demolition of the east side of Harrington Hall to include the single story industrial lab and three story chemical engineering addition. This demolished area of Harrington Hall would then be replaced by a new three story addition as part of phase 2 construction. The third phase of this version would then include either the demolition and replacement or significant renovation of Upson II in order to rebuild that portion of the complex to be of a more contextual façade.



MASSING SERIES 4: Massing Series 4 was the massing option that was reviewed and ultimately decided by the building committee to be developed further. It calls for the Phase 1, three story addition between Upson I and Harrington that also extends across a portion of the north face of Upson I. The completion of the first phase of construction provides the swing space to then demolish the east side of Harrington Hall and replace that with a three story addition and create a new entrance into a three story north/south atrium with research and teaching laboratories on both sides. This version also extends and east/west running connection to across the south façade of Upson I to create a more cohesive wayfinding path to better connect the entire complex. Subsequent phases will include the interior renovation of Upson II, light renovation and system replacement in Upson I and major reorganization in Leonard Hall.















PHASING AND COSTS

INTRODUCTION


The following pages illustrate the phased approach for the future facility and breaks down opinions of probable cost.




PHASE 1
Addition of 3 Stories of Lab Space and Main Street Link



PHASE 2 DEMO + INFILL
Demo Back Side of Harrington Hall and replace with 3 story laboratory spaces



PHASE 3
Renovate Upson II



PHASE 4
Renovate Remaining Spaces

MECHANICAL NARRATIVE - ALL PHASES

GENERAL

The design and installation of all mechanical systems will be in accordance with relevant portions of the following codes, standards, and publications:

- American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE) Handbooks and Standards
- American National Standards Institute (ANSI) Standards
- International Building Codes
- International Mechanical Code (IMC)
- International Plumbing Code (IPC)
- National Fire Protection Association (NFPA) Codes
- Americans with Disabilities Act Accessibility Guidelines (ADAAG)
- All codes and standards as established by the University of Nebraska Medical Center

TEMPERATURE AND HUMIDITY PARAMETERS

The following parameters will be used as the basis for the design of the building HVAC systems:

OUTDOOR DESIGN CONDITIONS:

| | |
|--|--------------|
| Winter Dry Bulb Temperature | -21.6 Deg. F |
| Summer Design Dry Bulb Temperature | 89.1 Deg. F |
| Summer Coincident Wet Bulb Temperature | 76.4 Deg. F |

INDOOR DESIGN CONDITIONS:

Summer / Winter Dry Bulb Temperature

| | |
|-----------------------------|----------------|
| Classrooms/Labs/Offices | 74 / 68 Deg. F |
| Mechanical/Electrical Rooms | 85 / 55 Deg. F |
| Telecomm Rooms | 74 / 70 Deg. F |
| Storage Rooms | 74 / 70 Deg. F |
| Stairs/Vestibules | NA / 65 Deg. F |
| All Other Areas | 74 / 70 Deg. F |
| Relative Humidity | |
| All Areas | 20-60% RH |

MINIMUM VENTILATION RATES:

| | |
|------------------------|---|
| Laboratory areas | Min. 6 ACH (air changes per hour) occupied Min. 4 ACH unoccupied |
| Chemical storage areas | Min. 15 ACH |
| All other areas | IMC/ASHRAE requirements |

FUME HOOD AIRFLOW RATES:

| | |
|---------------|--|
| Face Velocity | 60 feet per minute (FPM), tested in accordance with ASHRAE 110 to verify proper capture rates |
|---------------|--|

ELECTRICAL NARRATIVE - ALL PHASES

GENERAL

The design and installation of all electrical systems will be in accordance with relevant portions of the following codes, standards, and publications:

- ▷ National Electrical Code; NFPA #70
- ▷ National Fire Protection Association (NFPA) Standards
- ▷ National Electrical Safety Code (NESC)
- ▷ The International Building Code (IBC)
- ▷ ASHRAE Standards for the design of energy efficient buildings
- ▷ International Energy Conservation Code (IECC)
- ▷ International Fire Code
- ▷ American National Standards Institute (ANSI) Standards
- ▷ National Electrical Manufacturer’s Association (NEMA) Standards
- ▷ Underwriter’s Laboratories, Inc. (UL)
- ▷ Illuminating Engineering Society (IES) Lighting Handbook
- ▷ Americans with Disabilities Act Accessibility Guidelines (ADAAG)
- ▷ All codes and standards as established by the University of North Dakota

GENERAL REQUIREMENTS

The electrical design for this project will include the following considerations:

ELECTRICAL DISTRIBUTION: Selective demolition of existing distribution equipment, conduits, and feeders will be performed based upon the location, age, and condition of the existing equipment. When possible, existing panelboards will be reutilized.

GENERATOR SYSTEM(S): When applicable existing emergency/standby generator distribution will be expanded to provide emergency or standby power to required life safety, and standby loads throughout facilities.

MECHANICAL EQUIPMENT CONNECTIONS: For large mechanical equipment loads, 480V feeds will be provided, when available within the associated facility.

FIRE ALARM SYSTEMS: New fire alarm systems will be provided for the new additions. In buildings to be renovated, the existing fire alarm systems will be upgraded and expanded as required to meet code.

ACCESS CONTROL: Access control and security systems will be provided for the new additions. In buildings to be renovated, the existing systems will be upgraded and extended as required.

PHASE 1

The tables below the phase statistics and use distribution in NSF. The floor plan illustrates the location in the campus and the chart to the right indicates all programmatic spaces included in phase 1.

BUILDING ADDITION

PHASE SUMMARY


Phase 1 of the master plan involves the construction of a new addition to the north and west sides of Upson I. A portion of the north wing of the addition will include a new high bay loading area to serve the existing high bay space along the west side of Upson I with one occupied floor above while the balance of the usable square footage will be framed in three conventional stories to align with the floor-to-floor height in Harrington Hall. This first phase will construct a series of research, teaching and support spaces identified in the program as well as a new home for Biomedical Engineering, a replacement for Chemical Engineering's Unit Operations and equipment support labs for Mechanical Engineering. It will also provide swing space to vacate a significant portion of the east side of Harrington Hall for work in Phase 2 and it will vacate all lab spaces in Upson II in preparation for subsequent phases in that portion of the complex. Phase 1 construction will also create a new centralized dock and loading area with overhead door access into both the east and west sides of the Upson I high bay spaces.

STATS

| | |
|-------------------|--------------|
| PHASE NUMBER | 1 |
| NUMBER OF LEVELS | 3 |
| NET SQUARE FEET | 29,286 |
| GROSS SQUARE FEET | 51,397 |
| COST | \$24,072,763 |
| TYPE | NEW |

USE BREAKOUT (NSF)

| | | |
|-------------------------|--------|-----|
| TEACHING LABORATORY | 8,233 | 28% |
| RESEARCH LABORATORY | 12,609 | 43% |
| LABORATORY SUPPORT | 4,914 | 17% |
| LECTURE + CLASSROOM | 0 | 0% |
| OFFICE + ADMINISTRATION | 3,530 | 12% |
| OTHER | 0 | 0% |



SPACE IN PHASE 1

| | QTY | NSF |
|---|-----|-------|
| PETROLEUM ENGINEERING | | 2,178 |
| PE Teaching Laboratory | 1 | 2,178 |
| CHEMICAL ENGINEERING | | 7,864 |
| Teaching Laboratory (Unit Ops 1) | 1 | 1,089 |
| Unit Operations Teaching Laboratory | 1 | 1,815 |
| Wet Chemistry Research | 1 | 1,815 |
| Research Laboratory | 1 | 363 |
| Research Laboratory | 1 | 363 |
| Research Laboratory | 1 | 363 |
| Chem E Shop / Tool Storage | 1 | 484 |
| Fittings and Material Storage | 1 | 242 |
| Chem E Shop Storage | 1 | 121 |
| Chemistry Prep | 1 | 242 |
| Instrumentation Laboratory | 1 | 242 |
| Instrumentation Laboratory | 1 | 363 |
| Flue Mezzanine | 1 | 242 |
| Lab Manager's Office | 1 | 120 |
| ELECTRICAL ENGINEERING/COMPUTER SCIENCE | | 2,387 |
| EE&CS Maker Space | 1 | 2,178 |

| | | |
|------------------------------------|----|--------------|
| EE & CS Maker Space Support | 1 | 209 |
| MECHANICAL ENGINEERING | | 5,703 |
| ME Instructional Machine Shop new | 1 | 1,699 |
| ME Machine Shop new | 1 | 1,719 |
| ME Storage / Dock Area | 1 | 2,285 |
| COLLEGE OF ENGINEERING | | 1,452 |
| Drone Laboratory | 1 | 1,452 |
| BIOMEDICAL ENGINEERING | | 9,702 |
| Biomed Eng Teaching Laboratory | 1 | 1,452 |
| Biomedical Engineering Laboratory | 1 | 1,815 |
| Biomedical Research Wet Laboratory | 1 | 1,089 |
| Biomedical Optics Laboratory | 1 | 726 |
| Biomedical Exercise Laboratory | 1 | 726 |
| Biomed Lab Storage | 1 | 363 |
| Biomedical Secure Records Storage | 1 | 121 |
| Department Chair Office | 1 | 170 |
| Faculty Office | 7 | 840 |
| Grad Students / PhD Offices | 30 | 2,400 (80EA) |

| | |
|--------|--------|
| TOTALS | 29,286 |
|--------|--------|

MECHANICAL NARRATIVE

SITE EQUIPMENT AND UTILITIES

The building addition will be served by new steam, steam condensate, water, sanitary sewer, storm sewer, and natural gas piping connected to the existing mains located north of the addition and/or west of Harrington Hall. The utilities will be sized to serve Phase 2 of the project.

Existing mechanical equipment and external ductwork/piping in the area to the east of Harrington Hall and Upson II will be removed or relocated to accommodate the building addition.

AIR HANDLING SYSTEMS

The building addition will be served by two different types of air handling units (AHUs). In general, laboratory spaces will be served by 100% outside air (OA) AHUs, while non-laboratory spaces will be served by recirculating AHUs. Each AHU will operate in a variable air volume (VAV) mode to minimize energy use. To the extent possible, all AHUs will be located in the penthouse.

The components of each 100% AHU will be as follows (listed in direction of airflow):

| COMPONENT | COMMENTS |
|-------------------------|--|
| Outside air dampers | Low-leak dampers, airflow measurement |
| Prefilter bank | MERV 8, 2" plated filters |
| Final filter bank | MERV 14, 12" cartridge |
| Heat recovery coil bank | Runaround water coil, glycol for freeze protection |
| Preheat coil bank | Heating water coil |
| Supply fan(s) | Fan array with VFD |
| Humidifier grid | Steam dispersion grid |
| Cooling coil bank | Chilled water coil |
| Sound attenuator | 36" sound attenuating section |
| Discharge dampers | Low-leak dampers |

The components of each recirculating AHU will be as follows (listed in direction of airflow):

| COMPONENT | COMMENTS |
|-------------------------------|--|
| Return fan(s) | Fan array with VFD |
| Return/relief mixing box | Low-leak dampers |
| Return/outside air mixing box | Low-leak dampers, 100% economizer capabilities, airflow measurement on outside air |

| COMPONENT | COMMENTS |
|-------------------|-------------------------------|
| Prefilter bank | MERV 8, 2" plated filters |
| Final filter bank | MERV 14, 12" cartridge |
| Preheat coil bank | Heating water coil |
| Supply fan(s) | Fan array with VFD |
| Cooling coil bank | Chilled water coil |
| Sound attenuator | 36" sound attenuating section |
| Discharge dampers | Low-leak dampers |

Outside air will be introduced to each of the AHUs via louvers in the mechanical room side wall. Relief air will be discharged through louvers or roof hoods.

All AHUs will have double-wall construction, access doors at each coil and filter section, and internal lights for ease of maintenance. Vibration isolation (internal and/or external) will be provided to minimize noise and vibration transmission to the occupied spaces below.

EXHAUST SYSTEMS

High-plume mixed-flow exhaust fan systems will be installed to provide exhaust for the required facility spaces. Each fan system will be sized to exhaust both fume/lab exhaust as well as general building exhaust (such as restrooms, custodial closets, etc.). The new fan systems will be sized for N+1 redundancy. Each fan will be variable speed and include sound attenuation, and each fan system will include a mixing box / bypass plenum.

All exhaust discharge from the building will be located as far as feasible from fresh air intakes and from other buildings to help prevent air recirculation into occupied spaces.

ATRIUM SMOKE EVACUATION SYSTEM

A smoke evacuation system will be provided to serve the 3-story atrium in the building addition. It will include multiple roof-mounted exhaust fans that will be located and sized based on future smoke modeling calculations. Makeup air will be provided through passive means, such as through operable doors and/or louvers.

HEAT RECOVERY SYSTEM

A heat recovery unit will be installed to transfer energy between the 100% OA AHUs and the exhaust fan systems. The heat recovery unit(s) will be located in the penthouse and will consist of a MERV 8 filter bank followed by a runaround coil. All internal components will be either stainless steel or coated steel to minimize corrosion due to the fume exhaust airstream. A base-mounted pump will be provided for each runaround loop, located in the penthouse, and will circulate a mixture of glycol and water between the exhaust runaround coils and the AHU runaround coils. A three-way valve will be provided for temperature control and frost control purposes.

AIR DISTRIBUTION SYSTEMS

A variable air volume (VAV) air distribution system will be utilized for all areas. With this system type, each non-laboratory temperature control zone will be served by a supply VAV box with an integral hot water reheat coil, while each laboratory temperature control zone will be served by a high-speed venturi air valve and hot water reheat coil. The VAV box/air valve will modulate its damper position to maintain the required airflow as system pressure fluctuates. A heating water 2-way control valve will modulate water flow to the reheat coil to maintain desired zone temperature conditions. Supply air ductwork will generally be galvanized steel construction.

The exhaust system will operate in a VAV mode similar to the supply air system. Each temperature control zone will be served by an exhaust VAV box or air valve. In non-laboratory zones, the airflow of the exhaust VAV box will “track” the airflow of the corresponding zone supply VAV box to guarantee proper space pressurization is maintained. In laboratory zones, a fume hood air valve will be used to provide proper fume hood face velocity and a general exhaust air valve will modulate to provide proper room pressurization and minimum ventilation rates. All exhaust air will be routed using common ductwork to the high-plume exhaust fans. Exhaust air ductwork will generally be galvanized steel construction; however, all ductwork downstream of fume hoods, canopy hoods, snorkel hoods, or other specialized equipment will be stainless steel construction.

The return air system for the recirculating AHUs will generally consist of transfer ducts and return air plenum. Return air airflow-measuring dampers will be used near the return air duct main to control the air volume for each floor.

Room occupancy sensors will be used to reduce the airflow to the spaces during unoccupied hours. In laboratory areas, the airflow will be reduced, but will still be sufficient to maintain minimum code-required ventilation rates.

STANDALONE HEATING/COOLING SYSTEMS

In order to minimize the size of the AHUs, standalone units will be provided to supply dedicated heating and cooling to specialized spaces. Electrical rooms, mechanical rooms, telecom closets, and other similar cooling-only zones will be served by chilled water fan coil units (FCUs) or refrigerant-based split systems. Dock areas will be served by heating water unit heaters (UHs). Stairs and vestibules will be served by 2-pipe or 4-pipe FCUs.

CHILLED WATER SYSTEM

New rooftop air-cooled chillers will be provided to serve the building addition. Additionally, the use of small heat recovery chillers will be investigated during the design phase to provide simultaneous heating and cooling during low-load conditions.

New chilled water pumps will be provided to circulate chilled water to all required coils. The pumps will be controlled via VFDs and will modulate pump speed to allow chilled water flow reduction during low load conditions.

All new coil loads will be provided with pressure-independent 2-way control valves.

STEAM AND CONDENSATE SYSTEM

New steam and condensate piping will be extended from the campus system to the building. A new steam pressure reducing station will be provided to create low pressure steam.

New steam-to-hot water heat exchangers will be provided to generate heating water. Steam will be extended to the 100% OA AHUs for humidification. A new condensate pump serving the building will be provided to return condensate to the campus system.

HEATING WATER SYSTEM

The new steam-to-hot water heat exchangers will generate heating water. New heating water pumps will be provided to circulate heating water to all required AHU, terminal unit, and perimeter heating loads. Pumps will be controlled via VFD to modulate pump speed for energy savings.

Panel radiators will be provided to serve perimeter zones with large expanses of glazing. All new loads will be provided with pressure-independent 2-way control valves.

BUILDING AUTOMATION SYSTEM (BAS)

The building addition will utilize direct digital controls (DDC). The BAS will have the capability to adjust setpoints and system operation to match changing facility functions. All controls items will be integrated into the existing University controls infrastructure.

WATER SYSTEMS

New parallel, main backflow preventers and water meter will be provided at the location of the building water entrance. Additional backflow preventers will be used to create a laboratory cold water system for use in the lab spaces. The additional backflow preventers are planned to be installed in the mechanical penthouse along with the water softener and water heaters described below.

Two new semi-instantaneous steam-fed water heaters will be installed in the mechanical penthouse (one domestic, one laboratory) to support their respective fixtures. Recirculating pumps and piping will be installed on each hot water system to ensure continuous hot water supply at each point of use.

A water softener will be provided to reduce the hardness of all water feeding the water heaters, pure water equipment, and certain laboratory equipment. Additionally, soft water will be piped as necessary to any required laboratory areas.

Temperature mixing valves will be provided to serve any emergency fixtures (eye washes or emergency showers) in compliance with ANSI standards.

PURE WATER SYSTEMS

If required for laboratory uses, high purity water will be generated by a single water purification skid. The equipment will include carbon filters, reverse osmosis (RO) equipment, deionization (DI) tanks, ultraviolet (UV) sterilizer, 0.2-micron filters, storage and recirculating pump(s) that will continuously circulate the pure water through a polypropylene pipe loop to use points and laboratory equipment throughout the addition. The water quality produced by this system will be equivalent to Type 2 (1 mega-ohm) grade meeting ASTM/ISO 3696 specifications. Point of use polishers will be used for Type 1 lab water needs.

DRAIN, WASTE, AND VENT

Sanitary waste and vent piping will be extended to all required fixtures throughout the facility. Laboratory waste piping will be limited to piping from a laboratory sink/drain to the nearest main riser and will be comprised of fuse-seal polypropylene pipe and fittings. A dedicated acid neutralization system is not anticipated as chemicals will be collected and disposed of in lieu of dumping them down the sinks.

STORM WATER SYSTEMS

Primary and overflow storm drainage piping will be extended to all roof drain areas. The primary system will be routed to the underground storm sewer system. The overflow system will be routed to downspout nozzles located on the exterior walls 18" above grade.

NATURAL GAS SYSTEM

Natural gas will be routed to the new laboratory areas. When serving laboratory areas, an emergency shutoff valve will be provided to stop the flow of natural gas in the event of an emergency. Delivery pressure for laboratory use points will be between 7-11" w.c. unless an elevated pressure is required.

SPECIALTY GASES

LABORATORY COMPRESSED AIR: A new air compressor will be installed in the penthouse to serve new laboratory equipment. The compressor will be a dual oil free scroll tank mount type and installed on top of a 4" high concrete equipment pad with vibration isolators. The system will include a refrigerated air dryer (37.4 deg F dewpoint) and inline filters to provide clean, dry air suitable for laboratory grade use. Piping and fittings will be high purity copper suitable for laboratory use. A master pressure reducing valve will be installed in the penthouse to regulate the system delivery pressure to 125 psig.

CYLINDER GASES: The need and quantity of cylinder gases will be determined during subsequent design phases. Where centralized and stored within a dedicated cylinder closet, gas manifolds with auto-changeover capabilities will be installed and high purity copper suitable for laboratory use will be routed to all use points and equipment.

LABORATORY VACUUM: A new centralized laboratory vacuum pump system will be installed in the penthouse. The pump will be a multi-plex unit with receiver installed on top of a 4" high concrete equipment pad with vibration isolators. The system will be size to maintain a vacuum of 19 inches of mercury at the farthest terminal at peak demand based on 0.5 scfm demand at each terminal. Piping/fittings will be high purity copper suitable for laboratory use.

FIRE PROTECTION

A new fire suppression system will be installed to provide full coverage to all required areas. Hazard classifications will be based on applicable NFPA 13 requirements for each space type.

New fire protection standpipes and hose connections will be installed in all egress stairs.

All work will comply with NFPA 13, NFPA 14, NFPA 24, and other local requirements.

Code-required fire dampers, smoke dampers, and fire/smoke dampers will be installed throughout the building as necessary.

ELECTRICAL NARRATIVE

ELECTRICAL DISTRIBUTION SYSTEM

The building addition will be served by a new 480Y/277V, 3-phase, 4-wire normal electrical service. The main service will be sized to accommodate Phase 2 of the project. A main switchboard will provide feeds to distribution panelboards, and large mechanical loads throughout the building. In general, new HVAC equipment and large equipment loads will be served at 480 volts, 3-phase. Lighting throughout the facility will be served at 277 volts, single phase. Laboratory, office, and computer equipment, as well as general-purpose receptacle circuits will be served at 120 volts, single phase. All other equipment and devices will be served by the appropriate distribution system voltage

Additional electrical distribution system details include the following:

- Distribution system switchboards and panelboards will make use of circuit breakers for overcurrent protection of feeders and branch circuits.
- Copper bussing will be provided for all electrical distribution system equipment.
- Digital customer metering equipment will be provided as determined by consultation with University facilities personnel. Digital metering devices will be connected to the building energy management control system to allow for remote monitoring.
- Separate panelboards will be used to support facility lighting and general-purpose electrical requirements.
- Surge Protection Devices (SPD) will be provided for all new Life Safety distribution equipment

STANDBY/EMERGENCY GENERATOR SYSTEM

A new pad mounted diesel driven generator and associated emergency/standby electrical distribution equipment will be provided for the addition. It will be sized to feed Phase 2 of the project. The system will be used to supply code required emergency and life safety loads. These loads will include but may not be limited to emergency egress and exit lighting, any essential HVAC loads, alarm and communication systems and fire alarm equipment. In addition to code required loads some capacity will be provided for standby loads in each lab as coordinated with the owner.

LIGHTING SYSTEMS

Lighting systems throughout the facility will be designed in accordance with University design guidelines, IES recommendations and applicable energy codes. Lighting power densities will be minimized by using highly efficient fixtures throughout the areas of renovation. Occupancy/vacancy sensors will be used throughout most spaces to provide automatic off of lighting loads during unoccupied times. In addition, where daylighting opportunities and requirements exist, the use of daylighting controlled lighting systems will be utilized. In general, lighting systems will be as follows:

- For laboratories/classrooms it is critical to provide appropriate illumination levels on bench tops, to minimize the impact of shadows created by equipment, casework and personnel.. In addition, it is imperative that labs be provided with lighting fixtures that can withstand environmental conditions in each space. In areas with ceilings, high efficient, recessed linear, LED fixtures will be installed over the edge of the bench tops. This type of lighting provides adequate levels of illumination on bench tops, helps to minimize issues associated with glare and shadowing, while still providing illumination of vertical surfaces.
- All fixtures in laboratories with no ceiling will be linear pendant, high efficient LED fixtures. A portion of the light distribution of these fixtures will be indirect in order to increase the quality of light by providing even, diffuse light levels.
- All fixtures in laboratory areas will be equipped with dimming to provide a variety of light levels. Normal power fixtures in laboratories will be enabled by occupancy/vacancy sensors, and controlled locally within each space. A portion of the lighting in all laboratories will be connected to the emergency generator system.
- In chemical storage areas or laboratories that make use of a significant amount of chemicals, the most prudent approach to lighting is 1'x 4' recessed lensed LED troffers. This type of illumination reduces shadowing and provides adequate illumination levels. Normal fixtures in these spaces will be enabled by occupancy/vacancy sensors, and controlled locally within each space. A portion of the lighting in all areas with high chemical usage will be connected to the emergency generator system.

- Lighting in corridors will be provided by recessed, high efficient, LED fixtures. A portion of these fixtures will be connected to the emergency generator system to provide Code required emergency egress lighting and night lighting. All normal lighting fixtures will be connected to a lighting control system so they are turned off when the building is normally unoccupied.


RECEPTACLE LAYOUTS

Receptacle layouts and circuiting to support computer equipment, classroom equipment, laboratory equipment, telecommunications equipment and general purpose needs will be provided in accordance with direction provided by building users and campus personnel.

Two channel surface metal raceway systems will be provided above benches in laboratories to support the distribution of power, telecommunications and instrumentation cabling to computer and laboratory equipment. Duplex receptacles will be installed in surface metal raceway systems at intervals dictated by building users. Receptacles in raceway systems will be connected to 20-amp branch circuits unless further direction has been provided by a specific user.

In equipment alcoves and shared equipment or instrumentation spaces wall mounted busway will be utilized. The busway will provide quick plug-and-play power re-configuration to accommodate equipment changes. Busway will be rated at 208Y/120V, 3 phase, 4-wire with amperage ratings that vary depending on length. Standard busway receptacle/circuit breaker combination units will be coordinated with existing equipment and Campus personnel.

All electrical devices in laboratories will be labeled with the panel source and circuit number. Dedicated receptacles and circuits will be provided as required to support specific equipment locations throughout the facility. All receptacle branch circuits will be provided with equipment ground conductors. All branch circuit wiring will be copper and will be installed in concealed raceway systems. Ground fault interrupting type receptacles will be provided in all Code required locations, and in all designated “wet” locations throughout the facility.



FIRST FLOOR

DEPARTMENT BREAKOUT LEGEND

- | | | |
|---|--------------------------------|-----------------------------|
| CHEMICAL ENGINEERING | CIVIL ENGINEERING | BIOMEDICAL ENGINEERING |
| ELECTRICAL ENGINEERING + COMPUTER SCIENCE | COLLEGE OF ENGINEERING + MINES | INSTITUTE OF ENERGY STUDIES |
| GEOLOGY + GEOLOGICAL ENGINEERING | PETROLEUM ENGINEERING | BUILDING SUPPORT |
| MECHANICAL ENGINEERING | REGISTRAR | CIRCULATION |



SECOND FLOOR

DEPARTMENT BREAKOUT LEGEND

- | | | |
|---|--------------------------------|-----------------------------|
| CHEMICAL ENGINEERING | CIVIL ENGINEERING | BIOMEDICAL ENGINEERING |
| ELECTRICAL ENGINEERING + COMPUTER SCIENCE | COLLEGE OF ENGINEERING + MINES | INSTITUTE OF ENERGY STUDIES |
| GEOLOGY + GEOLOGICAL ENGINEERING | PETROLEUM ENGINEERING | BUILDING SUPPORT |
| MECHANICAL ENGINEERING | REGISTRAR | CIRCULATION |



THIRD FLOOR

DEPARTMENT BREAKOUT LEGEND

- CHEMICAL ENGINEERING

ELECTRICAL ENGINEERING + COMPUTER SCIENCE

GEOLOGY + GEOLOGICAL ENGINEERING

MECHANICAL ENGINEERING
- CIVIL ENGINEERING

COLLEGE OF ENGINEERING + MINES


PETROLEUM ENGINEERING

REGISTRAR
- BIOMEDICAL ENGINEERING

INSTITUTE OF ENERGY STUDIES

BUILDING SUPPORT

CIRCULATION



ROOF PLAN

DEPARTMENT BREAKOUT LEGEND

CHEMICAL ENGINEERING

ELECTRICAL ENGINEERING + COMPUTER SCIENCE

GEOLOGY + GEOLOGICAL ENGINEERING

MECHANICAL ENGINEERING

CIVIL ENGINEERING

COLLEGE OF ENGINEERING + MINES

PETROLEUM ENGINEERING

REGISTRAR

BIOMEDICAL ENGINEERING

INSTITUTE OF ENERGY STUDIES

BUILDING SUPPORT

CIRCULATION

PHASE 2

DEMOLITION AND INFILL

PHASE SUMMARY

Phase 2 of the master plan will demolish a significant portion of the east side of Harrington Hall and replace it with a new three-story addition aligning with the construction completed in Phase 1. The portion of the program accommodated in Phase 2 will include new teaching laboratories for Electrical Engineering, the Civil Engineering's MICA and Bridge Labs, Chemistry teaching labs for Chemical Engineering and several flexible, open research spaces to be shared among several departments.


The tables below the phase statistics and use distribution in NSF. The floor plan illustrates the location in the campus and the chart to the right indicates all programmatic spaces included in phase 2.

STATS

| | |
|-------------------|--------------|
| PHASE NUMBER | 2 |
| NUMBER OF LEVELS | 3 |
| NET SQUARE FEET | 25,205 |
| GROSS SQUARE FEET | 44,219 |
| COST | \$21,049,123 |
| TYPE | DEMO + NEW |

USE BREAKOUT (NSF)

| | | |
|-------------------------|--------|-----|
| TEACHING LABORATORY | 7,297 | 29% |
| RESEARCH LABORATORY | 16,698 | 66% |
| LABORATORY SUPPORT | 1,210 | 5% |
| LECTURE + CLASSROOM | 0 | 0% |
| OFFICE + ADMINISTRATION | 0 | 0% |
| OTHER | 0 | 0% |



| SPACE IN PHASE 2 | | QTY | NSF | | |
|---|---|-------|-------------------------------------|---|-------|
| PETROLEUM ENGINEERING | | | 3,630 | Glassware Prep / Chemical Storage | 1 363 |
| Industry Partner Computational Laboratory | 1 | 1,452 | Chemical Storage | 1 | 363 |
| New PE Research Laboratory | 1 | 2,178 | Chemical Storage | 1 | 242 |
| CIVIL ENGINEERING | | | 9,112 | ELECTRICAL ENGINEERING & COMPUTER 4,719 | |
| Computational Laboratory | 1 | 400 | SCIENCE | 1 | 1,815 |
| Environmental Engineering Lab 1 | 1 | 726 | EE&CS Teaching Laboratory | 1 | 1,089 |
| Environmental Engineering Lab 2 | 1 | 726 | EE&CS Circuits & Power Teaching Lab | 1 | 363 |
| Industrial Research Laboratory | 1 | 2,904 | EE&CS Research Laboratory | 1 | 363 |
| Bridge Lab | 1 | 1,452 | EE&CS Research Laboratory | 1 | 1,089 |
| MICA Laboratory | 1 | 2,904 | Computational Research Laboratory | | 2,904 |
| CHEMICAL ENGINEERING | | | 4,840 | MECHANICAL ENGINEERING 1 1,089 | |
| Wet Chemistry Teaching Laboratory | 2 | 1,452 | ME Instructional Measurement Lab | 1 | 1,815 |
| Chem E Research | 1 | 2,178 | ME Student Projects Laboratory | | |
| Teaching Lab Prep | 1 | 242 | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

MECHANICAL NARRATIVE

SITE EQUIPMENT AND UTILITIES

The Phase 1 building addition will provide utility connections for Phase 2. Where the partial demolition of Harrington Hall affects utilities, provisions will be made to keep the remaining portions of the building in service during Phase 2 construction.

AIR HANDLING SYSTEMS

The building addition will be served by two different types of air handling units (AHUs). In general, laboratory spaces will be served by 100% outside air (OA) AHUs, while non-laboratory spaces will be served by recirculating AHUs. Each AHU will operate in a variable air volume (VAV) mode to minimize energy use. To the extent possible, all AHUs will be located in the new penthouse. Additionally, the new AHUs will be sized for future extension to Harrington Hall in Phase 4.

The components of each 100% AHU will be as follows (listed in direction of airflow):

| COMPONENT | COMMENTS |
|-------------------------|--|
| Outside air dampers | Low-leak dampers, airflow measurement |
| Prefilter bank | MERV 8, 2" plated filters |
| Final filter bank | MERV 14, 12" cartridge |
| Heat recovery coil bank | Runaround water coil, glycol for freeze protection |
| Preheat coil bank | Heating water coil |
| Supply fan(s) | Fan array with VFD |
| Humidifier grid | Steam dispersion grid |
| Cooling coil bank | Chilled water coil |
| Sound attenuator | 36" sound attenuating section |
| Discharge dampers | Low-leak dampers |

The components of each recirculating AHU will be as follows (listed in direction of airflow):

| COMPONENT | COMMENTS |
|-------------------------------|--|
| Return fan(s) | Fan array with VFD |
| Return/relief mixing box | Low-leak dampers |
| Return/outside air mixing box | Low-leak dampers, 100% economizer capabilities, airflow measurement on outside air |

| COMPONENT | COMMENTS |
|-------------------|-------------------------------|
| Prefilter bank | MERV 8, 2" plated filters |
| Final filter bank | MERV 14, 12" cartridge |
| Preheat coil bank | Heating water coil |
| Supply fan(s) | Fan array with VFD |
| Cooling coil bank | Chilled water coil |
| Sound attenuator | 36" sound attenuating section |
| Discharge dampers | Low-leak dampers |

Outside air will be introduced to each of the AHUs via louvers in the mechanical room side wall. Relief air will be discharged through louvers or roof hoods.

All AHUs will have double-wall construction, access doors at each coil and filter section, and internal lights for ease of maintenance. Vibration isolation (internal and/or external) will be provided to minimize noise and vibration transmission to the occupied spaces below.

EXHAUST SYSTEMS

High-plume mixed-flow exhaust fan systems will be installed to provide exhaust for the required facility spaces. Each fan system will be sized to exhaust both fume/lab exhaust as well as general building exhaust (such as restrooms, custodial closets, etc.). The new fan systems will be sized for N+1 redundancy. Each fan will be variable speed and include sound attenuation, and each fan system will include a mixing box / bypass plenum. The new exhaust fan systems will be sized for future extension to Harrington Hall in Phase 4.

All exhaust discharge from the building will be located as far as feasible from fresh air intakes and from other buildings to help prevent air recirculation into occupied spaces.

HEAT RECOVERY SYSTEM

A heat recovery unit will be installed to transfer energy between the 100% OA AHUs and the exhaust fan systems. The heat recovery unit(s) will be located in the penthouse and will consist of a MERV 8 filter bank followed by a runaround coil. All internal components will be either stainless steel or coated steel to minimize corrosion due to the fume exhaust airstream. A base-mounted pump will be provided for each runaround loop, located in the penthouse, and will circulate a mixture of glycol and water between the exhaust runaround coils and the AHU runaround coils. A three-way valve will be provided for temperature control and frost control purposes.

AIR DISTRIBUTION SYSTEMS

A variable air volume (VAV) air distribution system will be utilized for all areas. With this system type, each non-laboratory temperature control zone will be served by a supply VAV box with an integral hot water reheat coil, while

each laboratory temperature control zone will be served by a high-speed venturi air valve and hot water reheat coil. The VAV box/air valve will modulate its damper position to maintain the required airflow as system pressure fluctuates. A heating water 2-way control valve will modulate water flow to the reheat coil to maintain desired zone temperature conditions. Supply air ductwork will generally be galvanized steel construction.

The exhaust system will operate in a VAV mode similar to the supply air system. Each temperature control zone will be served by an exhaust VAV box or air valve. In non-laboratory zones, the airflow of the exhaust VAV box will “track” the airflow of the corresponding zone supply VAV box to guarantee proper space pressurization is maintained. In laboratory zones, a fume hood air valve will be used to provide proper fume hood face velocity and a general exhaust air valve will modulate to provide proper room pressurization and minimum ventilation rates. All exhaust air will be routed using common ductwork to the high-plume exhaust fans. Exhaust air ductwork will generally be galvanized steel construction; however, all ductwork downstream of fume hoods, canopy hoods, snorkel hoods, or other specialized equipment will be stainless steel construction.

The return air system for the recirculating AHUs will generally consist of transfer ducts and return air plenum. Return air airflow-measuring dampers will be used near the return air duct main to control the air volume for each floor.

Room occupancy sensors will be used to reduce the airflow to the spaces during unoccupied hours. In laboratory areas, the airflow will be reduced, but will still be sufficient to maintain minimum code-required ventilation rates.

STANDALONE HEATING/COOLING SYSTEMS

In order to minimize the size of the AHUs, standalone units will be provided to supply dedicated heating and cooling to specialized spaces. Electrical rooms, mechanical rooms, telecom closets, and other similar cooling-only zones will be served by chilled water fan coil units (FCUs) or refrigerant-based split systems. Dock areas will be served by heating water unit heaters (UHs). Stairs and vestibules will be served by 2-pipe or 4-pipe FCUs.

CHILLED WATER SYSTEM

New rooftop air-cooled chillers will be provided to serve the building addition. Additionally, the use of small heat recovery chillers will be investigated during the design phase to provide simultaneous heating and cooling during low-load conditions. The new chilled water systems will be sized for future extension to Harrington Hall in Phase 4.

New chilled water pumps will be provided to circulate chilled water to all required coils. The pumps will be controlled via VFDs and will modulate pump speed to allow chilled water flow reduction during low load conditions.

All new coil loads will be provided with pressure-independent 2-way control valves.

STEAM AND CONDENSATE SYSTEM

New low-pressure steam and condensate piping will be extended from the Phase 1 building addition to the Phase 2 building.

New steam-to-hot water heat exchangers will be provided to generate heating water. Steam will be extended to the 100% OA AHUs for humidification. A new condensate pump serving the building will be provided to return condensate to the campus system.

HEATING WATER SYSTEM

The new steam-to-hot water heat exchangers will generate heating water. New heating water pumps will be provided to circulate heating water to all required AHU, terminal unit, and perimeter heating loads. Pumps will be controlled via VFD to modulate pump speed for energy savings.

Panel radiators will be provided to serve perimeter zones with large expanses of glazing. All new loads will be provided with pressure-independent 2-way control valves.

BUILDING AUTOMATION SYSTEM (BAS)

The building addition will utilize direct digital controls (DDC). The BAS will have the capability to adjust setpoints and system operation to match changing facility functions. All controls items will be integrated into the existing University controls infrastructure.

WATER SYSTEMS

Domestic water will be extended from the Phase 1 building to the Phase 2 building. Backflow preventers will be used to create a laboratory cold water system for use in the lab spaces. The additional backflow preventers are planned to be installed in the mechanical penthouse along with the water softener and water heaters described below.

Two new semi-instantaneous steam-fed water heaters will be installed in the mechanical penthouse (one domestic, one laboratory) to support their respective fixtures. Recirculating pumps and piping will be installed on each hot water system to ensure continuous hot water supply at each point of use.

A water softener will be provided to reduce the hardness of all water feeding the water heaters, pure water equipment, and certain laboratory equipment. Additionally, soft water will be piped as necessary to any required laboratory areas.

Temperature mixing valves will be provided to serve any emergency fixtures (eye washes or emergency showers) in compliance with ANSI standards.

PURE WATER SYSTEMS

If required for laboratory uses, high purity water will be generated by a single water purification skid. The equipment will include carbon filters, reverse osmosis (RO) equipment, deionization (DI) tanks, ultraviolet (UV) sterilizer, 0.2-micron filters, storage and recirculating pump(s) that will continuously circulate the pure water through a polypropylene pipe loop to use points and laboratory equipment throughout the addition. The water quality produced by this system will be equivalent to Type 2 (1 mega-ohm) grade meeting ASTM/ISO 3696 specifications. Point of use polishers will be used for Type 1 lab water needs.

DRAIN, WASTE, AND VENT

Sanitary waste and vent piping will be extended to all required fixtures throughout the facility. Laboratory waste piping will be limited to piping from a laboratory sink/drain to the nearest main riser and will be comprised of fuse-seal polypropylene pipe and fittings. A dedicated acid neutralization system is not anticipated as chemicals will be collected and disposed of in lieu of dumping them down the sinks.

STORM WATER SYSTEMS

Primary and overflow storm drainage piping will be extended to all roof drain areas. The primary system will be routed to the underground storm sewer system. The overflow system will be routed to downspout nozzles located on the exterior walls 18" above grade.

NATURAL GAS SYSTEM

Natural gas will be routed to the new laboratory areas from the Phase 1 building. When serving laboratory areas, an emergency shutoff valve will be provided to stop the flow of natural gas in the event of an emergency. Delivery pressure for laboratory use points will be between 7-11" w.c. unless an elevated pressure is required.

SPECIALTY GASES

LABORATORY COMPRESSED AIR: A new air compressor will be installed in the penthouse to serve new laboratory equipment. The compressor will be a dual oil free scroll tank mount type and installed on top of a 4" high concrete equipment pad with vibration isolators. The system will include a refrigerated air dryer (37.4 deg F dewpoint) and inline filters to provide clean, dry air suitable for laboratory grade use. Piping and fittings will be high purity copper suitable for laboratory use. A master pressure reducing valve will be installed in the penthouse to regulate the system delivery pressure to 125 psig.

CYLINDER GASES: The need and quantity of cylinder gases will be determined during subsequent design phases. Where centralized and stored within a dedicated cylinder closet, gas manifolds with auto-changeover capabilities will be installed and high purity copper suitable for laboratory use will be routed to all use points and equipment.

LABORATORY VACUUM: A new centralized laboratory vacuum pump system will be installed in the penthouse. The pump will be a multi-plex unit with receiver installed on top of a 4" high concrete equipment pad with vibration isolators. The system will be size to maintain a vacuum of 19 inches of mercury at the farthest terminal at peak demand based on 0.5 scfm demand at each terminal. Piping/fittings will be high purity copper suitable for laboratory use.

FIRE PROTECTION

The Phase 1 fire suppression system will be extended to the Phase 2 building to provide full coverage to all required areas. Hazard classifications will be based on applicable NFPA 13 requirements for each space type.

New fire protection standpipes and hose connections will be installed in all egress stairs.

All work will comply with NFPA 13, NFPA 14, NFPA 24, and other local requirements.

Code-required fire dampers, smoke dampers, and fire/smoke dampers will be installed throughout the building as necessary.

ELECTRICAL NARRATIVE

ELECTRICAL DISTRIBUTION SYSTEM

The Phase 1 addition's new 480Y/277V, 3-phase, 4-wire normal electrical service and standby/generator system will be extended to serve the Phase 2 project. Lighting throughout Phase 2 will be served at 277 volts, single phase. Laboratory, office, and computer equipment, as well as general-purpose receptacle circuits will be served at 120 volts, single phase. All other equipment and devices will be served by the appropriate distribution system voltage

Additional electrical distribution system details include the following:

- Distribution system switchboards and panelboards will make use of circuit breakers for overcurrent protection of feeders and branch circuits.
- Copper bussing will be provided for all electrical distribution system equipment.
- Digital customer metering equipment will be provided as determined by consultation with University facilities personnel. Digital metering devices will be connected to the building energy management control system to allow for remote monitoring.
- Separate panelboards will be used to support facility lighting and general-purpose electrical requirements.
- Surge Protection Devices (SPD) will be provided for all new Life Safety distribution equipment

LIGHTING SYSTEMS

Lighting systems throughout the Phase 2 will be designed in accordance with University design guidelines, IES recommendations and applicable energy codes. Lighting power densities will be minimized by using highly efficient fixtures throughout the areas of renovation. Occupancy/vacancy sensors will be used throughout most spaces to provide automatic off of lighting loads during unoccupied times. In addition, where daylighting opportunities and requirements exist, the use of daylighting controlled lighting systems will be utilized. In general, lighting systems will be as follows:

- For laboratories/classrooms it is critical to provide appropriate illumination levels on bench tops, to minimize the impact of shadows created by equipment, casework and personnel.. In addition, it is imperative that labs be provided with lighting fixtures that can withstand environmental conditions in each space. In areas with ceilings, high efficient, recessed linear, LED fixtures will be installed over the edge of the bench tops. This type of lighting provides adequate levels of illumination on bench tops, helps to minimize issues associated with glare and shadowing, while still providing illumination of vertical surfaces.
- All fixtures in laboratories with no ceiling will be linear pendant, high efficient LED fixtures. A portion of the light distribution of these fixtures will be indirect in order to increase the quality of light by providing even, diffuse light levels.
- All fixtures in laboratory areas will be equipped with dimming to provide a variety of light levels. Normal power fixtures in laboratories will be enabled by occupancy/vacancy sensors, and controlled locally within each space. A portion of the lighting in all laboratories will be connected to the emergency generator system.
- In chemical storage areas or laboratories that make use of a significant amount of chemicals, the most prudent approach to lighting is 1'x 4' recessed lensed LED troffers. This type of illumination reduces shadowing and provides adequate illumination levels. Normal fixtures in these spaces will be enabled by occupancy/vacancy sensors, and controlled locally within each space. A portion of the lighting in all areas with high chemical usage will be connected to the emergency generator system.
- Lighting in corridors will be provided by recessed, high efficient, LED fixtures. A portion of these fixtures will be connected to the emergency generator system to provide Code required emergency egress lighting and night lighting. All normal lighting fixtures will be connected to a lighting control system so they are turned off when the building is normally unoccupied.

RECEPTACLE LAYOUTS

Receptacle layouts and circuiting to support computer equipment, classroom equipment, laboratory equipment, telecommunications equipment and general purpose needs will be provided in accordance with direction provided by building users and campus personnel.

Two channel surface metal raceway systems will be provided above benches in laboratories to support the distribution of power, telecommunications and instrumentation cabling to computer and laboratory equipment. Duplex receptacles will be installed in surface metal raceway systems at intervals dictated by building users. Receptacles in raceway systems will be connected to 20-amp branch circuits unless further direction has been provided by a specific user.

In equipment alcoves and shared equipment or instrumentation spaces wall mounted busway will be utilized. The busway will provide quick plug-and-play power re-configuration to accommodate equipment changes. Busway will be rated at 208Y/120V, 3 phase, 4-wire with amperage ratings that vary depending on length. Standard busway receptacle/circuit breaker combination units will be coordinated with existing equipment and Campus personnel.

All electrical devices in laboratories will be labeled with the panel source and circuit number. Dedicated receptacles and circuits will be provided as required to support specific equipment locations throughout the facility. All receptacle branch circuits will be provided with equipment ground conductors. All branch circuit wiring will be copper and will be installed in concealed raceway systems. Ground fault interrupting type receptacles will be provided in all Code required locations, and in all designated “wet” locations throughout the facility.



FIRST FLOOR

DEPARTMENT BREAKOUT LEGEND

- | | | |
|---|--------------------------------|-----------------------------|
| CHEMICAL ENGINEERING | CIVIL ENGINEERING | BIOMEDICAL ENGINEERING |
| ELECTRICAL ENGINEERING + COMPUTER SCIENCE | COLLEGE OF ENGINEERING + MINES | INSTITUTE OF ENERGY STUDIES |
| GEOLOGY + GEOLOGICAL ENGINEERING | PETROLEUM ENGINEERING | BUILDING SUPPORT |
| MECHANICAL ENGINEERING | REGISTRAR | CIRCULATION |



SECOND FLOOR

DEPARTMENT BREAKOUT LEGEND


- | | | |
|---|--------------------------------|-----------------------------|
| CHEMICAL ENGINEERING | CIVIL ENGINEERING | BIOMEDICAL ENGINEERING |
| ELECTRICAL ENGINEERING + COMPUTER SCIENCE | COLLEGE OF ENGINEERING + MINES | INSTITUTE OF ENERGY STUDIES |
| GEOLOGY + GEOLOGICAL ENGINEERING | PETROLEUM ENGINEERING | BUILDING SUPPORT |
| MECHANICAL ENGINEERING | REGISTRAR | CIRCULATION |



THIRD FLOOR

DEPARTMENT BREAKOUT LEGEND

- | | | |
|---|--------------------------------|-----------------------------|
| CHEMICAL ENGINEERING | CIVIL ENGINEERING | BIOMEDICAL ENGINEERING |
| ELECTRICAL ENGINEERING + COMPUTER SCIENCE | COLLEGE OF ENGINEERING + MINES | INSTITUTE OF ENERGY STUDIES |
| GEOLOGY + GEOLOGICAL ENGINEERING | PETROLEUM ENGINEERING | BUILDING SUPPORT |
| MECHANICAL ENGINEERING | REGISTRAR | CIRCULATION |



ROOF PLAN

DEPARTMENT BREAKOUT LEGEND

- CHEMICAL ENGINEERING

ELECTRICAL ENGINEERING + COMPUTER SCIENCE

GEOLOGY + GEOLOGICAL ENGINEERING

MECHANICAL ENGINEERING
- CIVIL ENGINEERING

COLLEGE OF ENGINEERING + MINES

PETROLEUM ENGINEERING

REGISTRAR
- BIOMEDICAL ENGINEERING

INSTITUTE OF ENERGY STUDIES

BUILDING SUPPORT

CIRCULATION

PHASE 3

The tables below the phase statistics and use distribution in NSF. The floor plan illustrates the location in the campus and the chart to the right indicates all programmatic spaces included in phase 3.

RENOVATE UPSON II

PHASE SUMMARY


Phase 3 will renovate Upson II to consolidate the bulk of the faculty and departmental offices for Electrical Engineering and Computer Science, Mechanical Engineering, Chemical Engineering and Civil Engineering as well as the Dean's Office and most administrative functions of the college. It is assumed that office space can be accommodated elsewhere on campus during this phase of construction as all lab and instruction functions would have already been vacated as part of Phases 1 and 2. This phase ideally would also include a major exterior renovation of Upson II to bring it more in context with the adjacent building in this region of the campus.

STATS

| | |
|-------------------|-------------|
| PHASE NUMBER | 3 |
| NUMBER OF LEVELS | 4 |
| NET SQUARE FEET | 23,877 |
| GROSS SQUARE FEET | 41,889 |
| COST | \$8,355,132 |
| TYPE | RENOVATION |

USE BREAKOUT (NSF)

| | | |
|-------------------------|--------|------|
| TEACHING LABORATORY | 0 | 0% |
| RESEARCH LABORATORY | 0 | 0% |
| LABORATORY SUPPORT | 0 | 0% |
| LECTURE + CLASSROOM | 0 | 0% |
| OFFICE + ADMINISTRATION | 23,877 | 100% |
| OTHER | 0 | 0% |



SPACE IN PHASE 3

| | QTY | NSF | | |
|-----------------------------|-----|-------|---|---------|
| CIVIL ENGINEERING | | 3,312 | ELECTRICAL ENGINEERING/COMPUTER SCIENCE | 8,035 |
| Department Chair Civil E | 1 | 170 | Department Chair Office | 1 170 |
| Faculty Office | 12 | 1440 | Faculty Office | 30 3600 |
| CE Reception Area | 1 | 203 | EE&CS Reception Area | 1 270 |
| Conference Room | 1 | 183 | Conference Space | 1 183 |
| Mail Room | 1 | 36 | Copy Room | 1 120 |
| Grad Students / PhD Offices | 16 | 1280 | GTA Office | 1 319 |
| CHEMICAL ENGINEERING | | 6,766 | Grad Students / PhD Offices | 40 3200 |
| Department Chair Chem E | 1 | 170 | Storage | 1 173 |
| Faculty Office | 11 | 1320 | MECHANICAL ENGINEERING | 5,764 |
| Department Office | 1 | 499 | ME Department Chair | 1 170 |
| Conference Room | 1 | 144 | Faculty Offices | 20 2400 |
| Mail Room | 1 | 101 | Lab Manager's Office | 1 120 |
| Grad Students / PhD Offices | 48 | 3840 | ME Department Office | 1 258 |
| Break Room | 1 | 161 | ME Conference Room | 1 256 |
| Student Lounge | 1 | 531 | Grad Students / PhD Offices | 32 2560 |

TOTALS

23,877

MECHANICAL NARRATIVE

SITE EQUIPMENT AND UTILITIES

The existing steam, steam condensate, water, sanitary sewer, storm sewer, and natural gas piping services will be re-used during the renovation. All primary equipment will be replaced during the renovation.

AIR HANDLING SYSTEMS

The existing AHUs in Upson II will be replaced with new recirculating AHUs. Each AHU will operate in a variable air volume (VAV) mode to minimize energy use. To the extent possible, all AHUs will be located in the existing penthouse.

The components of each recirculating AHU will be as follows (listed in direction of airflow):

| COMPONENT | COMMENTS |
|-------------------------------|--|
| Return fan(s) | Fan array with VFD |
| Return/relief mixing box | Low-leak dampers |
| Return/outside air mixing box | Low-leak dampers, 100% economizer capabilities, airflow measurement on outside air |
| Prefilter bank | MERV 8, 2" plated filters |
| Final filter bank | MERV 14, 12" cartridge |
| Preheat coil bank | Heating water coil |
| Supply fan(s) | Fan array with VFD |
| Cooling coil bank | Chilled water coil |
| Sound attenuator | 36" sound attenuating section |
| Discharge dampers | Low-leak dampers |

Outside air will be introduced to each of the AHUs via louvers in the mechanical room side wall. Relief air will be discharged through louvers or roof hoods.

All AHUs will have double-wall construction, access doors at each coil and filter section, and internal lights for ease of maintenance. Vibration isolation (internal and/or external) will be provided to minimize noise and vibration transmission to the occupied spaces below.

EXHAUST SYSTEMS

Roof-mounted centrifugal exhaust fan systems will be installed to provide exhaust for the required facility spaces. Each fan will be variable speed via VFD.

All exhaust discharge from the building will be located as far as feasible from fresh air intakes and from other buildings to help prevent air recirculation into occupied spaces.

AIR DISTRIBUTION SYSTEMS

A variable air volume (VAV) air distribution system will be utilized for all areas. With this system type, each non-laboratory temperature control zone will be served by a supply VAV box with an integral hot water reheat coil. The VAV box will modulate its damper position to maintain the required airflow as system pressure fluctuates. A heating water 2-way control valve will modulate water flow to the reheat coil to maintain desired zone temperature conditions. Supply air ductwork will generally be galvanized steel construction.

The exhaust system will operate in a VAV mode similar to the supply air system. Each temperature control zone will be served by an exhaust VAV box. The airflow of the exhaust VAV box will "track" the airflow of the corresponding zone supply VAV box to guarantee proper space pressurization is maintained. Exhaust air ductwork will generally be galvanized steel construction.

The return air system for the recirculating AHUs will generally consist of transfer ducts and return air plenum. Return air airflow-measuring dampers will be used near the return air duct main to control the air volume for each floor.

Room occupancy sensors will be used to reduce the airflow to the spaces during unoccupied hours.

STANDALONE HEATING/COOLING SYSTEMS

In order to minimize the size of the AHUs, standalone units will be provided to supply dedicated heating and cooling to specialized spaces. Electrical rooms, mechanical rooms, telecom closets, and other similar cooling-only zones will be served by chilled water fan coil units (FCUs) or refrigerant-based split systems. Dock areas will be served by heating water unit heaters (UHs). Stairs and vestibules will be served by 2-pipe or 4-pipe FCUs.

CHILLED WATER SYSTEM

The existing rooftop air-cooled chillers, pumps, and accessories will be re-used to serve the renovated building. Piping will be modified as necessary to accommodate new AHUs and other coils.

All new coil loads will be provided with pressure-independent 2-way control valves.

STEAM AND CONDENSATE SYSTEM

The existing low-pressure steam and condensate piping will be re-used. Building equipment will be upgraded, however.

New steam-to-hot water heat exchangers will be provided to generate heating water. A new condensate pump serving the building will be provided to return condensate to the campus system.

HEATING WATER SYSTEM

The new steam-to-hot water heat exchangers will generate heating water. New heating water pumps will be provided

to circulate heating water to all required AHU, terminal unit, and perimeter heating loads. Pumps will be controlled via VFD to modulate pump speed for energy savings.

Panel radiators will be provided to serve perimeter zones with large expanses of glazing. All new loads will be provided with pressure-independent 2-way control valves.

BUILDING AUTOMATION SYSTEM (BAS)

The building addition will utilize direct digital controls (DDC). The BAS will have the capability to adjust setpoints and system operation to match changing facility functions. All controls items will be integrated into the existing University controls infrastructure.

WATER SYSTEMS

The existing water service to the building will be re-used. Backflow preventers and other primary equipment will be replaced. Additionally, existing piping will be replaced to the extent possible during renovation.

A new semi-instantaneous steam-fed water heaters will be installed in the mechanical room to serve the domestic hot water system. Recirculating pumps and piping will be installed to ensure continuous hot water supply at each point of use.

A new water softener will be provided to reduce the hardness of all water feeding the water heaters and other required equipment.

Temperature mixing valves will be provided to serve any emergency fixtures (eye washes or emergency showers) in compliance with ANSI standards.

DRAIN, WASTE, AND VENT

The existing sanitary waste piping to the building will be re-used. Existing waste and vent piping will be replaced to the extent possible during renovation.

STORM WATER SYSTEMS

The existing storm water piping to the building will be re-used. Existing primary and overflow storm piping will be replaced to the extent possible during renovation.

NATURAL GAS SYSTEM

The existing natural gas piping to the building will be re-used. Piping will be replaced to the extent possible during renovation.

FIRE PROTECTION

A new fire service will be installed to provide full coverage to all areas. Hazard classifications will be based on applicable NFPA 13 requirements for each space type.

New fire protection standpipes and hose connections will be installed in all egress stairs.

All work will comply with NFPA 13, NFPA 14, NFPA 24, and other local requirements.

Code-required fire dampers, smoke dampers, and fire/smoke dampers will be installed throughout the building as necessary.

ELECTRICAL NARRATIVE

ELECTRICAL DISTRIBUTION SYSTEM

When possible, existing panelboard will be replaced, however, it is anticipated that new distribution panels and branch panels will be required to support the areas of renovation. Lighting throughout the building will be replaced, and served at 277 volts, single phase. Laboratory, office, and computer equipment, as well as general-purpose receptacle circuits will be served at 120 volts, single phase. All other equipment and devices will be served by the appropriate distribution system voltage

Additional electrical distribution system details include the following:

- Distribution system switchboards and panelboards will make use of circuit breakers for overcurrent protection of feeders and branch circuits.
- Copper bussing will be provided for all electrical distribution system equipment.
- Digital customer metering equipment will be provided as determined by consultation with University facilities personnel. Digital metering devices will be connected to the building energy management control system to allow for remote monitoring.
- Separate panelboards will be used to support facility lighting and general-purpose electrical requirements.
- Surge Protection Devices (SPD) will be provided for all new Life Safety distribution equipment

LIGHTING SYSTEMS

Lighting systems throughout the building will be replaced, and designed in accordance with University design guidelines, IES recommendations and applicable energy codes. Lighting power densities will be minimized by using highly efficient fixtures throughout the areas of renovation. Occupancy/vacancy sensors will be used throughout most spaces to provide automatic off of lighting loads during unoccupied times. In addition, where daylighting opportunities and requirements exist, the use of daylighting controlled lighting systems will be utilized. In general, lighting systems will be as follows:

- For classrooms it is critical to provide appropriate illumination levels on bench tops, to minimize the impact of shadows created by equipment, casework and personnel.. In addition, it is imperative that labs be provided with lighting fixtures that can withstand environmental conditions in each space. In areas with ceilings, high efficient, recessed linear, LED fixtures will be installed over the edge of the bench tops. This type of lighting provides adequate levels of illumination on bench tops, helps to minimize issues associated with glare and shadowing, while still providing illumination of vertical surfaces.
- All fixtures in office areas will be equipped with dimming to provide a variety of light levels. Normal power fixtures in laboratories will be enabled by occupancy/vacancy sensors, and controlled locally within each space.
- Lighting in corridors will be provided by recessed, high efficient, LED fixtures. A portion of these fixtures will be connected to the emergency generator system to provide Code required emergency egress lighting and night lighting. All normal lighting fixtures will be connected to a lighting control system so they are turned off when the building is normally unoccupied.

RECEPTACLE LAYOUTS



Receptacle layouts and circuiting to support computer equipment, classroom equipment, office equipment, telecommunications equipment and general purpose needs will be provided in accordance with direction provided by building users and campus personnel.

PHASE 4

RENOVATIONS

PHASE SUMMARY

Phase 4 will ultimately be broken up into smaller areas of work over several years to renovate targeted portions of the remainder of Harrington and Leonard Halls. It is anticipated that the work on Harrington Hall would include upgrades to mechanical and electrical systems as well as new lighting and a general refresh. It is not anticipated that major realignment of walls or spaces would be needed. The work in Leonard Hall will be more invasive and involve a multi-phase approach to renovating the individual floors to realign the main north/south corridors in the building. This realignment will provide the opportunity to enlarge research and instructional spaces on the west side of the corridor while creating right sized spaces for faculty offices and support spaces on the east. The Leonard Hall renovations will also include the addition of a high-density storage area in the basement to create a more compact system for storing the large volume of geological and paleontology specimens for the Geology and Geological Engineering department.



SPACE IN PHASE 4

| | QTY | NSF | | QTY | NSF |
|--|-----|---------------|--|-----|---------------|
| PETROLEUM ENGINEERING | | 7,410 | Faculty Office | 10 | 1,200 |
| Department Chair Office | 1 | 170 | Visiting Faculty Office | 1 | 120 |
| Faculty Office | 10 | 1200 | Staff / Administrative Offices | 1 | 564 |
| Visiting Faculty Office | 2 | 240 | Staff / Administrative Offices | 1 | 286 |
| Staff / Administrative Offices | 10 | 1,000 | Staff / Administrative Offices | 1 | 143 |
| PhD Open Office | 60 | 4,800 | Conference Room | 1 | 446 |
| GEOLOGY AND GEOLOGICAL ENGINEERING | | 28,559 | Lab Director Office | 1 | 120 |
| Instruct / Res. Lab - Environmental Eng. | 1 | 304 | Faculty Lounge | 1 | 269 |
| Instruct / Res. Lab - Geomorphology | 1 | 1,289 | FD Holland Jr. Library - Dir. Office | 1 | 174 |
| Instruct / Res. Lab - Geo Engineering | 1 | 274 | Grad Students / PhD Offices | 36 | 2,880 |
| Instruct / Res. Lab - Hydrology | 1 | 274 | Emeritus Faculty | 1 | 120 |
| Geology Computer Laboratory | 1 | 849 | Student Study Area | 1 | 554 |
| Mineralogy Teaching Laboratory | 1 | 921 | Storage / Library | 1 | 233 |
| Instruct / Res. Lab - Microscopy | 1 | 875 | Geo Break Area | 1 | 274 |
| Sedimentology Instructional Laboratory | 1 | 1,452 | FD Holland Jr. Geo Library | 1 | 1,793 |
| Computer Teaching Laboratory | 1 | 281 | FD Holland Jr. Library - Workroom | 1 | 199 |
| Research Lab - Geo Eng. | 1 | 608 | FD Holland Jr. Geo Library - Mezzanine - 1 | 1 | 1,297 |
| Geochemistry Research Laboratory | 1 | 809 | FD Holland Jr. Geo Library - Mezzanine - 2 | 1 | 315 |
| Mineralogy Research Laboratory | 1 | 595 | FD Holland Jr. Geo Library - Map Room - 1 | 1 | 848 |
| Paleontolgy Research & Teaching Laboratory | 1 | 1,123 | FD Holland Jr. Geo Library - Map Room - 2 | 1 | 503 |
| Geo Research Laboratory | 1 | 280 | CIVIL ENGINEERING | | 10,116 |
| Geo EARL Laboratory (Chem) | 1 | 459 | Concrete and Asphalt Laboratory | 1 | 3,130 |
| Geo EARL Laboratory | 1 | 243 | Steel and Concrete Laboratory | 1 | 3,342 |
| Geo EARL Laboratory (office) | 1 | 178 | Basement Storage | 1 | 370 |
| Research Laboratory | 1 | 230 | Basement Storage | 1 | 370 |
| Geo Research Laboratory | 1 | 248 | Basement Pump Room | 1 | 380 |
| Geology 101 Prep Lab | 1 | 363 | Equipment Storage | 1 | 141 |
| Field Equipment Storage | 1 | 611 | Surveying Equipment | 1 | 155 |
| Storage / Shop | 1 | 216 | Asphalt Binding Room | 1 | 261 |
| Rock Prep | 1 | 258 | Water Sampling Equipment | 1 | 41 |
| Rock Prep Storage | 1 | 37 | Curing Room | 1 | 103 |
| Hydrology Equipment | 1 | 142 | Equipment Room | 1 | 101 |
| Rock Saw Room | 1 | 301 | Storage Room | 1 | 156 |
| Geology Sample Recovery | 1 | 300 | Storage Room | 1 | 101 |
| Geology Field Gear & Collections | 1 | 617 | Mezzanine | 1 | 689 |
| Prep Lab? | 1 | 151 | Lab Storage | 1 | 90 |
| Prep Lab? | 1 | 118 | Lab Storage | 1 | 104 |
| Dark Room | 1 | 113 | Prep Lab | 1 | 77 |
| High Density Specimen Storage | 1 | 1,320 | CE Commons / Student Groups | 1 | 505 |
| Instructional Recording Studio | 1 | 212 | CHEMICAL ENGINEERING | | 2,241 |
| Department Chair Office | 1 | 170 | Computational Laboratory | 1 | 800 |

| | | |
|--|----|--------|
| Pilot Scale Systems Research | 1 | 383 |
| Hoffman Energetics Laboratory | 1 | 107 |
| Electrolysis Laboratory | 1 | 120 |
| Storage | 1 | 42 |
| Storage | 1 | 236 |
| Storage | 1 | 238 |
| Unused | 1 | 140 |
| Unused | 1 | 175 |
| ELECTRICAL ENGINEERING & COMPUTER SCIENCE | | 4,312 |
| EE&CS Embedded Systems Teaching Lab | 1 | 572 |
| EE&CS Research Laboratory | 1 | 461 |
| Power and Energy Research Laboratory | 1 | 734 |
| EE&CS Research Laboratory | 1 | 333 |
| EE&CS Research Laboratory | 1 | 391 |
| EE&CS Research Laboratory | 1 | 726 |
| EE&CS Research Laboratory | 1 | 153 |
| EE&CS Research Laboratory | 1 | 177 |
| EE & CS Computer Laboratory | 1 | 442 |
| Senior Design Lab | 1 | 323 |
| INSTITUTE FOR ENGINEERING STUDIES | | 3,489 |
| IES High Bay Equip. Test Laboratory (Mezz) | 1 | 1,089 |
| IES Instructor's Office | 1 | 120 |
| IES Grant Writer's Office | 1 | 120 |
| IES Staff Office | 18 | 2,160 |
| MECHANICAL ENGINEERING | | 21,065 |
| ME Computational Laboratory | 1 | 510 |
| ME Instructional Machine Shop exg | 1 | 1,568 |
| ME Recording Room | 1 | 102 |
| ME Research Laboratory (hi-temp/manuf) | 1 | 1,310 |
| ME Faculty Research Laboratory | 1 | 2,015 |
| ME Freshman Projects | 1 | 726 |
| Laser Laboratory | 1 | 660 |
| ME Undergraduate Robotics Lab | 1 | 366 |
| ME Faculty Research Laboratory | 1 | 260 |
| ME Formula Car Cage | 1 | 1,110 |
| ME Student Projects Research Laboratory | 1 | 1,741 |
| ME Faculty Research Laboratory | 1 | 360 |
| ME Machine Shop exg | 1 | 1,911 |
| Machine Vision Laboratory | 1 | 357 |
| Machine Vision Laboratory | 1 | 105 |
| Mechanical Testing Laboratory | 1 | 667 |
| ME Faculty Research Laboratory | 1 | 368 |
| Senior Design Lab | 1 | 323 |

| | | |
|---|---|--------|
| ME Faculty Research Laboratory | 1 | 220 |
| ME Faculty Research Laboratory | 1 | 381 |
| Chemical Storage | 1 | 108 |
| Electrical Equipment | 1 | 135 |
| Machining Shop | 1 | 135 |
| Storage | 1 | 370 |
| Storage | 1 | 370 |
| ME 3D Printing | 1 | 207 |
| ME High Bay Support | 1 | 246 |
| Welding Shop | 1 | 1,980 |
| Welding Supply | 1 | 126 |
| ME Foundry | 1 | 332 |
| Storage | 1 | 139 |
| Storage | 1 | 181 |
| ME Foundry Support | 1 | 71 |
| Storage | 1 | 187 |
| Secure Storage | 1 | 150 |
| ME Wood Shop | 1 | 479 |
| ME Vibration Equipment Cage | 1 | 395 |
| ME 3D Printing | 1 | 394 |
| COLLEGE OF ENGINEERING | | 21,994 |
| Mezzanine Teaching Laboratory? | 1 | 1,153 |
| Core Imaging Laboratory | 1 | 1,029 |
| Undergraduate Computer Laboratory | 1 | 760 |
| Mezzanine Research Laboratory | 1 | 726 |
| CEM Computer Laboratory | 1 | 839 |
| CEM Computer Lab Support | 1 | 104 |
| Imaging Prep Laboratory | 1 | 197 |
| Executive Training Room | 1 | 617 |
| Multi-Purpose Classroom | 1 | 732 |
| Multi-Purpose Classroom | 1 | 737 |
| General Classroom (COE) | 1 | 303 |
| COE Admin. - Reception | 1 | 722 |
| COE Admin. - Deans Office | 1 | 401 |
| COE Admin. - Assistants Office | 1 | 110 |
| COE Admin - Business Officer Office | 1 | 143 |
| COE- Admin Office | 1 | 177 |
| COE Dean's Conference Room | 1 | 358 |
| COE Admin - Support Specialist Office | 1 | 558 |
| COE Admin Office | 1 | 102 |
| COE Admin Office | 1 | 102 |
| COE Admin - Online Program Coord. Office | 1 | 111 |
| COE Admin - Online Program Support Office | 1 | 103 |

| | | |
|--|---|--------|
| COE Admin Office | 1 | 103 |
| COE Admin - Copy Room | 1 | 251 |
| COE Admin Office | 1 | 113 |
| COE Admin Office | 1 | 114 |
| COE Admin Grant Manager's Office | 1 | 164 |
| COE Admin. Grant Manager's Office | 1 | 107 |
| COE Admin. - Undergrad Program Coord. Office | 1 | 119 |
| COE Admin. - Grad Program Coord. Office | 1 | 109 |
| COE Admin. - Linux Administrators Office | 1 | 152 |
| COE Admin. -IT Coord. Office | 1 | 98 |
| Office - IT? | 1 | 107 |
| Office - IT? | 1 | 109 |
| COE Storage | 1 | 109 |
| COE Copy Room | 1 | 143 |
| Conference Room | 1 | 405 |
| AE2S Board Room | 1 | 810 |
| AE2S BR Storage | 1 | 54 |
| AE2S BR Coats | 1 | 51 |
| Reception Area (ME; EE&CS) | 1 | 203 |
| Jodsaas Center Lobby | 1 | 878 |
| Jodsaas Center Admin Office | 1 | 136 |
| Jodsaas Center Admin Office | 1 | 167 |
| Jodsaas Center Admin Office | 1 | 181 |
| Jodsaas Center Admin Office | 1 | 250 |
| Jodsaas Center Conference Room | 1 | 754 |
| Student Organization Office / Storage | 1 | 242 |
| Solberg Student Success Center | 1 | 209 |
| Kitchenette | 1 | 62 |
| Lounge - Kitchenette | 1 | 230 |
| Faculty Lounge | 1 | 390 |
| Student Lounge | 1 | 264 |
| 1st Floor Lobby / Museum (Leonard Hall) | 1 | 2,577 |
| Storage | 1 | 42 |
| Vending | 1 | 134 |
| Storage | 1 | 236 |
| Closet | 1 | 35 |
| Instructional Services Office? | 1 | 191 |
| COE Hall of Fame | 1 | 393 |
| Open Lounge | 1 | 350 |
| Student Study Space | 1 | 695 |
| Unknown | 1 | 173 |
| REGISTRAR | | 13,387 |
| Shared Teaching Laboratory / Classroom | 1 | 847 |

| | | |
|--|---|---------|
| Shared Teaching Laboratory / Classroom | 1 | 561 |
| Shared Teaching Laboratory / Classroom | 1 | 1,069 |
| Lecture Hall | 1 | 2,500 |
| Classroom | 1 | 608 |
| Classroom | 1 | 1,681 |
| Classroom | 1 | 646 |
| Classroom | 1 | 918 |
| Classroom (Interactive) | 1 | 925 |
| Classroom | 1 | 949 |
| Classroom (Interactive) | 1 | 1,026 |
| Classroom | 1 | 462 |
| Classroom | 1 | 1,145 |
| Projection Booth | 1 | 50 |
| TOTALS | | 112,573 |

MECHANICAL NARRATIVE

SITE EQUIPMENT AND UTILITIES

The existing steam, steam condensate, water, sanitary sewer, storm sewer, and natural gas piping services will be re-used during the renovation. All primary equipment will be replaced during the renovation.

AIR HANDLING SYSTEMS

The Harrington Hall renovation will be served by two different types of air handling units (AHUs) located in the Phase 2 penthouse. The existing AHU in Upson II will be removed. In general, laboratory spaces will be served by 100% outside air (OA) AHUs, while non-laboratory spaces will be served by recirculating AHUs. Each AHU will operate in a variable air volume (VAV) mode to minimize energy use.

The components of each 100% AHU will be as follows (listed in direction of airflow):

| COMPONENT | COMMENTS |
|-------------------------|--|
| Outside air dampers | Low-leak dampers, airflow measurement |
| Prefilter bank | MERV 8, 2" plated filters |
| Final filter bank | MERV 14, 12" cartridge |
| Heat recovery coil bank | Runaround water coil, glycol for freeze protection |
| Preheat coil bank | Heating water coil |
| Supply fan(s) | Fan array with VFD |
| Humidifier grid | Steam dispersion grid |
| Cooling coil bank | Chilled water coil |
| Sound attenuator | 36" sound attenuating section |
| Discharge dampers | Low-leak dampers |

The components of each recirculating AHU will be as follows (listed in direction of airflow):

| COMPONENT | COMMENTS |
|-------------------------------|--|
| Return fan(s) | Fan array with VFD |
| Return/relief mixing box | Low-leak dampers |
| Return/outside air mixing box | Low-leak dampers, 100% economizer capabilities, airflow measurement on outside air |
| Prefilter bank | MERV 8, 2" plated filters |
| Final filter bank | MERV 14, 12" cartridge |
| Preheat coil bank | Heating water coil |

| COMPONENT | COMMENTS |
|-------------------|-------------------------------|
| Supply fan(s) | Fan array with VFD |
| Cooling coil bank | Chilled water coil |
| Sound attenuator | 36" sound attenuating section |
| Discharge dampers | Low-leak dampers |

Outside air will be introduced to each of the AHUs via louvers in the mechanical room side wall. Relief air will be discharged through louvers or roof hoods.

All AHUs will have double-wall construction, access doors at each coil and filter section, and internal lights for ease of maintenance. Vibration isolation (internal and/or external) will be provided to minimize noise and vibration transmission to the occupied spaces below.

EXHAUST SYSTEMS

The Harrington Hall renovation will be served by the high-plume mixed-flow exhaust fan systems installed on the Phase 2 roof.

All exhaust discharge from the building will be located as far as feasible from fresh air intakes and from other buildings to help prevent air recirculation into occupied spaces.

AIR DISTRIBUTION SYSTEMS

The existing duct systems will be replaced during the renovation. A variable air volume (VAV) air distribution system will be utilized for all areas. With this system type, each non-laboratory temperature control zone will be served by a supply VAV box with an integral hot water reheat coil, while each laboratory temperature control zone will be served by a high-speed venturi air valve and hot water reheat coil. The VAV box/air valve will modulate its damper position to maintain the required airflow as system pressure fluctuates. A heating water 2-way control valve will modulate water flow to the reheat coil to maintain desired zone temperature conditions. Supply air ductwork will generally be galvanized steel construction.

The exhaust system will operate in a VAV mode similar to the supply air system. Each temperature control zone will be served by an exhaust VAV box or air valve. In non-laboratory zones, the airflow of the exhaust VAV box will "track" the airflow of the corresponding zone supply VAV box to guarantee proper space pressurization is maintained. In laboratory zones, a fume hood air valve will be used to provide proper fume hood face velocity and a general exhaust air valve will modulate to provide proper room pressurization and minimum ventilation rates. All exhaust air will be routed using common ductwork to the high-plume exhaust fans. Exhaust air ductwork will generally be galvanized steel construction; however, all ductwork downstream of fume hoods, canopy hoods, snorkel hoods, or other specialized equipment will be stainless steel construction.

The return air system for the recirculating AHUs will generally consist of transfer ducts and return air plenum. Return air airflow-measuring dampers will be used near the return air duct main to control the air volume for each floor.

Room occupancy sensors will be used to reduce the airflow to the spaces during unoccupied hours. In laboratory areas, the airflow will be reduced, but will still be sufficient to maintain minimum code-required ventilation rates.

STANDALONE HEATING/COOLING SYSTEMS

In order to minimize the size of the AHUs, standalone units will be provided to supply dedicated heating and cooling to specialized spaces. Electrical rooms, mechanical rooms, telecom closets, and other similar cooling-only zones will be served by chilled water fan coil units (FCUs) or refrigerant-based split systems. Dock areas will be served by heating water unit heaters (UHs). Stairs and vestibules will be served by 2-pipe or 4-pipe FCUs.

CHILLED WATER SYSTEM

The Phase 2 chillers, pumps, and accessories will be re-used to serve the renovated building. Piping will be modified as necessary to accommodate new AHUs and other coils.

All new coil loads will be provided with pressure-independent 2-way control valves.

STEAM AND CONDENSATE SYSTEM

The existing low-pressure steam and condensate piping will be re-used. Building equipment will be upgraded, however.

New steam-to-hot water heat exchangers will be provided to generate heating water. A new condensate pump serving the building will be provided to return condensate to the campus system.

HEATING WATER SYSTEM

The new steam-to-hot water heat exchangers will generate heating water. New heating water pumps will be provided to circulate heating water to all required AHU, terminal unit, and perimeter heating loads. Pumps will be controlled via VFD to modulate pump speed for energy savings.

Panel radiators will be provided to serve perimeter zones with large expanses of glazing. All new loads will be provided with pressure-independent 2-way control valves.

BUILDING AUTOMATION SYSTEM (BAS)

The building addition will utilize direct digital controls (DDC). The BAS will have the capability to adjust setpoints and system operation to match changing facility functions. All controls items will be integrated into the existing University controls infrastructure.

WATER SYSTEMS

The existing water service to the building will be re-used. Backflow preventers and other primary equipment will

be replaced. Additional backflow preventers will be used to create a laboratory cold water system for use in the lab spaces. Additionally, existing piping will be replaced to the extent possible during renovation.

Two new semi-instantaneous steam-fed water heaters will be installed in the mechanical penthouse (one domestic, one laboratory) to support their respective fixtures. Recirculating pumps and piping will be installed on each hot water system to ensure continuous hot water supply at each point of use.

A water softener will be provided to reduce the hardness of all water feeding the water heaters, pure water equipment, and certain laboratory equipment. Additionally, soft water will be piped as necessary to any required laboratory areas.

Temperature mixing valves will be provided to serve any emergency fixtures (eye washes or emergency showers) in compliance with ANSI standards.

PURE WATER SYSTEMS

If required for laboratory uses, high purity water will be generated by a single water purification skid. The equipment will include carbon filters, reverse osmosis (RO) equipment, deionization (DI) tanks, ultraviolet (UV) sterilizer, 0.2-micron filters, storage and recirculating pump(s) that will continuously circulate the pure water through a polypropylene pipe loop to use points and laboratory equipment throughout the addition. The water quality produced by this system will be equivalent to Type 2 (1 mega-ohm) grade meeting ASTM/ISO 3696 specifications. Point of use polishers will be used for Type 1 lab water needs.

DRAIN, WASTE, AND VENT

The existing sanitary waste piping to the building will be re-used. Existing waste and vent piping will be replaced to the extent possible during renovation. Laboratory waste piping will be limited to piping from a laboratory sink/drain to the nearest main riser and will be comprised of fuse-seal polypropylene pipe and fittings. A dedicated acid neutralization system is not anticipated as chemicals will be collected and disposed of in lieu of dumping them down the sinks.

STORM WATER SYSTEMS

The existing storm water piping to the building will be re-used. Existing primary and overflow storm piping will be replaced to the extent possible during renovation.

NATURAL GAS SYSTEM

The existing natural gas piping to the building will be re-used. Piping will be replaced to the extent possible during renovation.

SPECIALTY GASES

LABORATORY COMPRESSED AIR: A new air compressor will be installed in the penthouse to serve new laboratory equipment. The compressor will be a dual oil free scroll tank mount type and installed on top of a 4" high concrete equipment pad with vibration isolators. The system will include a refrigerated air dryer (37.4 deg F dewpoint) and inline filters to provide clean, dry air suitable for laboratory grade use. Piping and fittings will be high purity copper suitable for laboratory use. A master pressure reducing valve will be installed in the penthouse to regulate the system delivery pressure to 125 psig.

CYLINDER GASES: The need and quantity of cylinder gases will be determined during subsequent design phases. Where centralized and stored within a dedicated cylinder closet, gas manifolds with auto-changeover capabilities will be installed and high purity copper suitable for laboratory use will be routed to all use points and equipment.

LABORATORY VACUUM: A new centralized laboratory vacuum pump system will be installed in the penthouse. The pump will be a multi-plex unit with receiver installed on top of a 4" high concrete equipment pad with vibration isolators. The system will be size to maintain a vacuum of 19 inches of mercury at the farthest terminal at peak demand based on 0.5 scfm demand at each terminal. Piping/fittings will be high purity copper suitable for laboratory use.

FIRE PROTECTION

A new fire service will be installed to provide full coverage to all areas. Hazard classifications will be based on applicable NFPA 13 requirements for each space type.

New fire protection standpipes and hose connections will be installed in all egress stairs.

All work will comply with NFPA 13, NFPA 14, NFPA 24, and other local requirements.

Code-required fire dampers, smoke dampers, and fire/smoke dampers will be installed throughout the building as necessary.

ELECTRICAL NARRATIVE

ELECTRICAL DISTRIBUTION SYSTEM

The main electrical services for Harrington and Leonard Halls will remain, with modifications only taking place to remedy code issues and replace equipment that is no longer functional. New panels will be required to support some areas of renovation, however, when possible existing branch panelboards will be repurposed.

LIGHTING SYSTEMS

Lighting systems throughout both buildings will be replaced. The new lighting systems will be designed in accordance with University design guidelines, IES recommendations and applicable energy codes. Lighting power densities will be minimized by using highly efficient fixtures throughout the areas of renovation. Occupancy/vacancy sensors will be used throughout most spaces to provide automatic off of lighting loads during unoccupied times. In addition, where daylighting opportunities and requirements exist, the use of daylighting controlled lighting systems will be utilized. In general, lighting systems will be as follows:

- For laboratories/classrooms it is critical to provide appropriate illumination levels on bench tops, to minimize the impact of shadows created by equipment, casework and personnel.. In addition, it is imperative that labs be provided with lighting fixtures that can withstand environmental conditions in each space. In areas with ceilings, high efficient, recessed linear, LED fixtures will be installed over the edge of the bench tops. This type of lighting provides adequate levels of illumination on bench tops, helps to minimize issues associated with glare and shadowing, while still providing illumination of vertical surfaces.
- All fixtures in laboratories with no ceiling will be linear pendant, high efficient LED fixtures. A portion of the light distribution of these fixtures will be indirect in order to increase the quality of light by providing even, diffuse light levels.
- All fixtures in laboratory areas will be equipped with dimming to provide a variety of light levels. Normal power fixtures in laboratories will be enabled by occupancy/vacancy sensors, and controlled locally within each space. A portion of the lighting in all laboratories will be connected to the emergency generator system.
- In chemical storage areas or laboratories that make use of a significant amount of chemicals, the most prudent approach to lighting is 1'x 4' recessed lensed LED troffers. This type of illumination reduces shadowing and provides adequate illumination levels. Normal fixtures in these spaces will be enabled by occupancy/vacancy sensors, and controlled locally within each space. A portion of the lighting in all areas with high chemical usage will be connected to the emergency generator system.
- Lighting in corridors will be provided by recessed, high efficient, LED fixtures. A portion of these fixtures will be connected to the emergency generator system to provide Code required emergency egress lighting and night lighting. All normal lighting fixtures will be connected to a lighting control system so they are turned off when the building is normally unoccupied.


RECEPTACLE LAYOUTS

In areas of renovation, receptacle layouts and circuiting to support computer equipment, classroom equipment, laboratory equipment, telecommunications equipment and general purpose needs will be provided in accordance with direction provided by building users and campus personnel.

Two channel surface metal raceway systems will be provided above benches in laboratories to support the distribution of power, telecommunications and instrumentation cabling to computer and laboratory equipment. Duplex receptacles will be installed in surface metal raceway systems at intervals dictated by building users. Receptacles in raceway systems will be connected to 20-amp branch circuits unless further direction has been provided by a specific user.

In equipment alcoves and shared equipment or instrumentation spaces wall mounted busway will be utilized. The busway will provide quick plug-and-play power re-configuration to accommodate equipment changes. Busway will be rated at 208Y/120V, 3 phase, 4-wire with amperage ratings that vary depending on length. Standard busway receptacle/circuit breaker combination units will be coordinated with existing equipment and Campus personnel.

All electrical devices in laboratories will be labeled with the panel source and circuit number. Dedicated receptacles and circuits will be provided as required to support specific equipment locations throughout the facility. All receptacle branch circuits will be provided with equipment ground conductors. All branch circuit wiring will be copper and will be installed in concealed raceway systems. Ground fault interrupting type receptacles will be provided in all Code required locations, and in all designated "wet" locations throughout the facility.



LOWER LEVEL

DEPARTMENT BREAKOUT LEGEND

- | | | |
|---|--|--|
| ■ CHEMICAL ENGINEERING | ■ CIVIL ENGINEERING | ■ BIOMEDICAL ENGINEERING |
| ■ ELECTRICAL ENGINEERING + COMPUTER SCIENCE | ■ COLLEGE OF ENGINEERING + MINES | ■ INSTITUTE OF ENERGY STUDIES |
| ■ GEOLOGY + GEOLOGICAL ENGINEERING | ■ PETROLEUM ENGINEERING | ■ BUILDING SUPPORT |
| ■ MECHANICAL ENGINEERING | ■ REGISTRAR | ■ CIRCULATION |



FIRST FLOOR

DEPARTMENT BREAKOUT LEGEND

- CHEMICAL ENGINEERING
- ELECTRICAL ENGINEERING + COMPUTER SCIENCE
- GEOLOGY + GEOLOGICAL ENGINEERING
- MECHANICAL ENGINEERING
- CIVIL ENGINEERING
- COLLEGE OF ENGINEERING + MINES
- PETROLEUM ENGINEERING
- REGISTRAR
- BIOMEDICAL ENGINEERING
- INSTITUTE OF ENERGY STUDIES
- BUILDING SUPPORT
- CIRCULATION



SECOND FLOOR

DEPARTMENT BREAKOUT LEGEND

- CHEMICAL ENGINEERING
- ELECTRICAL ENGINEERING + COMPUTER SCIENCE
- GEOLOGY + GEOLOGICAL ENGINEERING
- MECHANICAL ENGINEERING
- CIVIL ENGINEERING
- COLLEGE OF ENGINEERING + MINES
- PETROLEUM ENGINEERING
- REGISTRAR
- BIOMEDICAL ENGINEERING
- INSTITUTE OF ENERGY STUDIES
- BUILDING SUPPORT
- CIRCULATION



THIRD FLOOR

DEPARTMENT BREAKOUT LEGEND

- CHEMICAL ENGINEERING
- ELECTRICAL ENGINEERING + COMPUTER SCIENCE
- GEOLOGY + GEOLOGICAL ENGINEERING
- MECHANICAL ENGINEERING
- CIVIL ENGINEERING
- COLLEGE OF ENGINEERING + MINES
- PETROLEUM ENGINEERING
- REGISTRAR
- BIOMEDICAL ENGINEERING
- INSTITUTE OF ENERGY STUDIES
- BUILDING SUPPORT
- CIRCULATION

OPINIONS OF PROBABLE COST

TOTALS

The preliminary costs shown below are for construction and demolition, only in 2021 dollars. No additional funds for escalation, soft costs, fees, design, furnishings or additional site costs have been included.

| | |
|--------------------------|--------------|
| Net Square Feet | 190,941 |
| Gross Square Feet | 334,984 |
| Totals Construction Cost | \$95,886,491 |

BREAKDOWN PER DEPARTMENT

The preliminary costs shown below are for construction and demolition, only in 2021 dollars. No additional funds for escalation, soft costs, fees, design, furnishings or additional site costs have been included.

| DEPARTMENT | PHASE 1 | | | PHASE 2 | | |
|---|---------|--------|--------------|---------|--------|--------------|
| | NSF | GSF | COST | NSF | GSF | COST |
| Petroleum Engineering | 2,178 | 3,821 | \$2,006,053 | 3,630 | 6,368 | \$3,025,000 |
| Geology & Geological Engineering | 0 | 0 | \$0 | 0 | 0 | \$0 |
| Civil Engineering | 0 | 0 | \$0 | 9,112 | 15,986 | \$7,505,614 |
| Chemical Engineering | 7,864 | 13,796 | \$6,585,482 | 4,840 | 8,491 | \$4,404,825 |
| Electrical Engineering & Computer Science | 2,387 | 4,188 | \$1,943,333 | 4,719 | 8,279 | \$3,693,684 |
| Institute for Energy Studies | 0 | 0 | \$4,852,719 | 0 | 0 | \$0 |
| Mechanical Engineering | 5,703 | 10,005 | \$0 | 2,904 | 5,095 | \$2,420,000 |
| College of Engineering | 1,452 | 2,547 | \$1,273,684 | 0 | 0 | \$0 |
| Registrar | 0 | 0 | \$0 | 0 | 0 | \$0 |
| Biomedical Engineering | 9,702 | 17,021 | \$7,411,491 | 0 | 0 | \$0 |
| Totals | 29,286 | 51,379 | \$24,072,763 | 25,205 | 44,219 | \$21,049,123 |

| DEPARTMENT | PHASE 3 | | | PHASE 4 | | |
|---|---------|--------|-------------|---------|---------|--------------|
| | NSF | GSF | COST | NSF | GSF | COST |
| Petroleum Engineering | 0 | 0 | \$0 | 7,410 | 13,000 | \$2,644,737 |
| Geology & Geological Engineering | 0 | 0 | \$0 | 28,559 | 50,104 | \$10,839,254 |
| Civil Engineering | 3,312 | 5,811 | \$1,162,105 | 10,116 | 17,747 | \$2,946,096 |
| Chemical Engineering | 6,766 | 11,870 | \$2,374,035 | 2,241 | 3,932 | \$810,746 |
| Electrical Engineering & Computer Science | 8,035 | 14,096 | \$2,796,535 | 4,312 | 7,565 | \$1,134,737 |
| Institute for Energy Studies | 0 | 0 | \$0 | 3,489 | 6,121 | \$1,463,026 |
| Mechanical Engineering | 5,764 | 10,112 | \$2,022,456 | 21,065 | 36,956 | \$8,166,491 |
| College of Engineering | 0 | 0 | \$0 | 21,994 | 38,586 | \$8,315,088 |
| Registrar | 0 | 0 | \$0 | 13,387 | 23,486 | \$6,089,298 |
| Biomedical Engineering | 0 | 0 | \$0 | 0 | 0 | \$0 |
| Totals | 23,877 | 41,889 | \$8,355,132 | 112,573 | 197,496 | \$42,409,474 |

ALTERNATE OPTION

HYSLOP STARCHER SITE

North Dakota State University has been working on a campus masterplan that includes an analysis for the establishment of a STEM building to serve the campus. While several sites have been evaluated, the committee for the College of Engineering masterplan asked the design team to provide a brief overview of the possibilities surrounding using a building site directly to the east of Leonard Hall to accommodate the additional programmatic space needed by the College of Engineering. According to the work on the STEM study completed at the time of this study, the STEM building would occupy the north end of the site and the new development for the college of engineering would occupy the south on a parcel that measures approximately 210 feet north to south and 340 feet east to west. The eastern site is currently occupied by the Hyslop Athletic center and Starcher Hall. Starcher Hall would be demolished and removed in it's entirely and most of Hyslop would be demolished except for the northern most wing of the building.

The committee asked the design team to investigate the eastern site to see how it might accommodate a new engineering building to provide the growth space identified in the program plus all space in Harrington and Upson II (slated for demolition). The eastern site would then need to provide net square footage to replace or provide new, the following major areas identified in the masterplan:


- 1. All new space currently planned for the Phase 1 addition to the west and north of Upson I. (29,286 net square feet)
- 2. All new space currently planned for the Phase 2 demolition and addition to the east side of Harrington Hall. (25,205 net square feet).
- 3. All existing space remaining in Harrington Hall after the implementation of Phase 2. (20,844 net square feet.)
- 4. All existing space in Upson II planned for renovation in Phase 3. (25,196 net square feet).

The total net square footage needed in this scenario is 100,531 net square feet. Assuming a similar net to gross ratio of 57%, a new multi-story engineering addition would need to be built to provide approximately 176,000 gross square feet. Assuming set backs of roughly 40 feet on the eastern site, it is assumed that a maximum footprint of approximately 51,000 gross square feet could be achieved yielding either a three or four-story development plus a penthouse. In addition, the development would also likely include a skywalk from Leonard Hall to the new addition and the demolition of the existing Harrington and Upson II structures. It is assumed that demolition of Hyslop and Starcher would be included in the development of the eastern site in preparation for the construction of the new STEM Building to the north of the proposed engineering annex.


The preliminary costs shown below are for construction and demolition, only in 2021 dollars. No additional funds for escalation, soft costs, fees, design, furnishings or additional site costs have been included.


The preliminary costs shown below are for construction and demolition, only in 2021 dollars. No additional funds for escalation, soft costs, fees, design, furnishings or additional site costs have been included.

| HYSLOP STARCHER SITE | COST |
|--|--------------|
| Construction of new Engineering Annex (\$475 per GSF) | \$83,600,000 |
| Construction of skywalk (144 linear feet at \$10,000 per LF) | \$1,440,000 |
| Demolition of Harrington and Upson II (at \$6 per exg. GSF) | \$650,000 |
| Totals | \$85,690,000 |



■ COE BUILDINGS ■■■ SKYWALKS ■ BUILDING SLATED FOR DEMOLITION






HARRINGTON HALL

DEPARTMENT BREAKOUT LEGEND

- | | | |
|---|----------------------------------|-------------------------------|
| ■ CHEMICAL ENGINEERING | ■ CIVIL ENGINEERING | ■ BIOMEDICAL ENGINEERING |
| ■ ELECTRICAL ENGINEERING + COMPUTER SCIENCE | ■ COLLEGE OF ENGINEERING + MINES | ■ INSTITUTE OF ENERGY STUDIES |
| ■ GEOLOGY + GEOLOGICAL ENGINEERING | ■ PETROLEUM ENGINEERING | ■ BUILDING SUPPORT |
| ■ MECHANICAL ENGINEERING | ■ REGISTRAR | ■ CIRCULATION |







DEPARTMENT BREAKOUT LEGEND


- F.223



COLLABORATIVE ENERGY COMPLEX

DEPARTMENT BREAKOUT LEGEND

- CHEMICAL ENGINEERING
- ELECTRICAL ENGINEERING + COMPUTER SCIENCE
- GEOLOGY + GEOLOGICAL ENGINEERING
- MECHANICAL ENGINEERING
- CIVIL ENGINEERING
- COLLEGE OF ENGINEERING + MINES
- PETROLEUM ENGINEERING
- REGISTRAR
- BIOMEDICAL ENGINEERING
- INSTITUTE OF ENERGY STUDIES
- BUILDING SUPPORT
- CIRCULATION





LEONARD HALL

DEPARTMENT BREAKOUT LEGEND

- | | | |
|---|--------------------------------|-----------------------------|
| CHEMICAL ENGINEERING | CIVIL ENGINEERING | BIOMEDICAL ENGINEERING |
| ELECTRICAL ENGINEERING + COMPUTER SCIENCE | COLLEGE OF ENGINEERING + MINES | INSTITUTE OF ENERGY STUDIES |
| GEOLOGY + GEOLOGICAL ENGINEERING | PETROLEUM ENGINEERING | BUILDING SUPPORT |
| MECHANICAL ENGINEERING | REGISTRAR | CIRCULATION |

DESIGN ITERATION SERIES 01







82,000 SF ADDITION - PLAN
Without Underpass




82,000 SF ADDITION - PLAN
With Underpass



82,000 SF ADDITION - MASSING
Without Underpass



82,000 SF ADDITION - MASSING
Without Underpass




102,000 SF ADDITION - PLAN
Without Underpass



102,000 SF ADDITION - MASSING
Without Underpass





102,000 SF ADDITION - PLAN
With Underpass



102,000 SF ADDITION - MASSING
Without Underpass

DESIGN ITERATION SERIES 02






PHASE 1 - PLAN
2 Story High Bay + 1 Story Classrooms/Laboratories Addition




PHASE 1 - MASSING
Southwest View




PHASE 2 - PLAN
New Entry Link



PHASE 2 - MASSING
Southwest View



PHASE 3 - PLAN
Demo Harrington Hall + Skywalk Connections



PHASE 3 - MASSING
Southwest View




PHASE 3 - MASSING
Northwest View



102,000 SF ADDITION - MASSING
Southwest View

DESIGN ITERATION SERIES 03





PHASE 3 - PLAN

Demo Harrington Hall + Skywalk Connections




PHASE 3 - MASSING

Southwest View




PHASE 3 - MASSING

Northwest View




102,000 SF ADDITION - MASSING


Southwest View



PHASE 3 - PLAN
Demo Harrington Hall + Skywalk Connections



PHASE 3 - MASSING
Southwest View




PHASE 3 - MASSING
Northwest View




102,000 SF ADDITION - MASSING
Southwest View







MASSING SERIES 1



MASSING SERIES 3





MASSING SERIES 2




MASSING SERIES 4: MASSING TO MOVE FORWARD

| | |
|-----------------|--|
| FINAL ROOM LIST | |
|-----------------|--|

| | |
|-----------------|--|
| FINAL ROOM LIST | |
|-----------------|--|






| DEPARTMENT | PHASE 1 | | | PHASE 2 | | |
|---|---------|--------|--------------|---------|--------|--------------|
| | NSF | GSF | COST | NSF | GSF | COST |
| Petroleum Engineering | 2,178 | 3,821 | \$2,006,053 | 3,630 | 6,368 | \$3,025,000 |
| Geology & Geological Engineering | 0 | 0 | \$0 | 0 | 0 | \$0 |
| Civil Engineering | 0 | 0 | \$0 | 9,112 | 15,986 | \$7,505,614 |
| Chemical Engineering | 7,864 | 13,796 | \$6,585,482 | 4,840 | 8,491 | \$4,404,825 |
| Electrical Engineering & Computer Science | 2,387 | 4,188 | \$1,943,333 | 4,719 | 8,279 | \$3,693,684 |
| Institute for Energy Studies | 0 | 0 | \$4,852,719 | 0 | 0 | \$0 |
| Mechanical Engineering | 5,703 | 10,005 | \$0 | 2,904 | 5,095 | \$2,420,000 |
| College of Engineering | 1,452 | 2,547 | \$1,273,684 | 0 | 0 | \$0 |
| Registrar | 0 | 0 | \$0 | 0 | 0 | \$0 |
| Biomedical Engineering | 9,702 | 17,021 | \$7,411,491 | 0 | 0 | \$0 |
| Totals | 29,286 | 51,379 | \$24,072,763 | 25,205 | 44,219 | \$21,049,123 |



| | PHASE ONE | SUMMARY | | PHASE TWO | SUMMARY |
|------|--------------|--|------|--------------|--|
| NSF | 29,286 | New addition of laboratory spaces and entryway with commons. | NSF | 29,286 | New addition of laboratory spaces and entryway with commons. |
| GSF | 51,379 | | GSF | 51,379 | |
| COST | \$24,072,763 | | COST | \$24,072,763 | |



| DEPARTMENT | PHASE 1 | | | PHASE 2 | | |
|---|---------|--------|--------------|---------|--------|--------------|
| | NSF | GSF | COST | NSF | GSF | COST |
| Petroleum Engineering | 2,178 | 3,821 | \$2,006,053 | 3,630 | 6,368 | \$3,025,000 |
| Geology & Geological Engineering | 0 | 0 | \$0 | 0 | 0 | \$0 |
| Civil Engineering | 0 | 0 | \$0 | 9,112 | 15,986 | \$7,505,614 |
| Chemical Engineering | 7,864 | 13,796 | \$6,585,482 | 4,840 | 8,491 | \$4,404,825 |
| Electrical Engineering & Computer Science | 2,387 | 4,188 | \$1,943,333 | 4,719 | 8,279 | \$3,693,684 |
| Institute for Energy Studies | 0 | 0 | \$4,852,719 | 0 | 0 | \$0 |
| Mechanical Engineering | 5,703 | 10,005 | \$0 | 2,904 | 5,095 | \$2,420,000 |
| College of Engineering | 1,452 | 2,547 | \$1,273,684 | 0 | 0 | \$0 |
| Registrar | 0 | 0 | \$0 | 0 | 0 | \$0 |
| Biomedical Engineering | 9,702 | 17,021 | \$7,411,491 | 0 | 0 | \$0 |
| Totals | 29,286 | 51,379 | \$24,072,763 | 25,205 | 44,219 | \$21,049,123 |